

ELEVENTH EDITION

HVAC

ENGINEER'S HANDBOOK

F. PORGES



HVAC Engineer's Handbook

<http://boilersinfo.com/>

This Page Intentionally Left Blank

HVAC

Engineer's

Handbook

Eleventh edition

F. Porges

LL.B, BSc(Eng), CEng, FIMechE, MIEE, FCIBSE

BUTTERWORTH
HEINEMANN


OXFORD AUCKLAND BOSTON JOHANNESBURG MELBOURNE NEW DELHI

Butterworth-Heinemann

Linacre House, Jordan Hill, Oxford OX2 8DP

225 Wildwood Avenue, Woburn, MA 01801-2041

A division of Reed Educational and Professional Publishing Ltd

 A member of the Reed Elsevier plc group

First published as *Handbook of Heating, Ventilating and Air Conditioning* 1942

Second edition 1946

Third edition 1952

Fourth edition 1960

Fifth edition 1964

Sixth edition 1971

Seventh edition 1976

Eighth edition 1982

Ninth edition 1991

Tenth edition 1995

Reprinted 1997, 1998

Eleventh edition 2001

© F. Porges 1982, 1991, 1995, 2001

All rights reserved. No part of this publication may be reproduced in any material form (including photocopying or storing in any medium by electronic means and whether or not transiently or incidentally to some other use of this publication) without the written permission of the copyright holder except in accordance with the provisions of the Copyright, Designs and Patents Act 1988 or under the terms of a licence issued by the Copyright Licensing Agency Ltd, 90 Tottenham Court Road, London, England W1P 9HE. Applications for the copyright holder's written permission to reproduce any part of this publication should be addressed to the publishers.

British Library Cataloguing in publication Data

A catalogue record for this book is available from the British Library

Library of Congress Cataloguing in publication Data

A catalogue record for this book is available from the Library of Congress

ISBN 0 7506 4606 3

Printed and bound in Great Britain by MPG Books Ltd, Bodmin, Cornwall



FOR EVERY TITLE THAT WE PUBLISH, BUTTERWORTH-HEINEMANN
WILL PAY FOR BTCV TO PLANT AND CARE FOR A TREE

Contents

Preface vii

| | | |
|----|--|-----|
| 1 | Abbreviations, symbols and conversions | 1 |
| 2 | Standards for materials | 11 |
| 3 | Combustion | 30 |
| 4 | Heat and thermal properties of materials | 45 |
| 5 | Properties of steam and air | 69 |
| 6 | Heat losses | 90 |
| 7 | Cooling loads | 113 |
| 8 | Heating systems | 119 |
| 9 | Steam systems | 135 |
| 10 | Domestic services | 151 |
| 11 | Ventilation | 161 |
| 12 | Air conditioning | 190 |
| 13 | Pumps and fans | 223 |
| 14 | Sound | 234 |
| 15 | Labour rates | 243 |
| 16 | Bibliography | 251 |
| 17 | Standards | 255 |

Index 277

This Page Intentionally Left Blank

Preface

This book contains in a readily available form the data, charts and tables which are regularly required by heating, ventilating and air conditioning engineers in their daily work.

The data is presented in a concise manner to enable it to be applied directly in the actual daily work of the HVAC engineer. The book is designed for everyday use and a comprehensive bibliography has been included for the benefit of those who wish to pursue the theoretical side of any particular topic.

For this edition some errors have been corrected, the explanatory notes on the psychrometric chart have been improved and the chart in previous editions has been replaced, with permission, by the well known CIBSE chart. Additional data has been included on design temperatures and ventilation rates and information has been inserted on precautions against legionellosis in both hot water systems and air conditioning plant. The data on duct thicknesses and sizes has been revised to conform to current practice. A new section has been included on natural ventilation and the information on types of refrigeration compressors has been expanded. The data on refrigerants has been completely revised to list the new non-CFC and non-HCFC refrigerants. Practising engineers will still meet old plant which contains refrigerants which are now obsolete or obsolescent, and therefore the properties of the more important of these are also given.

The policy of previous editions of giving tabulated data in both SI and Imperial units has been continued although theoretical expressions are generally given only in SI units.

F. Porges

This Page Intentionally Left Blank

1

Abbreviations, symbols and conversions

Symbols for units

| | | | | | |
|---------------|------------------------------------|-----------------------|--------------------------------|--------------------|-------------------------|
| m | metre | s | second | st | stoke |
| mm | millimetre | min | minute | J | joule |
| μm | micrometre (formerly micron) | h | hour | kWh | kilowatt hour |
| in | inch | d | day | cal | calorie |
| ft | foot | yr | year | Btu | British thermal unit |
| yd | yard | kg | kilogram | W | watt |
| m^2 | square metre | t | tonne | V | volt |
| mm^2 | square millimetre | lb | pound | A | ampere |
| a | acre | gr | grain | VA | volt ampere |
| ha | hectare | cwt | hundred weight | K | kelvin |
| in^2 | square inch | N | newton | $^{\circ}\text{C}$ | degree Celsius |
| ft^2 | square foot | kgf | kilogram force | $^{\circ}\text{F}$ | degree Fahrenheit |
| m^3 | cubic metre | pdl | poundal | $^{\circ}\text{R}$ | degree Rankine |
| l | litre | lbf | pound force | dB | decibel |
| in^3 | cubic inch | Pa | pascal | | |
| ft^3 | cubic foot | m^2/s | metre squared per second | | |
| gal | gallon | | | | |

Symbols for physical quantities

| | | | | | |
|----------|-----------------------------------|----------|----------------------------|------------|--|
| l | length | α | attenuation coefficient | T | thermo- dynamic temperature |
| h | height | β | phase coefficient | θt | common temperature |
| b | width | m | mass | C_p | specific heat capacity at constant pressure |
| r | radius | ρ | density | C_v | specific heat capacity at constant volume |
| d | diameter | d | relative density | U | thermal trans- mittance |
| AS | area | F | force | k | thermal conductivity |
| V | volume | W | weight | | |
| t | time | M | moment | | |
| T | period (time of one cycle) | h | pressure | | |
| uvw | velocity | w | work | | |
| ω | angular velocity | p | power | | |
| a | acceleration | η | efficiency | | |
| g | acceleration due to gravity | ν | kinematic viscosity | | |


Multiples and sub-multiples

| | | | | | |
|------------------|------|---|-------------------|-------|-------|
| $\times 10^{12}$ | tera | T | $\times 10^{-1}$ | deci | d |
| $\times 10^9$ | giga | G | $\times 10^{-2}$ | centi | c |
| $\times 10^6$ | mega | M | $\times 10^{-3}$ | milli | m |
| $\times 10^3$ | kilo | k | $\times 10^{-6}$ | micro | μ |
| | | | $\times 10^{-9}$ | nano | n |
| | | | $\times 10^{-12}$ | pico | p |

Abbreviations used on drawings

| | | | |
|------|--|------|---|
| BBOE | bottom bottom opposite ends (radiator connections) | LSV | lockshield valve |
| CF | cold feed | MV | mixing valve |
| CW | cold water | MW | mains water |
| DC | drain cock | NB | nominal bore |
| EC | emptying cock | NTS | not to scale |
| F | flow | PR | primary (hot water flow) |
| FA | from above | R | return |
| TA | to above | SEC | secondary |
| FS | fire service | TA | to above |
| FTA | from and to above | TB | to below |
| FTB | from and to below | TBOE | top bottom opposite ends (radiator connections) |
| FW | fresh water | TBSE | top bottom same end |
| GV | gate valve | TW | tank water |
| HTG | heating | TWDS | tank water down service |

Standard sizes of drawing sheets





























| <i>Designation</i> | <i>Size of sheet</i> | | <i>Size of frame</i> | |
|--------------------|-----------------------|-----------------------|-----------------------|-----------------------|
| | <i>A</i> <i>mm</i> | <i>B</i> <i>mm</i> | <i>C</i> <i>mm</i> | <i>D</i> <i>mm</i> |
| A0 | 841 | 1189 | 791 | 1139 |
| A1 | 594 | 841 | 554 | 804 |
| A2 | 420 | 594 | 380 | 554 |
| A3 | 297 | 420 | 267 | 390 |
| A4 | 210 | 297 | 180 | 267 |



















Recommended scales for drawings

| | | | |
|-----|------|-------|--------|
| 1:1 | 1:10 | 1:100 | 1:1000 |
| 1:2 | 1:20 | 1:200 | |
| 1:5 | 1:50 | 1:500 | |

Symbols on drawings (based on BS 1553)

| | |
|--|--|
|  PIPE |  ANGLE VALVE |
|  PIPE BELOW GROUND |  RELIEF VALVE |
|  PIPE AT HIGH LEVEL |  ANGLE RELIEF VALVE |
|  EXISTING PIPE TO BE REMOVED |  NON-RETURN VALVE |
|  CROSSING, UNCONNECTED |  THREE-WAY VALVE |
|  JUNCTION, CONNECTED |  FOUR-WAY VALVE |
|  INDICATION OF FLOW DIRECTION |  FLOAT OPERATED IN LINE VALVE |
|  FALL 1 : 200 INDICATION OF FALL |  GLOBE VALVE |
|  HEATED OR COOLED |  BALL VALVE |
|  JACKETED |  BELLOWS |
|  GUIDE |  STRAINER OR FILTER |
|  ANCHOR |  TUNDISH |
|  IN LINE VALVE (ANY TYPE) |  OPEN VENT |

Symbols on drawings (continued)

| | | | |
|---|-----------------------------------|---|-------------------------------------|
|  | AXIAL FLOW FAN |  | NATURAL CONVECTOR |
|  | CENTRIFUGAL FAN OR PUMP |  | FAN CONVECTOR |
|  | DUCT BEND WITH SPLITTERS |  | RADIANT PANEL |
|  | MITRE BEND WITH INTERNAL VANES |  | CEILING MOUNTED PANEL |
|  | GRILLE, DIFFUSER |  | HORIZONTAL DISCHARGE HEATER UNIT |
|  | SINGLE LEAF DAMPER |  | DOWNWARD DISCHARGE HEATER UNIT |
|  | MULTI-LEAF DAMPER |  | PROPELLER FAN |
|  | FIRE DAMPER |  | AIR FILTER |
|  | RADIATOR |  | AUTOMATIC AIR VALVE |

Conversions

Length

$$\begin{aligned}
 1 \text{ in} &= 25.4 \text{ mm} \\
 &= 0.0254 \text{ m} \\
 1 \text{ ft} &= 0.3048 \text{ m} \\
 1 \text{ yd} &= 0.9144 \text{ m} \\
 1 \text{ m} &= 3.2808 \text{ ft} \\
 &= 1.0936 \text{ yd} \\
 1 \text{ mm} &= 0.03937 \text{ in}
 \end{aligned}$$

Area

$$\begin{aligned}
 1 \text{ in}^2 &= 6.452 \text{ cm}^2 \\
 &= 6.452 \times 10^{-4} \text{ m}^2 \\
 1 \text{ ft}^2 &= 0.0929 \text{ m}^2 \\
 1 \text{ yd}^2 &= 0.836 \text{ m}^2 \\
 1 \text{ ac} &= 4840 \text{ yd}^2 \\
 &= 0.4047 \text{ ha} \\
 1 \text{ mm}^2 &= 1.55 \times 10^{-3} \text{ in}^2 \\
 1 \text{ m}^2 &= 10.764 \text{ ft}^2 \\
 &= 1.196 \text{ yd}^2 \\
 1 \text{ ha} &= 10^4 \text{ m}^2 \\
 &= 2.471 \text{ ac}
 \end{aligned}$$

Volume

$$\begin{aligned}
 1 \text{ in}^3 &= 16.39 \text{ cm}^3 \\
 &= 1.639 \times 10^{-5} \text{ m}^3 \\
 1 \text{ ft}^3 &= 0.0283 \text{ m}^3 \\
 &= 6.23 \text{ gal} \\
 1 \text{ yd}^3 &= 0.7646 \text{ m}^3 \\
 1 \text{ gal} &= 4.546 \text{ l} \\
 &= 4.546 \times 10^{-3} \text{ m}^3 \\
 &= 0.16 \text{ ft}^3 \\
 1 \text{ pint} &= 0.568 \text{ l} \\
 1 \text{ U.S. gal} &= 0.83 \text{ Imperial gal} \\
 1 \text{ m}^3 &= 0.061 \text{ in}^2 \\
 1 \text{ m}^3 &= 35.31 \text{ ft}^3 \\
 &= 1.308 \text{ yd}^3 \\
 &= 220.0 \text{ gal} \\
 1 \text{ l} &= 0.220 \text{ gal}
 \end{aligned}$$

Mass

$$\begin{aligned}
 1 \text{ grain} &= 0.000143 \text{ lb} \\
 &= 0.0648 \text{ g} \\
 1 \text{ lb} &= 7000 \text{ grains} \\
 &= 0.4536 \text{ kg} \\
 &= 453.6 \text{ g}
 \end{aligned}$$

$$\begin{aligned}
 1 \text{ g} &= 15.43 \text{ grains} \\
 &= 0.0353 \text{ oz} \\
 &= 0.002205 \text{ lb} \\
 1 \text{ kg} &= 2.205 \text{ lb} \\
 1 \text{ tonne} &= 1000 \text{ kg} \\
 &= 0.984 \text{ tons}
 \end{aligned}$$

Content by weight

$$\begin{aligned}
 1 \text{ g/kg} &= 7.0 \text{ gr/lb} \\
 1 \text{ gr/lb} &= 0.143 \text{ g/kg}
 \end{aligned}$$

Density

$$\begin{aligned}
 1 \text{ lb/ft}^3 &= 16.02 \text{ kg/m}^3 \\
 1 \text{ kg/l} &= 62.43 \text{ lb/ft}^3 \\
 1 \text{ kg/m}^3 &= 0.0624 \text{ lb/ft}^3
 \end{aligned}$$

Velocity and volume flow

$$\begin{aligned}
 1 \text{ ft/min} &= 0.00508 \text{ m/s} \\
 1 \text{ m/s} &= 196.85 \text{ ft/min} \\
 1 \text{ kg/s (water)} &= 13.20 \text{ gal/min} \\
 1 \text{ m}^3/\text{s} &= 2118.9 \text{ ft}^3/\text{min} \\
 1 \text{ ft}^3/\text{min} &= 1.7 \text{ m}^3/\text{h} \\
 &= 0.47 \text{ l/s} \\
 1 \text{ l/s} &= 792 \text{ gal/h} \\
 &= 13.2 \text{ gal/min}
 \end{aligned}$$

Heat flow

$$\begin{aligned}
 1 \text{ Btu/h} &= 0.293 \text{ watt} \\
 1 \text{ kW} &= 1000 \text{ J/s} \\
 &= 3.6 \times 10^6 \text{ J/h} \\
 &= 1.360 \text{ metric} \\
 &\quad \text{horse power} \\
 &= 737 \text{ ft lb/s} \\
 &= 3412 \text{ Btu/h} \\
 &= 860 \text{ kcal/h} \\
 1 \text{ kcal/h} &= 1.16 \times 10^{-3} \text{ kW} \\
 1 \text{ Btu/ft}^2 &= 2.713 \text{ kcal/m}^2 \\
 &= 1.136 \times 10^4 \text{ J/m}^2 \\
 1 \text{ Btu/ft}^2 \text{ h} &= 3.155 \text{ W/m}^2 \\
 1 \text{ Btu/ft}^3 \text{ h} &= 10.35 \text{ W/m}^3 \\
 1 \text{ Btu/ft}^2 \text{ }^\circ\text{F} &= 4.88 \text{ kcal/m}^2 \text{ K} \\
 &= 2.043 \times 10^4 \text{ J/m}^2 \text{ K} \\
 1 \text{ Btu/ft}^3 &= 8.9 \text{ kcal/m}^3 \\
 &= 3.73 \times 10^4 \text{ J/m}^3
 \end{aligned}$$

Conversions (continued)

| | |
|---|---|
| 1 Btu/lb = 0.556 kcal/kg | = 0.295 × 10 ⁻³ in mercury |
| = 2326 J/kg | = 7.55 × 10 ⁻³ mm mercury |
| 1 kcal/m ² = 0.369 Btu/ft ² | mercury |
| 1 kcal/m ² K = 0.205 Btu/ft ² °F | = 0.1024 kg/m ² |
| 1 kcal/m ³ = 0.112 Btu/ft ³ | = 0.993 × 10 ⁻⁵ atm |
| 1 kcal/kg = 1.800 Btu/lb | 1 kN/m ² = 1 × 10 ⁻² bar |
| 1 ton refrigeration = 12.000 Btu/h | 1 in water = 0.0361 lb/in ² |
| = 3.516 kw | = 249 N/m ² |
| 1 ft ² h °F/Btu = 0.18 m ² K/w | = 25.4 kg/m ² |
| 1 ft ² h °F/Btu in = 6.9 m K/w | = 0.0739 in mercury |
| 1 Btu/h ft ² °F = 5.68 W/m ² K | 1 mm water = 1.42 × 10 ⁻³ lb/in ² |
| | = 9.80 N/m ² |
| | = 1 kg/m ² |
| | = 0.0736 mm mercury |
| | = 0.9677 × 10 ⁻⁴ atm |
| Pressure | 1 in mercury = 0.49 lb/in ² |
| 1 atm = 1.033 × 10 ⁴ kg/m ² | = 3378 N/m ² |
| = 1.033 kg/cm ² | = 12.8 in water |
| = 1.013 × 10 ² kN/m ² | 1 mm mercury = 0.0193 lb/in ² |
| = 1.013 bar | = 133 N/m ² |
| = 14.7 lb/in ² | = 12.8 mm water |
| = 407.1 in water at 62°F | 1 bar = 1 × 10 ⁵ N/m ² |
| = 10.33 m in water at 62°F | = 14.52 lb/in ² |
| = 30 in mercury at 62°F | = 100 kN/m ² |
| = 760 mm mercury at 62°F | = 10.4 mm w.g. |
| 1 lb/in ² = 6895 N/m ² | 1 Pa = 1 N/m ² |
| = 6.895 × 10 ⁻² bar | |
| = 27.71 in water at 62°F | |
| = 703.1 mm water at 62°F | |
| = 2.0416 in mercury at 62°F | |
| = 51.8 mm mercury at 62°F | |
| = 703.6 kg/m ² | |
| = 0.068 atm | |
| 1 kg/m ² = 1.422 × 10 ⁻³ lb/in ² | |
| = 9.81 N/m ² | |
| = 0.0394 in water | |
| = 1 mm water | |
| = 0.0736 mm mercury | |
| = 0.9681 × 10 ⁻⁴ atm | |
| 1 N/m ² = 0.1450 × 10 ⁻³ lb/in ² | |
| = 1 × 10 ⁻⁵ bar | |
| = 1 × 10 ⁻² mbar | |
| = 4.03 × 10 ⁻³ in water | |
| = 0.336 × 10 ⁻³ ft water | |
| = 0.1024 mm water | |
| | Energy and heat |
| | 1 joule = 1 watt second |
| | = 1 Nm |
| | = 0.74 ft lb |
| | = 9.478 × 10 ⁻⁴ Btu |
| | 1 Btu = 1.055 × 10 ³ joule |
| | = 0.252 kcal |
| | = 778 ft lb |
| | = 0.293 watt hour |
| | 1 kcal = 3.9683 Btu |
| | = 427 kg m |
| | = 4.187 × 10 ³ joule |
| | 1 ft lb = 0.1383 kg m |
| | = 0.001286 Btu |
| | = 1.356 joule |
| | 1 kg m = 7.233 ft lb |
| | = 0.00929 Btu |
| | = 9.806 joule |

Conversions (*continued*)**Power**

$$1 \text{ watt} = 1 \text{ Nm/s}$$

$$1 \text{ horse power} = 550 \text{ ft lb/s}$$

$$= 33,000 \text{ ft lb/m}$$

$$= 1.0139 \text{ metric horse}$$

power

$$= 746 \text{ W}$$

$$= 2545 \text{ Btu/h}$$

1 metric horse

$$\text{power} = 736 \text{ W}$$

$$= 75 \text{ kg m/s}$$

$$= 0.986 \text{ English horse}$$

power

Temperatures

$$^{\circ}\text{F} = \left(\frac{9}{5} ^{\circ}\text{C}\right) + 32$$

$$^{\circ}\text{C} = \frac{5}{9} (^{\circ}\text{F} - 32)$$

$$1 \text{ deg F} = 0.555 \text{ deg C}$$

$$1 \text{ deg C} = 1.8 \text{ deg F}$$

Viscosity

$$1 \text{ poise} = 0.1 \text{ kg/ms}$$

$$= 0.1 \text{ N s/m}^2$$

$$1 \text{ stoke} = 1 \times 10^{-4} \text{ m}^2/\text{s}$$

Force

$$1 \text{ N} = 0.2248 \text{ lbf}$$

$$1 \text{ lbf} = 4.448 \text{ N}$$

A mass of 1 kg has a weight of 1 kp

$$1 \text{ kp} = 9.81 \text{ N}$$

Acceleration due to gravity

$$\text{in London} = 32.2 \text{ ft/s}^2$$

$$= 9.81 \text{ m/s}^2$$

$$\text{at Equator} = 32.1 \text{ ft/s}^2$$

$$= 9.78 \text{ m/s}^2$$

Conversion tables

Temperature conversion table. Degrees Fahrenheit to Degrees Centigrade (Figures in italics represent negative values on the Centigrade Scale)

| <i>Degrees</i> | | | | | | | | | | |
|----------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| <i>F</i> | <i>0</i> | <i>1</i> | <i>2</i> | <i>3</i> | <i>4</i> | <i>5</i> | <i>6</i> | <i>7</i> | <i>8</i> | <i>9</i> |
| | <i>°C</i> | <i>°C</i> | <i>°C</i> | <i>°C</i> | <i>°C</i> | <i>°C</i> | <i>°C</i> | <i>°C</i> | <i>°C</i> | <i>°C</i> |
| 0 | <i>17.8</i> | <i>17.2</i> | <i>16.7</i> | <i>16.1</i> | <i>15.6</i> | <i>15.0</i> | <i>14.4</i> | <i>13.9</i> | <i>13.3</i> | <i>12.8</i> |
| 10 | <i>12.2</i> | <i>11.7</i> | <i>11.1</i> | <i>10.6</i> | <i>10.0</i> | <i>9.4</i> | <i>8.9</i> | <i>8.3</i> | <i>7.8</i> | <i>7.2</i> |
| 20 | <i>6.7</i> | <i>6.1</i> | <i>5.6</i> | <i>5.0</i> | <i>4.4</i> | <i>3.9</i> | <i>3.3</i> | <i>2.8</i> | <i>2.2</i> | <i>1.7</i> |
| 30 | <i>1.1</i> | <i>0.6</i> | — | — | — | — | — | — | — | — |
| 30 | 0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 |
| 40 | 4.4 | 5.0 | 5.6 | 6.1 | 6.7 | 7.2 | 7.8 | 8.3 | 8.9 | 9.4 |
| 50 | 10.0 | 10.6 | 11.1 | 11.7 | 12.2 | 12.8 | 13.3 | 13.9 | 14.4 | 15.0 |
| 60 | 15.6 | 16.1 | 16.7 | 17.2 | 17.8 | 18.3 | 18.9 | 19.4 | 20.0 | 20.6 |
| 70 | 21.1 | 21.7 | 22.2 | 22.8 | 23.3 | 23.9 | 24.4 | 25.0 | 25.6 | 26.1 |
| 80 | 26.7 | 27.2 | 27.8 | 28.3 | 28.9 | 29.4 | 30.0 | 30.6 | 31.1 | 31.7 |
| 90 | 32.2 | 32.8 | 33.3 | 33.9 | 34.4 | 35.0 | 35.6 | 36.1 | 36.7 | 37.2 |
| 100 | 37.8 | 38.3 | 38.9 | 39.4 | 40.0 | 40.6 | 41.1 | 42.7 | 42.2 | 42.8 |
| 110 | 43.3 | 43.9 | 44.4 | 45.0 | 45.6 | 46.1 | 46.7 | 47.2 | 47.8 | 48.3 |
| 120 | 48.9 | 49.4 | 50.0 | 50.6 | 51.1 | 51.7 | 52.2 | 52.8 | 53.3 | 53.9 |
| 130 | 54.4 | 55.0 | 55.6 | 56.1 | 56.7 | 57.2 | 57.8 | 58.3 | 58.9 | 59.4 |
| 140 | 60.0 | 60.6 | 61.1 | 61.7 | 62.2 | 62.8 | 63.3 | 63.9 | 64.4 | 65.0 |
| 150 | 65.6 | 66.1 | 66.7 | 67.2 | 67.8 | 68.3 | 68.9 | 69.4 | 70.0 | 70.6 |
| 160 | 71.1 | 71.7 | 72.2 | 72.8 | 73.3 | 73.9 | 74.4 | 75.0 | 75.6 | 76.1 |
| 170 | 76.7 | 77.2 | 77.8 | 78.3 | 78.9 | 79.4 | 80.0 | 80.6 | 81.1 | 81.7 |
| 180 | 82.2 | 82.8 | 83.3 | 83.9 | 84.4 | 85.0 | 85.6 | 86.1 | 86.7 | 87.2 |
| 190 | 87.8 | 88.3 | 88.9 | 89.4 | 90.0 | 90.6 | 91.1 | 91.7 | 92.2 | 92.8 |
| 200 | 93.3 | 93.9 | 94.4 | 95.0 | 95.6 | 96.1 | 96.7 | 97.2 | 97.8 | 98.3 |
| 210 | 98.9 | 99.4 | 100.0 | 100.6 | 101.1 | 101.7 | 102.2 | 102.8 | 103.3 | 103.9 |
| 220 | 104.4 | 105.0 | 105.6 | 106.1 | 106.7 | 107.2 | 107.8 | 108.3 | 108.9 | 109.4 |
| 230 | 110.0 | 110.6 | 111.1 | 111.7 | 112.2 | 112.8 | 113.3 | 113.9 | 114.4 | 115.0 |
| 240 | 115.6 | 116.1 | 116.7 | 117.2 | 117.8 | 118.3 | 118.9 | 119.4 | 120.0 | 120.6 |
| 250 | 121.1 | 121.7 | 122.2 | 122.8 | 123.3 | 123.9 | 124.4 | 125.0 | 125.6 | 126.1 |

$$F = (C \times 1.8) + 32$$

Temperature conversion table. Degrees Fahrenheit to Degrees Centigrade (*continued*)

| <i>Degrees</i> | | | | | | | | | | |
|----------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| <i>F</i> | 0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 |
| | °C | °C | °C | °C | °C | °C | °C | °C | °C | °C |
| 260 | 126.7 | 127.2 | 127.8 | 128.3 | 128.9 | 129.4 | 130.0 | 130.6 | 131.1 | 131.7 |
| 270 | 132.2 | 132.8 | 133.3 | 133.9 | 134.4 | 135.0 | 135.6 | 136.1 | 136.7 | 137.2 |
| 280 | 137.8 | 138.3 | 138.9 | 139.4 | 140.0 | 140.6 | 141.1 | 141.7 | 142.2 | 142.8 |
| 290 | 143.3 | 143.9 | 144.5 | 145.0 | 145.6 | 146.1 | 146.7 | 147.2 | 147.8 | 148.3 |
| 300 | 148.9 | 149.4 | 150.0 | 150.6 | 151.1 | 151.7 | 152.2 | 152.8 | 153.3 | 153.9 |
| 310 | 154.4 | 155.0 | 155.6 | 156.1 | 156.7 | 157.2 | 157.8 | 158.3 | 158.9 | 159.4 |
| 320 | 160.0 | 160.6 | 161.1 | 161.7 | 162.2 | 162.8 | 163.3 | 163.9 | 164.4 | 165.0 |
| 330 | 165.6 | 166.1 | 166.7 | 167.2 | 167.8 | 168.3 | 168.9 | 169.4 | 170.0 | 170.6 |
| 340 | 171.1 | 171.7 | 172.2 | 172.8 | 173.2 | 173.9 | 174.4 | 175.0 | 175.6 | 176.1 |
| 350 | 176.7 | 177.2 | 177.8 | 178.3 | 178.9 | 179.4 | 180.0 | 180.6 | 181.1 | 181.7 |
| 360 | 182.2 | 182.8 | 183.3 | 183.9 | 184.4 | 185.0 | 185.6 | 186.1 | 186.7 | 187.2 |
| 370 | 187.8 | 188.3 | 188.9 | 189.4 | 190.0 | 190.6 | 191.1 | 191.7 | 192.2 | 192.8 |
| 380 | 193.3 | 193.9 | 194.4 | 195.0 | 195.6 | 196.1 | 196.7 | 197.2 | 197.8 | 198.3 |
| 390 | 198.9 | 199.4 | 200.0 | 200.6 | 201.1 | 201.7 | 202.2 | 202.8 | 203.3 | 203.9 |
| 400 | 204.4 | 205.0 | 205.6 | 206.1 | 206.7 | 207.2 | 207.8 | 208.3 | 208.9 | 209.4 |
| 410 | 210.0 | 210.6 | 211.1 | 211.7 | 212.2 | 212.8 | 213.3 | 213.9 | 214.4 | 215.0 |
| 420 | 215.6 | 216.1 | 216.7 | 217.2 | 217.8 | 218.3 | 218.9 | 219.4 | 220.2 | 220.6 |
| 430 | 221.1 | 221.7 | 222.2 | 222.8 | 223.3 | 223.9 | 224.4 | 225.0 | 225.6 | 226.1 |
| 440 | 226.7 | 227.2 | 227.8 | 228.3 | 228.9 | 229.4 | 230.0 | 230.6 | 231.1 | 231.7 |
| 450 | 232.2 | 232.8 | 233.3 | 233.9 | 234.4 | 235.0 | 235.6 | 236.1 | 236.7 | 237.2 |
| 460 | 237.8 | 238.3 | 238.9 | 239.4 | 240.0 | 240.6 | 241.1 | 241.7 | 242.2 | 242.8 |
| 470 | 243.3 | 243.9 | 244.4 | 245.0 | 245.6 | 246.1 | 246.7 | 247.2 | 247.8 | 248.3 |
| 480 | 248.9 | 249.4 | 250.0 | 250.6 | 251.1 | 251.7 | 252.2 | 252.8 | 253.3 | 253.9 |
| 490 | 254.4 | 255.0 | 255.6 | 256.1 | 256.7 | 257.2 | 257.8 | 258.3 | 258.9 | 259.4 |
| 500 | 260.0 | — | — | — | — | — | — | — | — | — |

$$F = (C \times 1.8) + 32$$

Temperature conversion table. Degrees Centigrade to Degrees Fahrenheit

| <i>Degrees</i> | | | | | | | | | | |
|----------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| <i>C</i> | 0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 |
| | °F | °F | °F | °F | °F | °F | °F | °F | °F | °F |
| 0 | 32.0 | 33.8 | 35.6 | 37.4 | 39.2 | 41.0 | 42.8 | 44.6 | 46.4 | 48.2 |
| 10 | 50.0 | 51.8 | 53.6 | 55.4 | 57.2 | 59.0 | 60.8 | 62.6 | 64.4 | 66.2 |
| 20 | 68.0 | 69.8 | 71.6 | 73.4 | 75.2 | 77.0 | 78.8 | 80.6 | 82.4 | 84.2 |
| 30 | 86.0 | 87.8 | 89.6 | 91.4 | 93.2 | 95.0 | 96.8 | 98.6 | 101.4 | 102.2 |
| 40 | 104.0 | 105.8 | 107.6 | 109.4 | 111.2 | 113.0 | 114.8 | 116.6 | 118.4 | 120.2 |
| 50 | 122.0 | 123.8 | 125.6 | 127.4 | 129.2 | 131.0 | 132.8 | 134.6 | 136.4 | 138.2 |
| 60 | 140.0 | 141.8 | 143.6 | 145.4 | 147.2 | 149.0 | 150.8 | 152.6 | 154.4 | 156.2 |
| 70 | 158.0 | 159.8 | 161.6 | 163.4 | 165.2 | 167.0 | 168.8 | 170.6 | 172.4 | 174.2 |
| 80 | 176.0 | 177.8 | 179.6 | 181.4 | 183.2 | 185.0 | 186.8 | 188.6 | 190.4 | 192.2 |
| 90 | 194.0 | 195.8 | 197.6 | 199.4 | 201.2 | 203.0 | 204.2 | 206.6 | 208.4 | 210.2 |
| 100 | 212.0 | 213.8 | 215.6 | 217.4 | 219.2 | 221.0 | 222.8 | 224.6 | 226.4 | 228.2 |
| 110 | 230.0 | 231.8 | 233.6 | 235.4 | 237.2 | 239.0 | 240.8 | 242.6 | 244.4 | 246.2 |
| 120 | 248.0 | 249.8 | 251.6 | 253.4 | 255.2 | 257.0 | 258.8 | 260.6 | 262.4 | 264.2 |
| 130 | 266.0 | 267.8 | 269.6 | 271.4 | 273.2 | 275.0 | 276.8 | 278.6 | 280.4 | 282.2 |
| 140 | 284.0 | 285.8 | 287.6 | 289.4 | 291.2 | 293.0 | 294.8 | 296.6 | 298.4 | 300.2 |
| 150 | 302.0 | 303.8 | 305.6 | 307.4 | 309.2 | 311.0 | 312.8 | 314.6 | 316.4 | 318.2 |
| 160 | 320.0 | 321.8 | 323.6 | 325.4 | 327.2 | 329.0 | 330.8 | 332.6 | 334.4 | 336.2 |
| 170 | 338.0 | 339.8 | 341.6 | 343.4 | 345.2 | 347.0 | 348.8 | 350.6 | 352.4 | 354.2 |
| 180 | 356.0 | 357.8 | 359.6 | 361.4 | 363.2 | 365.0 | 366.8 | 368.6 | 370.4 | 372.2 |
| 190 | 374.0 | 375.8 | 377.6 | 379.4 | 381.2 | 383.0 | 384.8 | 386.6 | 388.4 | 390.2 |
| 200 | 392.0 | 393.8 | 395.6 | 397.4 | 399.2 | 401.0 | 402.8 | 404.6 | 406.4 | 408.2 |
| 210 | 410.0 | 411.8 | 413.6 | 415.4 | 417.2 | 419.0 | 420.8 | 422.6 | 424.4 | 426.2 |
| 220 | 428.0 | 429.8 | 431.6 | 433.4 | 435.2 | 437.0 | 438.8 | 440.6 | 442.4 | 444.2 |
| 230 | 446.0 | 447.8 | 449.6 | 451.4 | 453.2 | 455.0 | 456.8 | 458.6 | 460.4 | 462.2 |
| 240 | 464.0 | 465.8 | 467.6 | 469.4 | 471.2 | 473.0 | 474.8 | 476.6 | 478.4 | 480.2 |
| 250 | 482.0 | 483.8 | 485.6 | 487.4 | 489.2 | 491.0 | 492.8 | 494.6 | 496.4 | 498.2 |
| 260 | 500.0 | 501.8 | 503.6 | 505.4 | 507.2 | 509.0 | 510.8 | 512.6 | 514.4 | 516.2 |
| 270 | 518.0 | 519.8 | 521.6 | 523.4 | 525.2 | 527.0 | 528.8 | 530.6 | 532.4 | 534.2 |
| 280 | 536.0 | 537.8 | 539.6 | 541.4 | 543.2 | 545.0 | 546.8 | 548.6 | 550.4 | 552.2 |
| 290 | 554.0 | 555.8 | 557.6 | 559.4 | 561.2 | 563.0 | 563.8 | 566.6 | 568.4 | 570.2 |
| 300 | 572.0 | 573.8 | 575.6 | 577.4 | 579.2 | 581.0 | 582.8 | 584.6 | 586.4 | 588.2 |

$$C = (F - 32) \div 1.8$$

2 Standards for materials

Cold water storage and feed and expansion cisterns to BS 417

Imperial sizes

| Reference Nos. | Length in | Width in | Depth in | Capacity gal | Thickness | |
|----------------|-----------|----------|----------|--------------|-------------------|------------------|
| | | | | | Body B.G. | Loose cover B.G. |
| SC 10 | 18 | 12 | 12 | 4 | 16 | 20 |
| 15 | 24 | 12 | 15 | 8 | 16 | 20 |
| 20 | 24 | 16 | 15 | 12 | 16 | 20 |
| 25 | 24 | 17 | 17 | 15 | 16 | 20 |
| 30 | 24 | 18 | 19 | 19 | 16 | 20 |
| 40 | 27 | 20 | 20 | 25 | 16 | 20 |
| 50 | 29 | 22 | 22 | 35 | 14 | 20 |
| 60 | 30 | 23 | 24 | 42 | 14 | 20 |
| 70 | 36 | 24 | 23 | 50 | 14 | 20 |
| 80 | 36 | 26 | 24 | 58 | 14 | 20 |
| 100/2 | 38 | 27 | 27 | 74 | 14 | 20 |
| 125 | 38 | 30 | 31 | 93 | 12 | 18 |
| 150 | 43 | 34 | 29 | 108 | 12 | 18 |
| 200 | 46 | 35 | 35 | 156 | 12 | 18 |
| 250 | 60 | 36 | 32 | 185 | 12 | 18 |
| 350 | 60 | 45 | 36 | 270 | $\frac{1}{8}$ in | 16 |
| 500 | 72 | 48 | 40 | 380 | $\frac{1}{8}$ in | 16 |
| 600 | 72 | 48 | 48 | 470 | $\frac{1}{8}$ in | 16 |
| 1000 | 96 | 60 | 48 | 740 | $\frac{3}{16}$ in | 16 |

Metric sizes

| Reference No. | Length mm | Width mm | Depth mm | Capacity litres | Thickness | | Loose cover mm |
|---------------|-----------|----------|----------|-----------------|------------|------------|----------------|
| | | | | | Body | | |
| | | | | | Grade A mm | Grade B mm | |
| SCM 45 | 457 | 305 | 305 | 18 | 1.6 | — | 1.0 |
| 70 | 610 | 305 | 381 | 36 | 1.6 | — | 1.0 |
| 90 | 610 | 406 | 381 | 54 | 1.6 | — | 1.0 |
| 110 | 610 | 432 | 432 | 68 | 1.6 | — | 1.0 |
| 135 | 610 | 457 | 482 | 86 | 1.6 | — | 1.0 |
| 180 | 686 | 508 | 508 | 114 | 1.6 | — | 1.0 |

Metric sizes (continued)

| Reference No. | Length mm | Width mm | Depth mm | Capacity litres | Thickness | | |
|---------------|-----------|----------|----------|-----------------|------------|------------|----------------|
| | | | | | Body | | Loose cover mm |
| | | | | | Grade A mm | Grade B mm | |
| 230 | 736 | 559 | 559 | 159 | 2.0 | 1.6 | 1.0 |
| 270 | 762 | 584 | 610 | 191 | 2.0 | 1.6 | 1.0 |
| 320 | 914 | 610 | 584 | 227 | 2.0 | 1.6 | 1.0 |
| 360 | 914 | 660 | 610 | 264 | 2.0 | 1.6 | 1.0 |
| 450/1 | 1219 | 610 | 610 | 327 | 2.0 | 1.6 | 1.0 |
| 450/2 | 965 | 686 | 686 | 336 | 2.0 | 1.6 | 1.0 |
| 570 | 965 | 762 | 787 | 423 | 2.5 | 2.0 | 1.2 |
| 680 | 1092 | 864 | 736 | 491 | 2.5 | 2.0 | 1.2 |
| 910 | 1168 | 889 | 889 | 709 | 2.5 | 2.0 | 1.2 |
| 1130 | 1524 | 914 | 813 | 841 | 2.5 | 2.0 | 1.2 |
| 1600 | 1524 | 1143 | 914 | 1227 | 3.2 | 2.5 | 1.6 |
| 2270 | 1829 | 1219 | 1016 | 1727 | 3.2 | 2.5 | 1.6 |
| 2720 | 1829 | 1219 | 1219 | 2137 | 3.2 | 2.5 | 1.6 |
| 4540 | 2438 | 1524 | 1219 | 3364 | 4.8 | 3.2 | 1.6 |

Closed tanks to BS 417**Imperial sizes**

| Reference No. | Length in | Width in | Depth in | Capacity gal | Thickness in |
|---------------|-----------|----------|----------|--------------|---------------|
| T25/1 | 24 | 17 | 17 | 21 | $\frac{1}{8}$ |
| 25/2 | 24 | 24 | 12 | 21 | $\frac{1}{8}$ |
| 30/1 | 24 | 18 | 19 | 25 | $\frac{1}{8}$ |
| 30/2 | 24 | 24 | 15 | 27 | $\frac{1}{8}$ |
| 40 | 27 | 20 | 20 | 34 | $\frac{1}{8}$ |

Metric sizes

| Reference No. | Length mm | Width mm | Depth mm | Capacity litres | Thickness | |
|---------------|-----------|----------|----------|-----------------|------------|------------|
| | | | | | Grade A mm | Grade B mm |
| TM114/1 | 610 | 432 | 432 | 95 | 3.2 | 2.5 |
| 114/2 | 610 | 610 | 305 | 95 | 3.2 | 2.5 |
| 136/1 | 610 | 457 | 482 | 114 | 3.2 | 2.5 |
| 136/2 | 610 | 610 | 381 | 123 | 3.2 | 2.5 |
| 182 | 690 | 508 | 508 | 155 | 3.2 | 2.5 |

Copper indirect cylinders to BS 1566:1984

| <i>Reference No.</i> | <i>Diameter mm</i> | <i>Height mm</i> | <i>Capacity litres</i> | <i>Heating surface coil m²</i> |
|----------------------|--------------------|------------------|------------------------|---|
| 1 | 350 | 900 | 72 | 0.27 |
| 2 | 400 | 900 | 96 | 0.35 |
| 3 | 400 | 1050 | 114 | 0.42 |
| 4 | 450 | 675 | 84 | 0.31 |
| 5 | 450 | 750 | 95 | 0.35 |
| 6 | 450 | 825 | 106 | 0.40 |
| 7 | 450 | 900 | 117 | 0.44 |
| 8 | 450 | 1050 | 140 | 0.52 |
| 9 | 450 | 1200 | 162 | 0.61 |
| 9E | 450 | 1500 | 206 | 0.79 |
| 10 | 500 | 1200 | 190 | 0.75 |
| 11 | 500 | 1500 | 245 | 0.87 |
| 12 | 600 | 1200 | 280 | 1.10 |
| 13 | 600 | 1500 | 360 | 1.40 |
| 14 | 600 | 1800 | 440 | 1.70 |

Copper direct cylinders to BS 699:1984

| <i>Reference No.</i> | <i>Diameter mm</i> | <i>Height mm</i> | <i>Capacity litres</i> |
|----------------------|--------------------|------------------|------------------------|
| 1 | 350 | 900 | 74 |
| 2 | 400 | 900 | 98 |
| 3 | 400 | 1050 | 116 |
| 4 | 450 | 675 | 86 |
| 5 | 450 | 750 | 98 |
| 6 | 450 | 825 | 109 |
| 7 | 450 | 900 | 120 |
| 8 | 450 | 1050 | 144 |
| 9 | 450 | 1200 | 166 |
| 9E | 450 | 1500 | 210 |
| 10 | 500 | 1200 | 200 |
| 11 | 500 | 1500 | 255 |
| 12 | 600 | 1200 | 290 |
| 13 | 600 | 1500 | 370 |
| 14 | 600 | 1800 | 450 |

**Cold water storage and feed and expansion cisterns
of polyolefin or olefin copolymer to BS 4213**

| <i>Reference no.</i> | <i>Maximum height mm</i> | <i>Capacity litres</i> | <i>Distance of water line from top of cistern mm</i> |
|--------------------------|------------------------------|----------------------------|--|
| PC 4 | 310 | 18 | 110 |
| 8 | 380 | 36 | 110 |
| 15 | 430 | 68 | 115 |
| 20 | 510 | 91 | 115 |
| 25 | 560 | 114 | 115 |
| 40 | 610 | 182 | 115 |
| 50 | 660 | 227 | 115 |
| 60 | 660 | 273 | 115 |
| 70 | 660 | 318 | 115 |
| 100 | 760 | 455 | 115 |

The standard does not specify width and length.

Sheet and wire gauges

| Standard Wire Gauge No. | Birmingham Gauge No. | German Sheet Gauge No. (DIN 1541) | ISO | Thickness | | Weight of Sheet | |
|----------------------------------|-------------------------|---|--|-------------|-------|--------------------|-------------------|
| | | | Metric R20 Preferred Series mm | or Diameter | | lb/ft ² | kg/m ² |
| | | | | in | mm | | |
| 30 | — | — | 0.315 | 0.0124 | 0.315 | 0.48 | 2.5 |
| — | — | 27 | — | 0.0126 | 0.32 | 0.52 | 2.5 |
| 29 | — | — | — | 0.0136 | 0.345 | 0.52 | 2.7 |
| — | 29 | — | — | 0.0139 | 0.354 | 0.56 | 2.8 |
| — | — | — | 0.355 | 0.0140 | 0.355 | 0.56 | 2.8 |
| 28 | — | — | — | 0.0148 | 0.376 | 0.56 | 2.9 |
| — | 28 | — | — | 0.0156 | 0.397 | 0.63 | 3.1 |
| — | — | 26 | — | 0.0150 | 0.38 | 0.62 | 3.0 |
| — | — | — | 0.400 | 0.0158 | 0.400 | 0.64 | 3.1 |
| 27 | — | — | — | 0.0164 | 0.417 | 0.64 | 3.2 |
| — | 27 | — | — | 0.0175 | 0.443 | 0.71 | 3.5 |
| — | — | 25 | — | 0.0172 | 0.44 | 0.70 | 3.5 |
| — | — | — | 0.450 | 0.0177 | 0.450 | 0.72 | 3.5 |
| 26 | — | — | — | 0.018 | 0.457 | 0.72 | 3.6 |
| — | 26 | — | — | 0.0196 | 0.498 | 0.79 | 3.9 |
| — | — | 24 | 0.500 | 0.0197 | 0.500 | 0.80 | 3.9 |
| 25 | — | — | — | 0.020 | 0.508 | 0.80 | 4.0 |
| 24 | — | — | — | 0.022 | 0.559 | 0.88 | 4.4 |
| — | 25 | — | — | 0.022 | 0.560 | 0.89 | 4.4 |
| — | — | 23 | 0.560 | 0.0221 | 0.560 | 0.91 | 4.4 |
| 23 | — | — | — | 0.024 | 0.610 | 1.00 | 4.8 |
| — | 24 | — | — | 0.025 | 0.629 | 1.00 | 4.9 |
| — | — | 22 | 0.630 | 0.0248 | 0.630 | 1.02 | 4.9 |
| — | 23 | — | — | 0.028 | 0.707 | 1.13 | 5.5 |
| — | — | — | 0.710 | 0.0280 | 0.710 | 1.14 | 5.6 |
| 22 | — | — | — | 0.028 | 0.711 | 1.12 | 5.6 |
| — | — | 21 | — | 0.0295 | 0.75 | 1.21 | 5.9 |
| — | 22 | — | — | 0.031 | 0.794 | 1.27 | 6.2 |
| — | — | — | 0.800 | 0.0315 | 0.800 | 1.28 | 6.3 |
| 21 | — | — | — | 0.032 | 0.813 | 1.28 | 6.3 |
| — | — | 20 | — | 0.0346 | 0.88 | 1.41 | 6.9 |
| — | 21 | — | — | 0.035 | 0.887 | 1.41 | 7.0 |
| — | — | — | 0.900 | 0.0354 | 0.900 | 1.42 | 7.1 |
| 20 | — | — | — | 0.036 | 0.914 | 1.42 | 7.2 |
| — | 20 | — | — | 0.039 | 0.996 | 1.59 | 7.8 |
| — | — | 19 | 1.000 | 0.0394 | 1.000 | 1.61 | 7.8 |
| 19 | — | — | — | 0.040 | 1.016 | 1.68 | 8.0 |
| — | 19 | — | — | 0.044 | 1.12 | 1.78 | 8.8 |
| — | — | — | 1.12 | 0.0441 | 1.12 | 1.80 | 8.8 |
| — | — | 18 | — | 0.0443 | 1.13 | 1.81 | 8.9 |

Sheet and wire gauges (continued)

| Standard Wire Gauge No. | Birmingham Gauge No. | German Sheet Gauge No. (DIN 1541) | ISO | Thickness | | Weight of Sheet | |
|----------------------------------|-------------------------|---|--|-------------|-------|--------------------|-------------------|
| | | | Metric R20 Preferred Series mm | or Diameter | | lb/ft ² | kg/m ² |
| | | | | in | mm | | |
| 18 | — | — | — | 0.048 | 1.219 | 1.96 | 9.6 |
| — | — | 17 | 1.25 | 0.0492 | 1.25 | 2.00 | 9.8 |
| — | 18 | — | — | 0.050 | 1.26 | 2.00 | 9.9 |
| — | — | 16 | — | 0.0543 | 1.38 | 2.22 | 10.8 |
| — | — | — | 1.40 | 0.0551 | 1.40 | 2.25 | 11.0 |
| — | 17 | — | — | 0.056 | 1.41 | 2.25 | 11.1 |
| 17 | — | — | — | 0.056 | 1.422 | 2.32 | 11.1 |
| — | — | 15 | — | 0.0591 | 1.50 | 2.42 | 11.7 |
| — | 16 | — | — | 0.063 | 1.59 | 2.53 | 12.4 |
| — | — | — | 1.60 | 0.0630 | 1.60 | 2.58 | 12.5 |
| 16 | — | — | — | 0.064 | 1.626 | 2.60 | 12.7 |
| — | — | 14 | — | 0.0689 | 1.75 | 2.82 | 13.7 |
| — | 15 | — | — | 0.070 | 1.78 | 2.83 | 13.9 |
| — | — | — | 1.80 | 0.0709 | 1.80 | 2.90 | 14.1 |
| 15 | — | — | — | 0.072 | 1.829 | 2.94 | 14.3 |
| — | 14 | — | — | 0.079 | 1.99 | 3.18 | 15.6 |
| — | — | 13 | 2.00 | 0.0787 | 2.00 | 3.18 | 15.7 |
| 14 | — | — | — | 0.080 | 2.032 | 3.32 | 15.9 |
| — | — | — | — | — | — | — | — |
| — | 13 | — | 2.24 | 0.088 | 2.24 | 3.57 | 17.6 |
| — | — | 12 | — | 0.0886 | 2.25 | 3.59 | 17.6 |
| 13 | — | — | — | 0.092 | 2.337 | 3.80 | 18.3 |
| — | — | 11 | 2.50 | 0.0984 | 2.50 | 3.98 | 19.6 |
| — | 12 | — | — | 0.099 | 2.52 | 4.01 | 19.7 |
| 12 | — | — | — | 0.104 | 2.642 | 4.36 | 20.7 |
| — | — | 10 | — | 0.1083 | 2.75 | 4.38 | 21.6 |
| — | — | — | 2.80 | 0.1102 | 2.80 | 4.46 | 22.0 |
| — | 11 | — | — | 0.111 | 2.83 | 4.51 | 22.2 |
| 11 | — | — | — | 0.116 | 2.946 | 4.80 | 23.1 |
| — | — | 9 | — | 0.1181 | 3.00 | 4.56 | 23.5 |
| — | — | — | 3.15 | 0.1240 | 3.15 | 5.02 | 24.7 |
| — | 10 | — | — | 0.125 | 3.18 | 5.06 | 24.8 |
| — | — | 8 | — | 0.1279 | 3.25 | 5.18 | 25.5 |
| 10 | — | — | — | 0.128 | 3.251 | 5.36 | 25.4 |
| — | — | 7 | — | 0.1378 | 3.50 | 5.58 | 27.4 |
| — | 9 | — | 3.55 | 0.140 | 3.55 | 5.66 | 27.8 |
| 9 | — | — | — | 0.144 | 3.658 | 5.92 | 28.7 |
| — | — | 6 | — | 0.1476 | 3.75 | 5.98 | 29.4 |
| — | 8 | — | — | 0.157 | 3.99 | 6.36 | 31.3 |

Sheet and wire gauges (continued)

| Standard Wire Gauge No. | Birmingham Gauge No. | German Sheet Gauge No. (DIN 1541) | ISO Metric R20 Preferred Series mm | Thickness or Diameter | | Weight of Sheet | |
|----------------------------------|-------------------------|---|---|--------------------------|--------|--------------------|-------------------|
| | | | | in | mm | lb/ft ² | kg/m ² |
| — | — | 5 | 4.0 | 0.1575 | 4.0 | 6.38 | 31.4 |
| 8 | — | — | — | 0.160 | 4.064 | 6.60 | 31.9 |
| — | — | 4 | — | 0.1673 | 4.25 | 6.77 | 33.3 |
| 7 | — | — | — | 0.176 | 4.470 | 7.12 | 35.1 |
| — | 7 | — | — | 0.176 | 4.48 | 7.14 | 35.1 |
| — | — | 3 | 4.5 | 0.1772 | 4.50 | 7.17 | 35.3 |
| 6 | — | — | — | 0.192 | 4.877 | 7.80 | 38.2 |
| — | — | 2 | 5.0 | 0.1969 | 5.00 | 7.97 | 39.2 |
| — | 6 | — | — | 0.198 | 5.032 | 8.02 | 39.5 |
| 5 | — | — | — | 0.212 | 5.385 | 8.80 | 42.2 |
| — | — | 1 | — | 0.2165 | 5.50 | 8.77 | 43.1 |
| — | — | — | 5.6 | 0.2205 | 5.6 | 8.93 | 43.9 |
| — | 5 | — | — | 0.222 | 5.66 | 9.01 | 44.4 |
| 4 | — | — | — | 0.232 | 5.893 | 9.52 | 46.2 |
| — | — | — | 6.30 | 0.2480 | 6.30 | 10.04 | 49.4 |
| — | 4 | — | — | 0.250 | 6.35 | 10.12 | 49.9 |
| 3 | — | — | — | 0.252 | 6.401 | 10.36 | 50.2 |
| 2 | — | — | — | 0.276 | 7.010 | 11.17 | 55.0 |
| — | — | — | 7.10 | 0.2795 | 7.10 | 11.32 | 55.7 |
| — | 3 | — | — | 0.280 | 7.13 | 11.34 | 55.9 |
| 1 | — | — | — | 0.300 | 7.620 | 12.0 | 59.7 |
| — | 2 | — | — | 0.315 | 8.00 | 12.74 | 62.7 |
| — | — | — | 8.00 | 0.3150 | 8.00 | 12.74 | 62.7 |
| 0 | — | — | — | 0.324 | 8.229 | 13.1 | 63.9 |
| 2/0 | — | — | — | 0.348 | 8.839 | 13.9 | 69.3 |
| — | 1 | — | — | 0.353 | 8.98 | 14.30 | 70.4 |
| — | — | — | 9.00 | 0.3543 | 9.00 | 14.3 | 70.6 |
| 3/0 | — | — | — | 0.372 | 9.449 | 14.9 | 74.1 |
| — | — | — | 10.00 | 0.3937 | 10.00 | 15.9 | 78.4 |
| — | 0 | — | — | 0.396 | 10.07 | 16.0 | 78.9 |
| 4/0 | — | — | — | 0.400 | 10.160 | 16.0 | 79.7 |
| 5/0 | — | — | — | 0.432 | 10.973 | 17.3 | 86.0 |
| — | — | — | 11.2 | 0.4409 | 11.2 | 17.8 | 87.8 |
| — | 2/0 | — | — | 0.445 | 11.3 | 18.0 | 88.6 |
| 6/0 | — | — | — | 0.464 | 11.785 | 18.6 | 92.4 |
| — | — | — | 12.5 | 0.4921 | 12.5 | 19.9 | 98.0 |
| 7/0 | 3/0 | — | — | 0.500 | 12.700 | 20.0 | 99.5 |

Weight of steel bar and sheet

| <i>Thickness or Diameter mm</i> | <i>Weight in kg of</i> | | | <i>Thickness or Diameter mm</i> | <i>Weight in kg of</i> | | |
|---|------------------------------------|-------------------------|------------------------|---|------------------------------------|-------------------------|------------------------|
| | <i>Sheet per m²</i> | <i>Square per m</i> | <i>Round per m</i> | | <i>Sheet per m²</i> | <i>Square per m</i> | <i>Round per m</i> |
| 5 | 39.25 | 0.196 | 0.154 | 68 | 533.80 | 36.298 | 28.509 |
| 6 | 47.10 | 0.283 | 0.222 | 70 | 569.50 | 36.465 | 30.210 |
| 8 | 62.80 | 0.502 | 0.395 | 72 | 585.20 | 40.694 | 31.961 |
| 10 | 78.50 | 0.785 | 0.617 | 74 | 600.90 | 42.987 | 33.762 |
| 12 | 94.20 | 1.130 | 0.888 | 76 | 616.60 | 45.342 | 35.611 |
| 14 | 109.90 | 1.539 | 1.208 | 78 | 632.30 | 47.759 | 37.510 |
| 16 | 125.60 | 2.010 | 1.578 | 80 | 628.00 | 50.240 | 39.458 |
| 18 | 141.30 | 2.543 | 1.998 | 85 | 667.25 | 56.716 | 44.545 |
| 20 | 157.00 | 3.140 | 2.466 | 90 | 706.50 | 63.585 | 49.940 |
| 22 | 172.70 | 3.799 | 2.984 | 95 | 745.75 | 70.846 | 55.643 |
| 24 | 188.40 | 4.522 | 3.551 | 100 | 785.00 | 78.500 | 61.654 |
| 26 | 204.10 | 5.307 | 4.168 | 105 | 824.25 | 86.546 | 67.973 |
| 28 | 219.80 | 6.154 | 4.834 | 110 | 863.5 | 94.985 | 74.601 |
| 30 | 235.50 | 7.065 | 5.549 | 115 | 902.75 | 103.816 | 81.537 |
| 32 | 251.20 | 8.038 | 6.313 | 120 | 942.0 | 113.040 | 88.781 |
| 34 | 266.90 | 9.075 | 7.127 | 125 | 981.2 | 122.656 | 96.334 |
| 36 | 282.60 | 10.174 | 7.990 | 130 | 1020 | 132.665 | 104.195 |
| 38 | 298.30 | 11.335 | 8.903 | 135 | 1060 | 143.006 | 112.364 |
| 40 | 314.00 | 12.560 | 9.865 | 140 | 1099 | 153.860 | 120.841 |
| 42 | 329.70 | 13.847 | 10.876 | 145 | 1138 | 165.046 | 129.627 |
| 44 | 345.40 | 15.198 | 11.936 | 150 | 1178 | 176.625 | 138.721 |
| 46 | 361.10 | 16.611 | 13.046 | 155 | 1217 | 188.596 | 148.123 |
| 48 | 376.80 | 18.086 | 14.205 | 160 | 1256 | 200.960 | 157.834 |
| 50 | 392.50 | 19.625 | 15.413 | 165 | 1295 | 213.716 | 167.852 |
| 52 | 408.20 | 21.226 | 16.671 | 170 | 1355 | 226.865 | 178.179 |
| 54 | 423.90 | 22.891 | 17.978 | 175 | 1394 | 240.406 | 188.815 |
| 56 | 439.60 | 24.618 | 19.335 | 180 | 1413 | 254.340 | 199.758 |
| 58 | 455.30 | 26.407 | 20.740 | 185 | 1452 | 268.666 | 211.010 |
| 60 | 471.00 | 28.260 | 22.195 | 190 | 1492 | 283.385 | 222.570 |
| 62 | 486.70 | 30.175 | 23.700 | 195 | 1511 | 298.496 | 234.438 |
| 64 | 502.40 | 32.154 | 25.253 | 200 | 1570 | 314.000 | 246.615 |
| 66 | 518.10 | 34.195 | 26.856 | | | | |

Weight of steel bar and sheet

| <i>Thickness or Diameter in</i> | <i>Weight in lb of</i> | | | <i>Thickness or Diameter in</i> | <i>Weight in lb of</i> | | |
|---|-------------------------------------|--------------------------|-------------------------|---|-------------------------------------|--------------------------|-------------------------|
| | <i>Sheet per ft²</i> | <i>Square per ft</i> | <i>Round per ft</i> | | <i>Sheet per ft²</i> | <i>Square per ft</i> | <i>Round per ft</i> |
| $\frac{1}{8}$ | 5.10 | 0.053 | 0.042 | 1 | 40.80 | 3.40 | 2.68 |
| $\frac{3}{16}$ | 7.65 | 0.120 | 0.094 | $1\frac{1}{8}$ | 45.9 | 4.31 | 3.38 |
| $\frac{1}{4}$ | 10.20 | 0.213 | 0.167 | $1\frac{1}{4}$ | 51.0 | 5.32 | 4.17 |
| $\frac{5}{16}$ | 12.75 | 0.332 | 0.261 | $1\frac{3}{8}$ | 56.1 | 6.43 | 5.05 |
| $\frac{3}{8}$ | 15.30 | 0.479 | 0.376 | $1\frac{1}{2}$ | 61.2 | 7.71 | 6.01 |
| $\frac{7}{16}$ | 17.85 | 0.651 | 0.511 | $1\frac{5}{8}$ | 66.3 | 8.99 | 7.05 |
| $\frac{1}{2}$ | 20.40 | 0.851 | 0.658 | $1\frac{3}{4}$ | 71.4 | 10.4 | 8.19 |
| $\frac{9}{16}$ | 22.95 | 1.08 | 0.845 | $1\frac{7}{8}$ | 76.5 | 12.0 | 9.39 |
| $\frac{5}{8}$ | 25.50 | 1.33 | 1.04 | 2 | 81.6 | 13.6 | 10.7 |
| $\frac{11}{16}$ | 28.05 | 1.61 | 1.29 | $2\frac{1}{2}$ | 102.2 | 21.3 | 16.8 |
| $\frac{3}{4}$ | 30.60 | 1.91 | 1.50 | 3 | 122.4 | 30.6 | 24.1 |
| $\frac{13}{16}$ | 33.15 | 2.25 | 1.77 | 4 | 163.2 | 54.4 | 42.8 |
| $\frac{7}{8}$ | 35.70 | 2.61 | 2.04 | 5 | 204.0 | 85.1 | 66.9 |
| $\frac{15}{16}$ | 38.25 | 2.99 | 2.35 | 6 | 324.8 | 122.5 | 96.2 |

British Standard flanges

Steel flanges to BS 1560 Sect. 3.1: 1989

These are interchangeable with flanges to ANSI B16.5
Class 150

| <i>Nominal pipe size in</i> | <i>Outside diameter of flange mm</i> | <i>Diameter of bolt circle mm</i> | <i>No. of bolts</i> | <i>Size of bolts in</i> |
|-------------------------------------|--|---|---------------------|-----------------------------|
| $\frac{1}{2}$ | 89 | 60.3 | 4 | $\frac{1}{2}$ |
| $\frac{3}{4}$ | 98 | 69.8 | 4 | $\frac{1}{2}$ |
| 1 | 108 | 79.4 | 4 | $\frac{1}{2}$ |
| $1\frac{1}{2}$ | 127 | 98.4 | 4 | $\frac{1}{2}$ |
| 2 | 152 | 120.6 | 4 | $\frac{5}{8}$ |
| $2\frac{1}{2}$ | 178 | 139.7 | 4 | $\frac{5}{8}$ |
| 3 | 190 | 152.4 | 4 | $\frac{5}{8}$ |
| 4 | 229 | 190.5 | 8 | $\frac{5}{8}$ |
| 6 | 279 | 241.3 | 8 | $\frac{3}{4}$ |
| 8 | 343 | 298.4 | 8 | $\frac{3}{4}$ |
| 10 | 406 | 362.0 | 12 | $\frac{7}{8}$ |
| 12 | 483 | 431.8 | 12 | $\frac{7}{8}$ |
| 14 | 533 | 476.2 | 12 | 1 |
| 16 | 597 | 539.8 | 16 | 1 |
| 18 | 635 | 577.8 | 16 | $1\frac{1}{8}$ |
| 20 | 698 | 635.0 | 20 | $1\frac{1}{8}$ |
| 24 | 813 | 749.3 | 20 | $1\frac{1}{4}$ |

British Standard flanges

Steel flanges to BS 1560 Sect. 3.1: 1989

These are interchangeable with flanges to ANSI B16.5

Class 300

| <i>Nominal pipe size in</i> | <i>Outside diameter of flange mm</i> | <i>Diameter of bolt circle mm</i> | <i>No. of bolts</i> | <i>Size of bolts in</i> |
|---|--|---|-------------------------|---------------------------------|
| $\frac{1}{2}$ | 95 | 66.7 | 4 | $\frac{1}{2}$ |
| $\frac{3}{4}$ | 117 | 82.6 | 4 | $\frac{5}{8}$ |
| 1 | 124 | 88.9 | 4 | $\frac{5}{8}$ |
| $1\frac{1}{2}$ | 156 | 114.3 | 4 | $\frac{3}{4}$ |
| 2 | 165 | 127.0 | 8 | $\frac{5}{8}$ |
| $2\frac{1}{2}$ | 190 | 149.2 | 8 | $\frac{3}{4}$ |
| 3 | 210 | 168.3 | 8 | $\frac{3}{4}$ |
| 4 | 254 | 200.0 | 8 | $\frac{3}{4}$ |
| 6 | 318 | 269.9 | 12 | $\frac{3}{4}$ |
| 8 | 381 | 330.2 | 12 | $\frac{7}{8}$ |
| 10 | 444 | 387.4 | 16 | 1 |
| 12 | 521 | 450.8 | 16 | $1\frac{1}{8}$ |
| 14 | 584 | 514.4 | 20 | $1\frac{1}{8}$ |
| 16 | 648 | 571.5 | 20 | $1\frac{1}{4}$ |
| 18 | 711 | 628.6 | 24 | $1\frac{1}{4}$ |
| 20 | 775 | 685.8 | 24 | $1\frac{1}{4}$ |
| 24 | 914 | 812.8 | 24 | $1\frac{1}{2}$ |

Metric pipe flanges to BS 4504

Nominal pressure – 2.5 bar

Thickness of flange depends on type and material

| <i>Nominal pipe size</i> | <i>Outside diameter of pipe mm</i> | <i>Diameter of flange mm</i> | <i>Diameter of bolt circle mm</i> | <i>No. of bolts</i> | <i>Size of bolts</i> |
|--------------------------|------------------------------------|------------------------------|-----------------------------------|---------------------|----------------------|
| 10 | 17.2 | 75 | 50 | 4 | M10 |
| 15 | 21.3 | 80 | 55 | 4 | M10 |
| 20 | 26.9 | 90 | 65 | 4 | M10 |
| 25 | 33.7 | 100 | 75 | 4 | M10 |
| 32 | 42.4 | 120 | 90 | 4 | M12 |
| 40 | 48.3 | 130 | 100 | 4 | M12 |
| 50 | 60.3 | 140 | 110 | 4 | M12 |
| 65 | 76.1 | 160 | 130 | 4 | M12 |
| 80 | 88.9 | 190 | 150 | 4 | M16 |
| 100 | 114.3 | 210 | 170 | 4 | M16 |
| 125 | 139.7 | 240 | 200 | 8 | M16 |
| 150 | 168.3 | 265 | 225 | 8 | M16 |
| 200 | 219.1 | 320 | 280 | 8 | M16 |
| 250 | 273 | 375 | 335 | 12 | M16 |
| 300 | 323.9 | 440 | 395 | 12 | M20 |
| 350 | 355.6 | 490 | 445 | 12 | M20 |
| 400 | 406.4 | 540 | 495 | 16 | M20 |
| 500 | 508 | 645 | 600 | 20 | M20 |
| 600 | 609.6 | 755 | 705 | 20 | M24 |

Nominal pressure – 6 bar

Dimensions as for 2.5 bar for sizes up to 600 NB

Metric pipe flanges to BS 4504

Nominal pressure - 10 bar

Thickness of flange depends on type and material

| <i>Nominal pipe size</i> | <i>Outside diameter of pipe mm</i> | <i>Diameter of flange mm</i> | <i>Diameter of bolt circle mm</i> | <i>No. of bolts</i> | <i>Size of bolts</i> |
|------------------------------|--|--------------------------------------|---|-------------------------|--------------------------|
| 10 | 17.2 | 90 | 60 | 4 | M12 |
| 15 | 21.3 | 95 | 65 | 4 | M12 |
| 20 | 26.9 | 105 | 75 | 4 | M12 |
| 25 | 33.7 | 115 | 85 | 4 | M12 |
| 32 | 42.4 | 140 | 100 | 4 | M16 |
| 40 | 48.3 | 150 | 110 | 4 | M16 |
| 50 | 60.3 | 165 | 125 | 4 | M16 |
| 65 | 76.1 | 185 | 145 | 4 | M16 |
| 80 | 88.9 | 200 | 160 | 8 | M16 |
| 100 | 114.3 | 220 | 180 | 8 | M16 |
| 125 | 139.7 | 250 | 210 | 8 | M16 |
| 150 | 168.3 | 285 | 240 | 8 | M20 |
| 200 | 219.1 | 340 | 295 | 8 | M20 |
| 250 | 273 | 395 | 350 | 12 | M20 |
| 300 | 323.9 | 445 | 400 | 12 | M20 |
| 350 | 355.6 | 505 | 460 | 16 | M20 |
| 400 | 406.4 | 565 | 515 | 16 | M24 |
| 500 | 508 | 670 | 620 | 20 | M24 |
| 600 | 609.6 | 780 | 725 | 20 | M27 |

Metric pipe flanges to BS 4504

Nominal pressure - 16 bar

Thickness of flange depends on type and material

| <i>Nominal pipe size</i> | <i>Outside diameter of pipe mm</i> | <i>Diameter of flange mm</i> | <i>Diameter of bolt circle mm</i> | <i>No. of bolts</i> | <i>Size of bolts</i> |
|--------------------------|------------------------------------|------------------------------|-----------------------------------|---------------------|----------------------|
| 10 | 17.2 | 90 | 60 | 4 | M12 |
| 15 | 21.3 | 95 | 65 | 4 | M12 |
| 20 | 26.9 | 105 | 75 | 4 | M12 |
| 25 | 33.7 | 115 | 85 | 4 | M12 |
| 32 | 42.4 | 140 | 100 | 4 | M16 |
| 40 | 48.3 | 150 | 110 | 4 | M16 |
| 50 | 60.3 | 165 | 125 | 4 | M16 |
| 65 | 76.1 | 185 | 145 | 4 | M16 |
| 80 | 88.9 | 200 | 160 | 8 | M16 |
| 100 | 114.3 | 220 | 180 | 8 | M16 |
| 125 | 139.7 | 250 | 210 | 8 | M16 |
| 150 | 168.3 | 285 | 240 | 8 | M20 |
| 200 | 219.1 | 340 | 295 | 12 | M20 |
| 250 | 273 | 405 | 355 | 12 | M24 |
| 300 | 323.9 | 460 | 410 | 12 | M24 |
| 350 | 355.6 | 520 | 470 | 16 | M24 |
| 400 | 406.4 | 580 | 525 | 16 | M27 |
| 500 | 508 | 715 | 650 | 20 | M30 |
| 600 | 609.6 | 840 | 770 | 20 | M33 |

Metric pipe flanges to BS 4504

Nominal pressure - 25 bar

Thickness of flange depends on type and material

| <i>Nominal pipe size</i> | <i>Outside diameter of pipe mm</i> | <i>Diameter of flange mm</i> | <i>Diameter of bolt circle mm</i> | <i>No. of bolts</i> | <i>Size of bolts</i> |
|--------------------------|------------------------------------|------------------------------|-----------------------------------|---------------------|----------------------|
| 10 | 17.2 | 90 | 60 | 4 | M12 |
| 15 | 21.3 | 95 | 65 | 4 | M12 |
| 20 | 26.9 | 105 | 75 | 4 | M12 |
| 25 | 33.7 | 115 | 85 | 4 | M12 |
| 32 | 42.4 | 140 | 100 | 4 | M16 |
| 40 | 48.3 | 150 | 110 | 4 | M16 |
| 50 | 60.3 | 165 | 125 | 4 | M16 |
| 65 | 76.1 | 185 | 145 | 8 | M16 |
| 80 | 88.9 | 200 | 160 | 8 | M16 |
| 100 | 114.3 | 235 | 190 | 8 | M20 |
| 125 | 139.7 | 270 | 220 | 8 | M24 |
| 150 | 168.3 | 300 | 250 | 8 | M24 |
| 200 | 219.1 | 360 | 310 | 12 | M24 |
| 250 | 273 | 425 | 370 | 12 | M27 |
| 300 | 323.9 | 485 | 430 | 16 | M27 |
| 350 | 355.6 | 555 | 490 | 16 | M30 |
| 400 | 406.4 | 620 | 550 | 16 | M33 |
| 500 | 508 | 730 | 660 | 20 | M33 |

Dimensions of tubes

General dimensions of steel tubes to BS 1387: 1985

(Subject to standard tolerances and usual working allowances)

| Nominal bore | | Outside diameter | | Thickness | | | Mass of black tube | | | | | |
|----------------|-----------|------------------|----------------|-----------|-----------|-----------|--------------------|-------------|-------------|-------------|-------------|-------------|
| | | Light | Heavy & Medium | Light | Medium | Heavy | Light | | Medium | | Heavy | |
| | | | | | | | Plain | Screwed | Plain | Screwed | Plain | Screwed |
| <i>in</i> | <i>mm</i> | <i>mm</i> | <i>mm</i> | <i>mm</i> | <i>mm</i> | <i>mm</i> | <i>kg/m</i> | <i>kg/m</i> | <i>kg/m</i> | <i>kg/m</i> | <i>kg/m</i> | <i>kg/m</i> |
| $\frac{1}{4}$ | 8 | 13.6 | 13.9 | 1.8 | 2.3 | 2.9 | 0.515 | 0.519 | 0.641 | 0.645 | 0.765 | 0.769 |
| $\frac{3}{8}$ | 10 | 17.1 | 17.4 | 1.8 | 2.3 | 2.9 | 0.670 | 0.676 | 0.839 | 0.845 | 1.02 | 1.03 |
| $\frac{1}{2}$ | 15 | 21.4 | 21.7 | 2.0 | 2.6 | 3.2 | 0.947 | 0.956 | 1.21 | 1.22 | 1.44 | 1.45 |
| $\frac{3}{4}$ | 20 | 26.9 | 27.2 | 2.3 | 2.6 | 3.2 | 1.38 | 1.39 | 1.56 | 1.57 | 1.87 | 1.88 |
| 1 | 25 | 33.8 | 34.2 | 2.6 | 3.2 | 4.0 | 1.98 | 2.00 | 2.41 | 2.43 | 2.94 | 2.96 |
| $1\frac{1}{4}$ | 32 | 42.5 | 42.9 | 2.6 | 3.2 | 4.0 | 2.54 | 2.57 | 3.10 | 3.13 | 3.80 | 3.83 |
| $1\frac{1}{2}$ | 40 | 48.4 | 48.8 | 2.9 | 3.2 | 4.0 | 3.23 | 3.27 | 3.57 | 3.61 | 4.38 | 4.42 |
| 2 | 50 | 60.2 | 60.8 | 2.9 | 3.6 | 4.5 | 4.08 | 4.15 | 5.03 | 5.10 | 6.19 | 6.26 |
| $2\frac{1}{2}$ | 65 | 76.0 | 76.6 | 3.2 | 3.6 | 4.5 | 5.71 | 5.83 | 6.43 | 6.55 | 7.93 | 8.05 |
| 3 | 80 | 88.7 | 89.5 | 3.2 | 4.0 | 5.0 | 6.72 | 6.89 | 8.37 | 8.54 | 10.3 | 10.5 |
| 4 | 100 | 113.9 | 114.9 | 3.6 | 4.5 | 5.4 | 9.75 | 10.0 | 12.2 | 12.5 | 14.5 | 14.8 |
| 5 | 125 | — | 140.6 | — | 5.0 | 5.4 | — | — | 16.6 | 17.1 | 17.9 | 18.4 |
| 6 | 150 | — | 166.1 | — | 5.0 | 5.4 | — | — | 19.7 | 20.3 | 21.3 | 21.9 |

Suggested maximum working pressures

The pressures given below can be taken as conservative estimates for tubes screwed taper with sockets tapped parallel under normal (non-shock) conditions

| | <i>Grade</i> | <i>Nom. bore</i> | $\frac{1}{8}$ to 1 in | $1\frac{1}{4}$ & $1\frac{1}{2}$ in | 2 & $2\frac{1}{2}$ in | 3 in | 4 in | 5 in | 6 in |
|---------------------|---------------|--------------------------|-----------------------|------------------------------------|-------------------------|------|------|------|------|
| <i>Water</i> | <i>light</i> | <i>lb/in²</i> | 150 | 125 | 100 | 100 | 80 | — | — |
| | | <i>kN/m²</i> | 1000 | 850 | 700 | 700 | 550 | — | — |
| | <i>medium</i> | <i>lb/in²</i> | 300 | 250 | 200 | 200 | 150 | 150 | 125 |
| | | <i>kN/m²</i> | 2000 | 1750 | 1400 | 1400 | 1000 | 1000 | 850 |
| | <i>heavy</i> | <i>lb/in²</i> | 350 | 300 | 250 | 250 | 200 | 200 | 150 |
| | | <i>kN/m²</i> | 2400 | 2000 | 1750 | 1750 | 1400 | 1400 | 1000 |
| <i>Steam or air</i> | <i>medium</i> | <i>lb/in²</i> | 150 | 125 | 100 | 100 | 80 | 80 | 60 |
| | | <i>kN/m²</i> | 1000 | 850 | 700 | 700 | 550 | 550 | 400 |
| | <i>heavy</i> | <i>lb/in²</i> | 175 | 150 | 125 | 125 | 100 | 100 | 80 |
| | | <i>kN/m²</i> | 1200 | 1000 | 850 | 850 | 700 | 700 | 550 |


The following allowed for plain end tubes end-to-end welded for steam or compressed air.

| | | | | | | | | |
|---------------|--------------------------|------|------|------|------|------|------|------|
| <i>medium</i> | <i>lb/in²</i> | 250 | 200 | 200 | 150 | 150 | 150 | 125 |
| | <i>kN/m²</i> | 1750 | 1400 | 1400 | 1000 | 1000 | 1000 | 850 |
| <i>heavy</i> | <i>lb/in²</i> | 300 | 300 | 300 | 200 | 200 | 200 | 75 |
| | <i>kN/m²</i> | 2000 | 2000 | 2000 | 1400 | 1400 | 1400 | 1200 |


Copper tube to BS 2871: 1972

| Nominal bore mm | Outside diameter mm | Table X Half hard light gauge tube | | Table Y Half hard and annealed tube | | Table Z Hard drawn thin wall tube | |
|-----------------------|---------------------------|---------------------------------------|---|--|---|--------------------------------------|---|
| | | Thickness mm | Maximum working pressure N/mm ² | Thickness mm | Maximum working pressure N/mm ² | Thickness mm | Maximum working pressure N/mm ² |
| 6 | 6 | 0.6 | 13.3 | 0.8 | 14.4 | 0.5 | 11.3 |
| 8 | 8 | 0.6 | 9.7 | 0.8 | 10.5 | 0.5 | 9.8 |
| 10 | 10 | 0.6 | 7.7 | 0.8 | 8.2 | 0.5 | 7.8 |
| 12 | 12 | 0.6 | 6.3 | 0.8 | 6.7 | 0.5 | 6.4 |
| 15 | 15 | 0.7 | 5.8 | 1.0 | 6.7 | 0.5 | 5.0 |
| 18 | 18 | 0.8 | 5.6 | 1.0 | 5.5 | 0.6 | 5.0 |
| 22 | 22 | 0.9 | 5.1 | 1.2 | 5.7 | 0.6 | 4.1 |
| 28 | 28 | 0.9 | 4.0 | 1.2 | 4.2 | 0.6 | 3.2 |
| 35 | 35 | 1.2 | 4.2 | 1.5 | 4.1 | 0.7 | 3.0 |
| 42 | 42 | 1.2 | 3.5 | 1.5 | 3.4 | 0.8 | 2.8 |
| 54 | 54 | 1.2 | 2.7 | 2.0 | 3.6 | 0.9 | 2.5 |
| 67 | 67 | 1.2 | 2.0 | 2.0 | 2.8 | 1.0 | 2.0 |
| 76.1 | 76.2 | 1.5 | 2.4 | 2.0 | 2.5 | 1.2 | 1.9 |
| 108 | 108.1 | 1.5 | 1.7 | 2.5 | 2.2 | 1.2 | 1.7 |
| 133 | 133.4 | 1.5 | 1.4 | — | — | 1.5 | 1.6 |
| 159 | 159.4 | 2.0 | 1.5 | — | — | 1.5 | 1.5 |



Malleable iron pipe fittings




EQUAL BEND




EQUAL ELBOW

DEPTH OF THREAD ENGAGEMENT
COMMON TO ALL FITTINGS


EQUAL TEE




HEXAGON NIPPLE




SOCKET



EQUAL PITCHER TEE



UNION



CLIP

Dimensions of malleable iron pipe fittings

Dimensions in mm

| Nominal bore | | 15 | 20 | 25 | 32 | 40 | 50 | 65 | 80 | 100 |
|----------------------------|--------------|----|----|----|----|----|-----|-----|-----|-----|
| Depth of thread engagement | A | 13 | 14 | 16 | 19 | 19 | 24 | 25 | 29 | 35 |
| Bend | B | 45 | 50 | 63 | 76 | 85 | 102 | 114 | 127 | 165 |
| Elbow | C | 28 | 33 | 38 | 45 | 50 | 58 | 69 | 78 | 96 |
| Equal Tee | C | 28 | 33 | 38 | 45 | 50 | 58 | 69 | 78 | 96 |
| Hexagon nipple | length | D | 44 | 49 | 56 | 64 | 71 | 80 | 89 | 102 |
| | across flats | E | 23 | 28 | 35 | 44 | 50 | 61 | 77 | 115 |
| Socket | length | F | 34 | 39 | 42 | 49 | 54 | 64 | 73 | 94 |
| Equal pitcher Tee | B | 45 | 50 | 63 | 76 | 85 | 102 | 114 | 127 | 165 |
| | G | 24 | 28 | 33 | 40 | 43 | 53 | 61 | 70 | 87 |
| Union | length | H | 46 | 52 | 57 | 64 | 68 | 75 | 84 | 106 |
| | across flats | J | 42 | 48 | 57 | 68 | 76 | 92 | 109 | 155 |
| Pipe clip | K | 43 | 43 | 51 | 56 | 70 | 76 | 89 | 97 | 118 |
| | L | 40 | 48 | 54 | 60 | 73 | 86 | 95 | 108 | 143 |

3 Combustion

Atomic weights of elements occurring in combustion calculations

| <i>Element</i> | <i>Symbol</i> | <i>Atomic No.</i> | <i>Atomic weight</i> |
|----------------|---------------|-------------------|----------------------|
| Carbon | C | 6 | 12.011 |
| Hydrogen | H | 1 | 1.008 |
| Nitrogen | N | 7 | 14.007 |
| Oxygen | O | 8 | 15.9994 |
| Phosphorus | P | 15 | 30.9738 |
| Sulphur | S | 16 | 32.06 |

Heat of combustion of important chemicals

| <i>Substance</i> | <i>Products of combustion</i> | <i>Chemical equation</i> | <i>Heat of combustion</i> | |
|------------------|-------------------------------|------------------------------|---------------------------|---------------|
| | | | <i>kJ/kg</i> | <i>Btu/lb</i> |
| Carbon | Carbon dioxide | $C + O_2 = CO_2$ | 33,950 | 14,590 |
| Carbon | Carbon monoxide | $2C + O_2 = 2CO$ | 9,210 | 3,960 |
| Carbon monoxide | Carbon dioxide | $2CO + O_2 = 2CO_2$ | 10,150 | 4,367 |
| Hydrogen | Water | $2H_2 + O_2 = 2H_2O$ | 144,200 | 62,000 |
| Sulphur | Sulphur dioxide | $S + O_2 = SO_2$ | 9,080 | 3,900 |
| Methane | Carbon dioxide and water | $CH_4 + 2O_2 = CO_2 + 2H_2O$ | 55,860 | 24,017 |







Ignition temperatures

| | | | | | |
|----------------------|-------|--------|--------------------|-------|--------|
| Wood | 300°C | 570°F | Petroleum | 400°C | 750°F |
| Peat | 227°C | 440°F | Benzene | 415°C | 780°F |
| Bituminous coal | 300°C | 570°F | Coal-tar oil | 580°C | 1080°F |
| Semi anthracite coal | 400°C | 750°F | Producer gas | 750°C | 1380°F |
| Coke | 700°C | 1290°F | Light hydrocarbons | 650°C | 1200°F |
| Hydrogen | 500°C | 930°F | Heavy hydrocarbons | 750°C | 1380°F |
| Carbon monoxide | 300°C | 570°F | Light gas | 600°C | 1110°F |
| Carbon | 700°C | 1290°F | Naphtha | 550°C | 1020°F |

Composition and calorific value of fuels

| <i>Fuel</i> | <i>Composition by weight</i> | | | | | | <i>Higher calorific value</i> | |
|---------------------------------------|------------------------------|----------|------------|----------|-----------------------|------------|-------------------------------|---------------------------|
| | <i>C</i> | <i>H</i> | <i>O+N</i> | <i>S</i> | <i>H₂O</i> | <i>Ash</i> | <i>kJ/kg</i> | <i>Btu/lb</i> |
| Anthracite | 83-87 | 3.5-4.0 | 3.0-4.7 | 0.9 | 1-3 | 4-6 | 32 500-34 000 | 14 000-14 500 |
| Semi-anthracite | 63-76 | 3.5-4.8 | 8-10 | 0.5-1.8 | 5-15 | 4-14 | 26 700-32 500 | 11 500-14 000 |
| Bituminous coal | 46-56 | 3.5-5.0 | 9-16 | 0.2-3.0 | 18-32 | 2-10 | 17 000-23 250 | 73 00-10 000 |
| Lignite | 37 | 7 | 13.5 | 0.5 | 37 | 5 | 16 300 | 7000 |
| Peat | 38-49 | 3.0-4.5 | 19-28 | 0.2-1.0 | 16-29 | 1-9 | 13 800-20 500 | 5500-8800 |
| Coke | 80-90 | 0.5-1.5 | 1.5-5.0 | 0.5-1.5 | 1-5 | 5-12 | 28 000-31 000 | 12 000-13 500 |
| Charcoal | 84 | 1 | — | — | 12 | 3 | 29 600 | 12 800 |
| Wood (dry) | 35-45 | 3.0-5.0 | 34-42 | — | 7-22 | 0.3-3.0 | 14 400-17 400 | 6200-7500 |
| | | | | | | | <i>kJ/m³</i> | <i>Btu/ft³</i> |
| Town gas | 26 | 56 | 18 | — | — | — | 18 600 | 500 |
| Natural gas | 75 | 25 | — | — | — | — | 37 200 | 1000 |
| Propane C ₃ H ₈ | 82 | 18 | — | — | — | — | 93 900 | 2520 |
| Butane C ₄ H ₁₀ | 83 | 17 | — | — | — | — | 130 000 | 3490 |
| | | | | | | | <i>kJ/l</i> | <i>Btu/gal</i> |
| Kerosine | | | | | | | 35 000 | 154 000 |
| Gas oil | 86.2 | 13.0 | — | 0.8 | — | — | 38 000 | 164 000 |
| Heavy fuel oil | 85.0 | 10.8 | — | 3.8 | — | — | 41 200 | 177 000 |

THE RINGELMANN SCALE FOR GRADING DENSITY OF SMOKE

| SMOKE NUMBER | 0 | 1 | 2 | 3 | 4 | 5 |
|--|---|---|---|---|---|---|
| $\frac{\text{LINES mm}}{\text{SPACES mm}}$ | — ALL WHITE | 1 9 | 2.3 7.7 | 3.7 6.3 | 5.5 4.5 | ALL BLACK — |
| |  |  |  |  |  |  |

Observer should stand 30–300 m from stack and hold scale at arm's length. He should then determine the shade in the chart most nearly corresponding to the shade of the smoke. Care should be taken to avoid either bright sunlight or dark buildings in the background.

Excess of air for good conditions

| | |
|--|---------|
| For anthracite and coke | 40% |
| For semi-anthracite, hand firing | 70–100% |
| For semi-anthracite, with stoker | 40–70% |
| For semi-anthracite, with travelling grate | 30–60% |
| For oil | 10–20% |
| For gas | 10% |

Theoretical values of combustion air and flue gases

| Fuel | Theoretical air for combustion Volume at S.T.P. | | Theoretical flue gas produced Volume at S.T.P. | |
|--------------------|--|--------------------------------------|---|--------------------------------------|
| | m^3/kg | ft^3/lb | m^3/kg | ft^3/lb |
| Anthracite | 9.4 | 150 | 9.5 | 152 |
| Semi-anthracite | 8.4 | 135 | 8.6 | 137 |
| Bituminous coal | 6.9 | 110 | 7.0 | 112 |
| Lignite | 5.7 | 92 | 5.8 | 93 |
| Peat | 5.7 | 92 | 5.9 | 94 |
| Coke | 8.4 | 134 | 8.4 | 135 |
| Charcoal | 8.4 | 134 | 8.4 | 135 |
| Wood (dry) | 4.4 | 70 | 5.0 | 80 |
| | $m^3 \text{ air}/m^3 \text{ fuel}$ | $ft^3 \text{ air}/ft^3 \text{ fuel}$ | $m^3 \text{ gas}/m^3 \text{ fuel}$ | $ft^3 \text{ gas}/ft^3 \text{ fuel}$ |
| Town gas | 4 | 4 | 3.8 | 3.8 |
| Natural gas | 9.5 | 9.5 | 8.5 | 8.5 |
| Propane C_3H_8 | 24.0 | 24.0 | 22 | 22 |
| Butane C_4H_{10} | 31 | 31 | 27 | 27 |
| | $m^3 \text{ air}/\text{litre fuel}$ | $ft^3 \text{ air}/\text{gal fuel}$ | $m^3 \text{ gas}/\text{litre fuel}$ | $ft^3 \text{ gas}/\text{gal fuel}$ |
| Gas oil | 9.8 | 1570 | 10.4 | 1670 |
| Heavy fuel oil | 10.8 | 1730 | 11.6 | 1860 |

Heat losses in a boiler

- 1 Sensible heat carried away by dry flue gases

$$L_1 = WC_p(t_1 - t_A) \text{ kJ per kg of fuel}$$

$$= WC_p(t_1 - t_A) \frac{100}{S} \text{ per cent}$$

- 2 Heat lost by free moisture in fuel

$$L_2 = w(H - h) \text{ kJ per kg of fuel}$$

$$= w(H - h) \frac{100}{S} \text{ per cent}$$

- 3 Heat lost by incomplete combustion

$$L_3 = 24\,000 \frac{\text{CO}}{\text{CO}_2 + \text{CO}} \text{C kJ per kg of fuel}$$

$$= 24\,000 \frac{\text{CO}}{\text{CO}_2 + \text{CO}} \text{C} \times \frac{100}{S} \text{ per cent}$$

- 4 Heat lost due to Carbon in Ash

$$L_4 = W_c \times 33\,950 \text{ kJ per kg of fuel}$$

$$= W_c \times 33\,950 \times \frac{100}{S} \text{ per cent}$$

- 5 Heat lost by Radiation and Unaccounted Losses obtained by difference

$$L_s = S - (M + L_1 + L_2 + L_3 + L_4)$$

where

W = weight of combustion products, kg per kg fuel

W_c = weight of carbon in ash, kg per kg fuel

w = weight of water in fuel, kg per kg fuel

C_p = specific heat capacity of flue gas, kJ per kg per deg C
= 1.0

t_1 = temperature of flue gas °C

t_A = ambient temperature in boiler room, °C

S = higher calorific value of fuel, kJ per kg

H = total heat of superheated steam at temperature t_1 and atmospheric pressure, kJ per kg

h = sensible heat of water at temperature t_A , kJ per kg

C = weight of carbon in fuel, kg per kg



CO = percentage by volume of carbon monoxide in flue gas

CO₂ = percentage by volume of carbon dioxide in flue gas



M = utilised heat in boiler output.

The largest loss is normally the sensible heat in the flue gases. In good practice it is about 20%.

Sensible heat carried away by flue gases



Sensible heat carried away by flue gases



Chimney sizes

Theoretical chimney draught

$$h = 354 H \left(\frac{1}{T_1} - \frac{1}{T_2} \right)$$

where

h = draught in mm water

H = chimney height in m

T_1 = absolute temperature outside chimney K

T_2 = absolute temperature inside chimney K

$$h = 7.64 H \left(\frac{1}{T_1} - \frac{1}{T_2} \right)$$

where

h = draught in inches of water

H = chimney height in ft

T_1 = absolute temperature outside chimney °R

T_2 = absolute temperature inside chimney °R.

Chimney area

The chimney should be designed to give a maximum velocity of 2 m/s (7 ft/s) for small furnaces, and 10–15 m/s for large furnaces.

$$A = \frac{Q}{V}$$

where

A = cross-sectional area of chimney, m²

Q = volume of flue gases at chimney temperature, m³/s

V = velocity, m/s

An empirical rule is to provide 400 mm² chimney area per 1 kW boiler rating (0.2 in² per 1000 Btu/hour boiler rating).

Recommended sizes of explosion doors or draught stabilisers for oil firing installations

| <i>Cross-sectional area of chimney in²</i> | <i>Release opening of stabiliser, approx., in</i> | <i>Cross-sectional area of chimney m²</i> | <i>Release opening of stabiliser, approx., mm</i> |
|---|---|--|---|
| 40–80 | 6×9 | 0.025–0.050 | 150×230 |
| 80–200 | 8×13 | 0.050–0.125 | 200×330 |
| 200–300 | 13×18 | 0.125–0.200 | 330×450 |
| 300–600 | 16×24 | 0.200–0.400 | 400×600 |
| 600–1500 | 24×32 | 0.400–1.000 | 600×800 |


Combustion air

A boiler house must have openings to fresh air to allow combustion air to enter. An empirical rule is to allow 1600 mm² free area per 1 kW boiler rating (1.5 in² per 2000 Btu/hour boiler rating).

Flue dilution

Flue gases from gas burning appliances can be diluted with fresh air to enable the products of combustion to be discharged at low level or near windows.

Typical arrangements



To reduce CO₂ concentration to 1%, fan must handle 100 m³ mixed volume per 1 m³ natural gas fuel burnt.

In determining fan pressure allowance must be made for pressure due to local wind conditions.

Discharge grille must have free area not less than that of flue.

Fresh air intake must have free area not less than that of flue.

Fresh air intake should be on same face of building as discharge grille in order to balance out wind effect.

Density and specific volume of stored fuels

| <i>Fuel</i> | <i>Density</i> | | <i>Specific volume</i> | |
|---------------------|-------------------------|--------------------------|--------------------------------------|-----------------------------------|
| | <i>kg/m³</i> | <i>lb/ft³</i> | <i>m³ per 1000 kg</i> | <i>ft³ per ton</i> |
| Wood | 360-385 | 22.5-2.4 | 2.5-2.8 | 90-100 |
| Charcoal, hard wood | 149 | 9.3 | 6.7 | 240 |
| Charcoal, soft wood | 216 | 13.5 | 4.6 | 165 |
| Anthracite | 720-850 | 45-53 | 1.2-1.4 | 42-50 |
| Bituminous coal | 690-800 | 43-50 | 1.2-1.5 | 45-52 |
| Peat | 310-400 | 19.5-25 | 2.5-3.2 | 90-115 |
| Coke | 375-500 | 23.5-31 | 2.0-2.7 | 72-95 |
| Kerosine | 790 | 49 | 1.3 | 47 |
| Gas oil | 835 | 52 | 1.2 | 43 |
| Fuel oil | 930 | 58 | 1.1 | 39 |

Classification of Oil Fuels

Based on BS 2869

| <i>Common Name</i> | <i>Kerosine</i> | <i>Gas oil</i> | <i>Fuel oil or heavy fuel oil</i> | | | |
|---|--|--|--|---|---------|---------|
| Class to BS 2869 | C1 | C2 | D | E | F | G |
| Kinematic viscosity cSt at 40°C | — | 1.0–2.0 | 1.5–5.5 | | | |
| cSt at 100°C | — | | | 8.2 max. | 20 max. | 40 max. |
| Flash point, closed Abel, min. °C | 43 | 38 | 56 | | | |
| Pensky-Martin, min. °C | — | | | 66 | 66 | 66 |
| Sulphur content per cent by mass | 0.04 | 0.2 | 0.5 | 3.5 | 3.5 | 3.5 |
| Minimum temperature for storage °C | ambient | ambient | ambient | 10 | 25 | 40 |
| for outflow from storage and handling °C | ambient | ambient | ambient | 10 | 30 | 50 |
| Application | Distillate fuel for free standing flue less domestic appliances | Similar for vapourising and atomising burners on domestic appliances with flues | Distillate fuel for atomising burners for domestic and industrial use | Residual or blended fuels for atomising burners normally requiring preheating before combustion in burner | | |

Classification of Coal

Based on volatile matter and coking power of clean material

| <i>Class</i> | <i>Volatile matter percent (dry mineral matter free basis)</i> | <i>General description</i> | | |
|--------------|--|----------------------------|-----------------------|---------------------------------------|
| 101 | < 6.1 | Anthracites | | |
| 102 | 6.1-9.0 | | | |
| 201 | 9.1-13.5 | Dry steam coals | | |
| 202 | 13.6-15.0 | Coking steam coals | | |
| 203 | 15.1-17.0 | | | |
| 204 | 17.1-19.5 | | | |
| 206 | 9.1-19.5 | | | Heat altered low volatile steam coals |
| 301 | 19.6-32.0 | Prime coking coals | Medium volatile coals | |
| 305 | 19.6-32.0 | Mainly heat altered | | |
| 306 | 19.6-32.0 | coals | | |
| 401 | 32.1-36.0 | Very strongly coking coals | | |
| 402 | > 36.0 | | | |
| 501 | 32.1-36.0 | Strongly coking coals | | |
| 502 | > 36.0 | | | |
| 601 | 32.1-36.0 | Medium coking | High volatile coals | |
| 602 | > 36.0 | coals | | |
| 701 | 32.1-36.0 | Weakly coking coals | | |
| 702 | > 36.0 | | | |
| 801 | 32.1-36.0 | Very weakly coking coals | | |
| 802 | > 36.0 | | | |
| 901 | 32.1-36.0 | Non-coking coals | | |
| 902 | > 36.0 | | | |

Flow of oil in pipes

Head loss of various viscosities for laminar flow

| <i>Viscosity at temp. in pipe</i> | | | | | |
|-----------------------------------|---|--|--|---------------------------------------|---------------------------------------|
| <i>cS</i> | 4.0 | 25 | 45 | 250 | 500 |
| i_1 | $0.54 \times 10^{-4} \frac{f_1}{d_1^4}$ | $3.4 \times 10^{-4} \frac{f_1}{d_1^4}$ | $6.1 \times 10^{-4} \frac{f_1}{d_1^4}$ | $34 \times 10^{-4} \frac{f_1}{d_1^4}$ | $67 \times 10^{-4} \frac{f_1}{d_1^4}$ |
| i_2 | $1.7 \times 10^4 \frac{f_2}{d_2^4}$ | $11 \times 10^4 \frac{f_2}{d_2^4}$ | $20 \times 10^4 \frac{f_2}{d_2^4}$ | $110 \times 10^4 \frac{f_2}{d_2^4}$ | $220 \times 10^4 \frac{f_2}{d_2^4}$ |

$i_1 = i_2$ = head loss in feet of oil per foot of pipe or metres of oil per metre of pipe. (Length of pipe to include allowances for bends, valves and fittings)

f_1 = flow of oil in gal/hr

f_2 = flow of oil in litre/s

d_1 = internal diameter of pipe in inches

d_2 = internal diameter of pipe in mm.

The above formulae are for laminar flow. Flow is laminar if Reynolds Number (Re) is less than 1500. Reynolds number can be checked from the following formulae. As Re is a dimensionless ratio it is the same in all consistent systems of units. The coefficients in the following formulae take into account the dimensions of f_1 , d_1 , f_2 , d_2 respectively.

The viscosity to be taken is that at the temperature of the oil in the pipe.

| <i>Viscosity at temp. in pipe</i> | | | | | |
|-----------------------------------|----------------------------------|-----------------------------------|-----------------------------------|------------------------------------|------------------------------------|
| <i>cS</i> | 4.0 | 25 | 45 | 250 | 500 |
| | $16 \frac{f_1}{d_1}$ | $2.5 \frac{f_1}{d_1}$ | $1.0 \frac{f_1}{d_1}$ | $0.25 \frac{f_1}{d_1}$ | $0.12 \frac{f_1}{d_1}$ |
| Re | $32 \times 10^4 \frac{f_2}{d_2}$ | $4.5 \times 10^4 \frac{f_2}{d_2}$ | $2.8 \times 10^4 \frac{f_2}{d_2}$ | $0.45 \times 10^4 \frac{f_2}{d_2}$ | $0.25 \times 10^4 \frac{f_2}{d_2}$ |

Heat loss from oil tanks


| <i>Position</i> | <i>Oil temperature</i> | | <i>Heat loss</i> | | | |
|-----------------|------------------------|-------------|---------------------------------|-------------------|---------------------------------|-------------------|
| | | | <i>Unlagged</i> | | <i>Lagged</i> | |
| | $^{\circ}F$ | $^{\circ}C$ | $\frac{Btu}{ft^2 hr ^{\circ}F}$ | $\frac{W}{m^2 K}$ | $\frac{Btu}{ft^2 hr ^{\circ}F}$ | $\frac{W}{m^2 K}$ |
| Sheltered | up to 50 | up to 10 | 1.2 | 6.8 | 0.3 | 1.7 |
| | 50-80 | 10-27 | 1.3 | 7.4 | 0.325 | 1.8 |
| | 80-100 | 27-38 | 1.4 | 8.0 | 0.35 | 2.0 |
| Exposed | up to 50 | up to 10 | 1.4 | 8.0 | 0.35 | 2.0 |
| | 50-80 | 10-27 | 1.5 | 8.5 | 0.375 | 2.1 |
| | 80-100 | 27-38 | 1.6 | 9.0 | 0.4 | 2.25 |
| In pit | | | Nil | | Nil | |

Heat transfer coefficients for coils are:

Steam to oil: $11.3 \text{ W/m}^2 \text{ }^{\circ}C$ $20 \text{ Btu/ft}^2 \text{ hr } ^{\circ}F$
 Hot water to oil: $5.7 \text{ W/m}^2 \text{ }^{\circ}C$ $10 \text{ Btu/ft}^2 \text{ hr } ^{\circ}F$


Heat loss from oil pipes

| <i>Nominal bore</i> | <i>Oil temperature</i> | | <i>Heat loss</i> | |
|---------------------|------------------------|-------------|-------------------------------|----------------|
| | | | $\frac{Btu}{hr ft ^{\circ}F}$ | $\frac{W}{mK}$ |
| <i>mm</i> | $^{\circ}F$ | $^{\circ}C$ | | |
| 15 | up to 50 | up to 10 | 0.4 | 0.7 |
| 20 | | | 0.4 | 0.7 |
| 25 | | | 0.8 | 1.4 |
| 40 | | | 1.2 | 2.1 |
| 50 | | | 1.6 | 2.8 |
| 15 | 50-80 | 10-27 | 0.5 | 0.9 |
| 20 | | | 0.6 | 1.1 |
| 25 | | | 0.7 | 1.2 |
| 40 | | | 1.0 | 1.7 |
| 50 | | | 1.2 | 2.1 |
| 15 | 80-100 | 27-38 | 0.5 | 0.9 |
| 20 | | | 0.6 | 1.1 |
| 25 | | | 0.8 | 1.4 |
| 40 | | | 1.1 | 1.9 |
| 50 | | | 1.3 | 2.2 |



Diagrammatic arrangement of oil storage tank

Diagrammatic arrangement of oil storage tank and day oil tank



4

Heat and thermal properties of materials

Expansion by heat

Linear expansion is the increase in length

$$L_2 = L_1(1+et)$$

Surface expansion is the increase in area

$$A_2 = A_1(1+2et)$$

Volumetric expansion is the increase in volume

$$V_2 = V_1(1+3et)$$

where

- t = temperature difference (K)
- L_1 = original length (m)
- A_1 = original area (m²)
- V_1 = original volume (m³)
- L_2 = final length (m)
- A_2 = final area (m²)
- V_2 = final volume (m³)
- e = coefficient of linear expansion (m/mK)

Sensible heat for heating or cooling

$$H = cM(t_2 - t_1)$$

where

- H = Heat (J)
- M = mass (kg)
- c = specific heat capacity (J/kg K)
- t_1 = initial temperature (°C)
- t_2 = final temperature (°C)

Expansion of gases

General gas law

$$PV = mRT$$
$$R = (C_p - C_v)$$

where

P = pressure (absolute), N/m^2 (lbf/ft^2)

V = volume, m^3 (ft^3)

m = mass, kg (lbm)

R = gas constant, J/kg K (ft lbf/lbm K)

T = absolute temperature, $^\circ\text{K}$ ($^\circ\text{R}$)

C_p = specific heat capacity at constant pressure, J/kg K ($\text{Btu/lb}^\circ\text{F}$)

C_v = specific heat capacity at constant volume, J/kg K ($\text{Btu/lb}^\circ\text{F}$)

For air

$R = 287 \text{ J/kg K}$

$= 96 \text{ ft lbf/lbm K}$

$= 53.3 \text{ ft lbf/lbm }^\circ\text{F}$

$G = MR =$ universal gas constant which is the same for all gases

where

G = universal gas constant J/kg K

M = molecular weight of gas (dimensionless)

R = gas constant for the gas J/kg K

$$G = (C_{p_m} - C_{v_m})$$

where

C_{p_m} = specific heat capacity at constant pressure in J/kg mol K

C_{v_m} = specific heat capacity at constant volume in J/kg mol K

$$PV_m = nGT$$

where

V_m = volume of n moles

n = number of moles

In various units

$G = 1.985 \text{ Btu/lb }^\circ\text{F}$

$= 1544 \text{ ft lbf/lbm }^\circ\text{F}$

$= 2780 \text{ ft lbf/lbm K}$

$= 1.985 \text{ kcal/kg K}$

$= 8.314 \text{ kJ/kg K}$

At N.T.P. 1 kg mol occupies 22.4 m^3

1 lb mol occupies 359 ft^3

At S.T.P. 1 kg mol occupies 23.7 m^3

1 lb mol occupies 379 ft^3

Methods of heating and expanding gases (not vapours)

| <i>Type of expansion</i> | <i>Remarks</i> | <i>Work done W</i> | <i>Change of internal energy E</i> | <i>Heat absorbed H</i> | <i>Final temperature</i> |
|----------------------------------|--|--|--|----------------------------------|---|
| Constant pressure | Isobar | $P(V_2 - V_1)$ | $MC_v(T_2 - T_1)$ | $MC_p(T_2 - T_1)$ | $T_1 \left(\frac{V_2}{V_1}\right)$ |
| Constant temperature | Isotherm | $P_1 V_1 \log_e \frac{V_2}{V_1}$ | 0 | $P_1 V_1 \log_e \frac{V_2}{V_1}$ | T_1 |
| Constant heat | Adiabatic $PV^\gamma = \text{const.}$ | $\frac{P_1 V_1 - P_2 V_2}{\gamma - 1}$ | $MC_v(T_2 - T_1)$ | 0 | $T_1 \left(\frac{V_1}{V_2}\right)^{\gamma-1}$ |
| Int. energy & temperature change | Polytrope $PV^n = \text{const.}$ | $\frac{P_1 V_1 - P_2 V_2}{n - 1}$ | $MC_v(T_2 - T_1)$ | $W + E$ | $T_1 \left(\frac{V_1}{V_2}\right)^{n-1}$ |

where

- | | |
|--|---|
| W = external work done by gas (kJ) | T_1, T_2 = initial, final, temperature ($^{\circ}\text{C}$) |
| E = increase of internal energy by gas (kJ) | M = mass (kg) |
| H = total heat absorbed (kJ) | $\gamma = C_p/C_v$ (dimensionless) |
| P_1, P_2 = initial, final, pressure (N/m^2) | n = index of expansion law (dimensionless) |
| V_1, V_2 = initial, final, volume (m^3) | C_v = specific heat capacity at constant volume (kJ/kg K) |
| | C_p = specific heat capacity of constant pressure (kJ/kg K) |

Mixtures of gases

$$PV = mR_m T$$

$$m = m_1 + m_2 + m_3$$

$$R_m = \frac{R_1 m_1 + R_2 m_2 + R_3 m_3}{m_1 + m_2 + m_3} = \text{gas constant of mixture}$$

The laws of perfect gases

The Critical Temperature of a substance is that temperature above which it cannot exist as a liquid.

The Critical Pressure is the pressure of a saturated vapour at its critical temperature.

Critical temperatures and pressures of various substances

| <i>Substance</i> | <i>Critical temperature</i> | | <i>Critical pressure absolute</i> | | <i>Boiling temperature at atmospheric pressure</i> | |
|---|-----------------------------|-----------|-----------------------------------|-------------|--|-----------|
| | <i>°F</i> | <i>°C</i> | <i>lb./sq. in.</i> | <i>atm.</i> | <i>°F</i> | <i>°C</i> |
| Air | -220 | -140 | 573 | 39 | - | - |
| Alcohol (C ₂ H ₆ O) | 421 | 216 | 956 | 65 | 172.4 | 78 |
| Ammonia (NH ₃) | 266 | 130 | 1691 | 115 | -27.4 | -33 |
| Benzol (C ₆ H ₆) | 554 | 292 | 735 | 50 | 176 | 80 |
| Carbon-dioxide (CO ₂) | 88.2 | 31 | 1132 | 77 | -110 | -79 |
| Carbon-monoxide (CO) | -222 | -141 | 528 | 35.9 | -310 | -190 |
| Ether (C ₄ H ₁₀ O) | 381.2 | 194 | 544 | 37 | 95 | 35 |
| Hydrogen (H) | -402 | -242 | 294 | 20 | -423 | -253 |
| Nitrogen (N) | -236 | -149 | 514 | 35 | -321 | -195 |
| Oxygen (O ₂) | -180 | -118 | 735 | 50 | -297 | -183 |
| Water (H ₂ O) | 706-716 | 375-380 | 3200 | 217.8 | 212 | 100 |

(From Mark's Mech. Eng. Hand.)

Estimations of temperatures of incandescent bodies

Colours of different temperatures

| | | |
|----------------------|--------|--------|
| Faint red | 960°F | 516°C |
| Dull red | 1290°F | 700°C |
| Brilliant red | 1470°F | 750°C |
| Cherry red | 1650°F | 900°C |
| Bright cherry red | 1830°F | 1000°C |
| Orange | 2010°F | 1100°C |
| Bright orange | 2190°F | 1200°C |
| White heat | 2370°F | 1300°C |
| Bright white heat | 2550°F | 1400°C |
| Brilliant white heat | 2750°F | 1500°C |

Heat transfer

Transfer of heat may occur by

- 1 Conduction
- 2 Convection
- 3 Radiation

1 Conduction is the transfer of heat through the molecules of a substance.

- (a) *Internal Conduction* is transmission within a body.
- (b) *External Conduction* is transmission from one body to another, when the two bodies are in contact.

Thermal Conductivity is the heat flowing through one unit of area and one unit of thickness in one unit of time per degree temperature difference.

Thermal Conductance is the heat flowing through a structural component of unit area in unit time per degree temperature difference between its faces.

$$H = \frac{AK(t_2 - t_1)}{X} = AC(t_2 - t_1)$$

$$C = \frac{K}{X}$$

where

H = heat flow, W (Btu/hr)

A = area, m² (ft²)

K = thermal conductivity, W/mK (Btu in/hr ft² °F)

C = thermal conductance, W/m² K (Btu/hr ft² °F)

X = thickness, m (in)

t_1 = temperature at cooler section, °C (°F)

t_2 = temperature at hotter section, °C (°F)

Thermal Resistance is the reciprocal of thermal conductance

$$H = \frac{A(t_2 - t_1)}{R} \quad \text{W (Btu/hr)}$$

$$R = \frac{1}{C} = \frac{X}{K} \quad \frac{m^2 K}{W} \quad \frac{\text{hr ft}^2 \text{ } ^\circ\text{F}}{\text{Btu}}$$

2 Convection is the transfer of heat by flow of currents within a fluid body. (Liquid or gas flowing over the surface of a hotter or cooler body.)

$$H = aA(t_2 - t_1) = \frac{A(t_2 - t_1)}{R_1} \text{ (Btu/hr or watts)}$$

a = Thermal conductance (Btu/hr sq ft °F or W/m² °C)

$$R_1 = \frac{1}{aX} = \text{Thermal resistance.}$$

The amount of heat transferred per unit of time is affected by the velocity of moving medium, the area and form of surface and the temperature difference.

3 Radiation is the transfer of heat from one body to another by wave motion.

Stephan-Boltzmann Formula

$$E = C \left(\frac{T}{100} \right)^4$$

E = Heat emission of a body (Btu/hr or Watts)
 T = Absolute temperature (°R or °K)
 C = Radiation constant

Quantities of heat transferred between two surfaces:

$$Q_{\text{Rad}} = CA \left[\left(\frac{T_1}{100} \right)^4 - \left(\frac{T_2}{100} \right)^4 \right]$$

A = Area

$T_1 T_2$ = Absolute temperatures of hot and cold surfaces respectively.

For the absolute black body

$$C = 5.72 \text{ Watts per sq m per (deg C)}^4$$

$$= 0.173 \text{ Btu per hr per sq ft per (deg F)}^4$$

For other materials see table below.

Radiation constant of building material (C)

| | $\frac{W}{m^2}$ ($^{\circ}C$) ⁴ | $\frac{Btu}{hr ft^2}$ ($^{\circ}F$) ⁴ | | $\frac{W}{m^2}$ ($^{\circ}C$) ⁴ | $\frac{Btu}{hr ft^2}$ ($^{\circ}F$) ⁴ |
|------------|---|---|--------------------------------|---|---|
| Black body | 5.72 | 0.173 | Wrought iron, dull oxidised | 5.16 | 0.156 |
| Cotton | 4.23 | 0.128 | Wrought iron, polished | 1.55 | 0.047 |
| Glass | 5.13 | 0.155 | Cast iron, rough oxidised | 5.09 | 0.154 |
| Wood | 4.17 | 0.126 | Copper, polished | 1.19 | 0.036 |
| Brick | 5.16 | 0.156 | Brass, dull | 0.152 | 0.0046 |
| Oil paint | 4.30 | 0.130 | Silver | 1.19 | 0.036 |
| Paper | 4.43 | 0.134 | Zinc, dull | 0.152 | 0.0046 |
| Lamp black | 5.16 | 0.156 | Tin | 0.26 | 0.0077 |
| Sand | 4.20 | 0.127 | Plaster | 5.16 | 0.156 |
| Shavings | 4.10 | 0.124 | | | |
| Silk | 4.30 | 0.130 | | | |
| Water | 3.70 | 0.112 | | | |
| Wool | 4.30 | 0.130 | | | |


Conduction of heat through pipes or partitions

Symbols

- t_m = Logarithmic mean temperature difference
 t_{a1} = Initial temperature of heating medium
 t_{a2} = Final temperature of heating medium
 t_1 = Initial temperature of heated fluid
 t_2 = Final temperature of heated fluid.


The heat exchange can be classified as follows:

- Parallel Flow**, the fluids flow in the same directions over the separating wall.



$$t_m = \frac{t_{a1} - t_{a2} + t_2 - t_1}{\log_e \frac{(t_{a1} - t_1)}{(t_{a2} - t_2)}} = \frac{\text{Initial temp. dif.} - \text{Final temp. dif.}}{2.3 \log_{10} \frac{\text{Initial temp. dif.}}{\text{Final temp. dif.}}}$$


2 Counter Flow, the directions are opposite.



$$t_m = (\text{as before}) = \frac{\text{Initial temp. dif.} - \text{Final temp. dif.}}{2.3 \log_{10} \frac{\text{Initial temp. dif.}}{\text{Final temp. dif.}}}$$

3 Evaporators or Condensers

One fluid remains at a constant temperature while changing its state.



$$t_m = (\text{as before}) = \frac{(t_1 - t_2)}{2.3 \log_{10} \frac{t_s - t_2}{t_s - t_1}}$$

4 Mixed Flow

One of the fluids takes an irregular direction with respect to the other.

$$t_m = \frac{t_{a1} - t_{a2}}{2} - \frac{t_1 - t_2}{2}$$

Heat transfer in the unsteady state

Newton's Law of cooling. In the warming and cooling of bodies, the heat gain or loss, respectively, is proportional to the difference between the temperatures of the body and the surroundings.

Let:

θ_s = Temperature of the surroundings $^{\circ}\text{C}$

θ_1 = Initial temperature of the body $^{\circ}\text{C}$

θ_2 = Temperature of the body $^{\circ}\text{C}$

k = Thermal conductivity of the body W/mK

w = Density of the body kg/m^3

s = Specific heat capacity of the body J/kgK

h = Coefficient of heat transfer between the body and the surroundings $\text{W/m}^2\text{K}$

r = Radius of a sphere or cylinder, or half thickness of a slab cooled or heated on both faces or thickness of a slab cooled or heated on one face only



t = Cooling (or heating) time secs.

Then

$$\frac{\theta_1 - \theta_s}{\theta_2 - \theta_s} = e^{-Kt} \quad \text{and} \quad \log_e(\theta_2 - \theta_s) - \log_e(\theta_1 - \theta_s) = -Kt$$

where K = Constant which can be found by measuring the temperatures of the body at different times t_1 and t_2 and which is given by


$$K = \frac{\log_e(\theta_2 - \theta_s)}{\log_e(\theta_1 - \theta_s)} \bigg/ (t_2 - t_1)$$



Cooling curve (I) and heating curve (II) showing relation of temperature and time on linear and semi-logarithmic paper.

Graphs showing how the temperature of cooling or heating up bodies can be plotted on semi-logarithmic paper by introducing the following dimensionless ratios


$$Y = \frac{\theta_2 - \theta_s}{\theta_1 - \theta_s} \quad x = \frac{kt}{wsR^2} \quad m = \frac{k}{hr}$$



The Increased Heat Requirement of Buildings during the heating up period causes a greater heat requirement than the steady state. This additional heat loss depends mainly on the type of building, length of heating interruption and heating up time, and type of heating installation. The allowance for covering the increased heat loss during heating up is usually expressed as a percentage of the heat loss in the steady state. See pages 91 and 92.

The temperatures during warming up of bodies are represented graphically by curves which are symmetrical to cooling down curves.

Logarithmic mean temperature differences



Example of using the chart

Water to water calorifier with counter flow

Primary flow temperature 80°C . Secondary return temperature 10°C

Primary return temperature 70°C . Secondary flow temperature 40°C

Original temperature difference = $80 - 70 = 10^{\circ}\text{C}$

Final temperature difference = $70 - 40 = 30^{\circ}\text{C}$

From chart: Log mean temp. dif. = 18°C

The chart can be used equally well for $^{\circ}\text{C}$ or $^{\circ}\text{F}$.

Transmission of heat

Heat transmission coefficients for metals

| | | | $\frac{Watts}{m^2 \text{ } ^\circ C}$ | $\frac{Btu}{ft^2 hr \text{ } ^\circ F}$ |
|-------|------------|------------|---------------------------------------|---|
| Water | Cast iron | Air or Gas | 8.0 | 1.4 |
| Water | Mild steel | Air or Gas | 11.0 | 2.0 |
| Water | Copper | Air or Gas | 11.0 | 2.25 |
| Water | Cast iron | Water | 220 to 280 | 40 to 50 |
| Water | Mild steel | Water | 340 to 400 | 50 to 70 |
| Water | Copper | Water | 350 to 450 | 62 to 80 |
| Air | Cast iron | Air | 6.0 | 1.0 |
| Air | Mild steel | Air | 8.0 | 1.4 |
| Steam | Cast iron | Air | 11.0 | 2.0 |
| Steam | Mild steel | Air | 11.0 | 2.5 |
| Steam | Copper | Air | 17.0 | 3.0 |
| Steam | Cast iron | Water | 900 | 160 |
| Steam | Mild steel | Water | 1050 | 185 |
| Steam | Copper | Water | 1170 | 205 |

The above values are average coefficients for practically still fluids. The coefficients are dependent on velocities of heating and heated media – on type of heating surface, temperature difference, and other circumstances. For special cases, see literature and manufacturer's data.

Table of $n^{1.3}$ for radiator and pipe coefficients in relation to various temperature differences

| n | $n^{1.3}$ | n | $n^{1.3}$ | n | $n^{1.3}$ | n | $n^{1.3}$ | n | $n^{1.3}$ | n | $n^{1.3}$ |
|-----|-----------|-----|-----------|-----|-----------|-----|-----------|-----|-----------|-----|-----------|
| 30 | 83 | 70 | 250 | 110 | 450 | 150 | 674 | 190 | 917 | 230 | 1176 |
| 35 | 102 | 75 | 273 | 115 | 477 | 155 | 704 | 195 | 948 | 235 | 1209 |
| 40 | 121 | 80 | 298 | 120 | 505 | 160 | 733 | 200 | 980 | 240 | 1242 |
| 45 | 141 | 85 | 322 | 125 | 533 | 165 | 763 | 205 | 1012 | 245 | 1219 |
| 50 | 162 | 90 | 347 | 130 | 560 | 170 | 793 | 210 | 1044 | 250 | 1310 |
| 55 | 183 | 95 | 372 | 135 | 589 | 175 | 824 | 215 | 1075 | | |
| 60 | 205 | 100 | 398 | 140 | 617 | 180 | 855 | 220 | 1110 | | |
| 65 | 226 | 105 | 424 | 145 | 645 | 185 | 887 | 225 | 1142 | | |

Heat loss of steel pipes

For various water temperatures and steam pressures

| <i>Nominal bore</i> | | <i>Heat loss W/m for fluid inside pipe</i> | | | | | | <i>Heat loss Btu/h ft for fluid inside pipe</i> | | | | | |
|---------------------|-----------|--|-------------|-------------|--------------|--------------|--------------|---|--------------|--------------|--------------|----------------|----------------|
| | | <i>Water</i> | | | | <i>Steam</i> | | <i>Water</i> | | | | <i>Steam</i> | |
| <i>in</i> | <i>mm</i> | <i>50°C</i> | <i>60°C</i> | <i>75°C</i> | <i>100°C</i> | <i>1 bar</i> | <i>4 bar</i> | <i>120°F</i> | <i>140°F</i> | <i>170°F</i> | <i>212°F</i> | <i>15 psig</i> | <i>60 psig</i> |
| $\frac{1}{2}$ | 15 | 30 | 40 | 60 | 90 | 130 | 190 | 30 | 40 | 60 | 95 | 135 | 200 |
| $\frac{3}{4}$ | 20 | 35 | 50 | 70 | 110 | 160 | 220 | 35 | 50 | 75 | 115 | 170 | 230 |
| 1 | 25 | 40 | 60 | 90 | 130 | 190 | 270 | 40 | 60 | 90 | 135 | 200 | 280 |
| $1\frac{1}{4}$ | 32 | 50 | 70 | 110 | 160 | 230 | 330 | 50 | 70 | 110 | 165 | 240 | 340 |
| $1\frac{1}{2}$ | 40 | 55 | 80 | 120 | 180 | 250 | 370 | 55 | 80 | 130 | 190 | 260 | 380 |
| 2 | 50 | 65 | 95 | 150 | 220 | 310 | 440 | 65 | 90 | 150 | 230 | 320 | 460 |
| $2\frac{1}{2}$ | 65 | 80 | 120 | 170 | 260 | 360 | 530 | 80 | 120 | 180 | 270 | 380 | 550 |
| 3 | 80 | 100 | 140 | 210 | 300 | 440 | 630 | 100 | 140 | 220 | 310 | 460 | 650 |
| 4 | 100 | 120 | 170 | 260 | 380 | 550 | 800 | 120 | 170 | 270 | 390 | 570 | 830 |
| 6 | 150 | 170 | 250 | 370 | 540 | 770 | 1100 | 170 | 250 | 380 | 560 | 800 | 1150 |

Correction factors for use with above table

| | | | |
|--|------|-----------------------------------|------|
| Single pipe along skirting or riser | 1.0 | More than one pipe along ceiling | 0.65 |
| More than one pipe along skirting or riser | 0.90 | Single pipe freely exposed | 1.1 |
| Single pipe along ceiling | 0.75 | More than one pipe freely exposed | 1.0 |

Heat loss of steel pipes

For high temperature difference (MPHW and HPHW)

For various temperature differences between pipe and air

| Nominal bore mm | Heat loss for temperature difference (W/m) | | | | | | | |
|-----------------------|--|-------|-------|-------|-------|-------|-------|-------|
| | 110°C | 125°C | 140°C | 150°C | 165°C | 195°C | 225°C | 280°C |
| 15 | 130 | 155 | 180 | 205 | 235 | 280 | 375 | 575 |
| 20 | 160 | 190 | 220 | 255 | 290 | 370 | 465 | 660 |
| 25 | 200 | 235 | 275 | 305 | 355 | 455 | 565 | 815 |
| 32 | 240 | 290 | 330 | 375 | 435 | 555 | 700 | 1000 |
| 40 | 270 | 320 | 375 | 420 | 485 | 625 | 790 | 1120 |
| 50 | 330 | 395 | 465 | 520 | 600 | 770 | 975 | 1390 |
| 65 | 390 | 465 | 540 | 615 | 715 | 910 | 1150 | 1650 |
| 80 | 470 | 560 | 650 | 740 | 860 | 1090 | 1380 | 1980 |
| 100 | 585 | 700 | 820 | 925 | 1065 | 1370 | 1740 | 2520 |
| 150 | 815 | 970 | 1130 | 1290 | 1470 | 1910 | 2430 | 3500 |
| 200 | 1040 | 1240 | 1440 | 1650 | 1900 | 2440 | 3100 | 4430 |
| 250 | 1250 | 1510 | 1750 | 1995 | 2300 | 2980 | 3780 | 5600 |
| 300 | 1470 | 1760 | 2060 | 2340 | 2690 | 3370 | 4430 | 6450 |

| Nominal bore in | Heat loss for temperature difference (Btu/hr/ft) | | | | | | | |
|-----------------------|--|-------|-------|-------|-------|-------|-------|-------|
| | 200°F | 225°F | 250°F | 275°F | 300°F | 350°F | 400°F | 500°F |
| $\frac{1}{2}$ | 140 | 160 | 190 | 215 | 245 | 310 | 390 | 595 |
| $\frac{3}{4}$ | 170 | 200 | 230 | 270 | 305 | 380 | 475 | 680 |
| 1 | 210 | 245 | 285 | 325 | 370 | 470 | 580 | 840 |
| $1\frac{1}{4}$ | 265 | 300 | 345 | 400 | 460 | 565 | 715 | 1035 |
| $1\frac{1}{2}$ | 290 | 335 | 390 | 450 | 510 | 650 | 815 | 1160 |
| 2 | 350 | 410 | 480 | 550 | 630 | 800 | 1000 | 1460 |
| $2\frac{1}{2}$ | 430 | 490 | 560 | 650 | 750 | 880 | 1190 | 1700 |
| 3 | 580 | 655 | 670 | 780 | 900 | 1130 | 1410 | 2040 |
| 4 | 620 | 730 | 850 | 825 | 1120 | 1420 | 1790 | 2600 |
| 6 | 860 | 1010 | 1170 | 1360 | 1540 | 1980 | 2700 | 3600 |
| 8 | 1090 | 1390 | 1480 | 1740 | 2000 | 2540 | 3180 | 4610 |
| 10 | 1320 | 1535 | 1810 | 2100 | 2425 | 3100 | 3900 | 5700 |
| 12 | 1530 | 1835 | 2125 | 2460 | 2830 | 3500 | 4950 | 6650 |

Heat loss of copper pipes

For various temperature differences between pipe and air

| Nominal bore | | Heat loss for temperature difference (W/m) | | | Heat loss for temperature difference ($Btu/hr\ ft$) | | |
|----------------|-----------|--|---------------|---------------|---|----------------|----------------|
| <i>in</i> | <i>mm</i> | $40^{\circ}C$ | $55^{\circ}C$ | $72^{\circ}C$ | $70^{\circ}F$ | $100^{\circ}F$ | $130^{\circ}F$ |
| $\frac{1}{2}$ | 15 | 21 | 32 | 45 | 22 | 34 | 47 |
| $\frac{3}{4}$ | 22 | 28 | 43 | 60 | 29 | 45 | 53 |
| 1 | 28 | 34 | 53 | 76 | 36 | 56 | 79 |
| $1\frac{1}{4}$ | 35 | 41 | 64 | 89 | 43 | 67 | 93 |
| $1\frac{1}{2}$ | 42 | 47 | 74 | 104 | 49 | 77 | 108 |
| 2 | 54 | 59 | 93 | 131 | 62 | 97 | 136 |
| $2\frac{1}{2}$ | 67 | 71 | 111 | 156 | 74 | 116 | 162 |
| 3 | 76 | 83 | 129 | 181 | 87 | 135 | 189 |
| 4 | 108 | 107 | 165 | 232 | 111 | 172 | 241 |

Heat loss of insulated copper pipes

For temperature difference $55^{\circ}C$ ($100^{\circ}F$)

For 25 mm thick insulation with $k = 0.043\ W/m^{\circ}C$ ($0.3\ Btu\ in/ft^2\ hr\ ^{\circ}F$)

| Nominal bore | | Heat loss | | Nominal bore | | Heat loss | |
|----------------|-----------|-----------|--------------|----------------|-----------|-----------|--------------|
| <i>in</i> | <i>mm</i> | W/m | $Btu/hr\ ft$ | <i>in</i> | <i>mm</i> | W/m | $Btu/hr\ ft$ |
| $\frac{3}{4}$ | 22 | 8 | 8 | 2 | 54 | 14.5 | 15 |
| 1 | 28 | 10 | 10 | $2\frac{1}{2}$ | 67 | 16 | 17 |
| $1\frac{1}{2}$ | 42 | 11.5 | 12 | 3 | 76 | 19 | 20 |

Heat loss through lagging

| Insulating material | Heat loss through 75 mm thickness per 55 K difference between faces W/m^2 |
|---------------------|---|
| Asbestos | 75 |
| Cork | 32 |
| Sawdust | 54 |

Loss for bare metal for 55 K difference is approximately $485\ W/m^2$

Densities

| | kg/m^3 | lb/ft^3 |
|------------------|-----------|-----------|
| Metals | | |
| Aluminium | 2690 | 168 |
| Antimony | 6690 | 417 |
| Brass, cast | 8100 | 505 |
| Bronze, gunmetal | 8450 | 529 |
| Copper | 8650 | 551 |
| Gold, pure, cast | 19 200 | 1200 |
| Iron, cast | 7480 | 467 |
| Iron, wrought | 7850 | 486 |
| Lead | 11 340 | 705 |
| Mercury | 13 450 | 840 |
| Nickel | 8830 | 551 |
| Platinum | 21 450 | 1340 |
| Silver | 10 500 | 655 |
| Steel | 7900 | 493 |
| Tin | 7280 | 455 |
| Zinc | 7200 | 444 |
| Solids | | |
| Asbestos | 3060 | 191 |
| Asphalt | 1650 | 103 |
| Brick | 1000-2000 | 62-134 |
| Cement, Portland | 3000 | 187 |
| Cement, Roman | 1550 | 97 |
| Chalk | 1500-2800 | 95-175 |
| Coal | 1500-1650 | 95-103 |
| Coke | 1000 | 62 |
| Concrete, mean | 2240 | 140 |
| Dowtherm | 880-1073 | 55-67 |
| Glass, window | 2640 | 164 |
| Granite | 2130 | 133 |
| Gypsum | 2165 | 135 |
| Ice, at 0°C | 910 | 57 |
| Lime | 2740 | 171 |

| | kg/m^3 | lb/ft^3 |
|---------------------|-----------|-----------|
| Limestone | 3170 | 198 |
| Marble | 2650 | 165 |
| Mortar | 1400-1750 | 86-109 |
| Peat | 600-1330 | 37-83 |
| Plaster | 1180 | 73 |
| Porcelain | 2300 | 143 |
| Rubber | 920 | 67 |
| Salt, common | 2130 | 133 |
| Soap | 1070 | 67 |
| Starch | 945 | 59 |
| Sulphur | 2020 | 126 |
| Wax, paraffin | 930 | 58 |
| Wood | 700-900 | 44-56 |
| Liquids | | |
| Acetic acid | 1049 | 66 |
| Alcohol | 790 | 49 |
| Ammonia | 610 | 38 |
| Beer | 1030 | 64 |
| Ether | 870 | 54 |
| Glycerine | 1270 | 79 |
| Kerosene (paraffin) | 810 | 50 |
| Oil, mineral | 850 | 53 |
| Oil, vegetable | 920 | 57 |
| Milk | 1030 | 64 |
| Petrol | 700-750 | 44-47 |
| Turpentine | 870 | 54 |
| Water, distilled | 1000 | 62 |
| Water, sea, 4°C | 1030 | 64 |

Specific heat capacities of gases

| Gas | Formula | Specific heat capacity | | | | | Gas constant = ($C_p - C_v$) | |
|---------------------|-------------------------------|------------------------|-------|---------|-------|--------------------|--------------------------------|---------|
| | | Btu/lb °F | | kJ/kg K | | $\gamma = C_p/C_v$ | ft lb/lb °F | kJ/kg K |
| | | C_p | C_v | C_p | C_v | | | |
| Acetylene | C ₂ H ₂ | 0.350 | 0.270 | 1.47 | 1.13 | 1.28 | 59.34 | 0.34 |
| Air | — | 0.251 | 0.171 | 1.01 | 0.716 | 1.40 | 53.34 | 0.29 |
| Ammonia | NH ₃ | 0.523 | 0.399 | 2.19 | 1.67 | 1.31 | 96.50 | 0.52 |
| Blast furnace gas | — | 0.245 | 0.174 | 1.03 | 0.729 | 1.40 | 55.05 | 0.297 |
| Carbon dioxide | CO ₂ | 0.210 | 0.160 | 0.827 | 0.632 | 1.31 | 38.86 | 0.189 |
| Carbon monoxide | CO | 0.243 | 0.172 | 1.02 | 0.720 | 1.41 | 55.14 | 0.297 |
| Combustion products | — | 0.24 | — | 1.01 | — | — | — | — |
| Ethylene | C ₂ H ₄ | 0.400 | 0.330 | 1.67 | 1.38 | 1.20 | 55.08 | 0.29 |
| Hydrogen | H ₂ | 3.42 | 2.44 | 14.24 | 10.08 | 1.40 | 765.90 | 4.16 |
| Methane | CH ₄ | 0.593 | 0.450 | 2.23 | 1.71 | 1.32 | 111.31 | 0.60 |
| Nitrogen | N ₂ | 0.247 | 0.176 | 1.034 | 0.737 | 1.40 | 54.99 | 0.297 |
| Oxygen | O ₂ | 0.219 | 0.157 | 0.917 | 0.656 | 1.40 | 48.24 | 0.260 |
| Sulphur dioxide | SO ₂ | 0.154 | 0.123 | 0.645 | 0.515 | 1.25 | 24.10 | 0.130 |

Density of gases

| <i>Gas</i> | <i>Molecular weight</i> | <i>Density at 0°C and atmospheric pressure</i> | |
|---------------------|-------------------------|--|--------------------------|
| | | <i>kg/m³</i> | <i>lb/ft³</i> |
| Acetylene | 26 | 1.170 | 0.0729 |
| Air | — | 1.293 | 0.0806 |
| Ammonia | 17 | 0.769 | 0.0480 |
| Blast furnace gas | — | 1.250 | 0.0780 |
| Carbon dioxide | 44 | 1.977 | 0.1234 |
| Carbon monoxide | 28 | 1.250 | 0.0780 |
| Combustion products | — | 1.11 | 0.069 |
| Ethylene | 28 | 1.260 | 0.0786 |
| Hydrogen | 2 | 0.0899 | 0.0056 |
| Methane | 16 | 0.717 | 0.0447 |
| Nitrogen | 28 | 1.250 | 0.0780 |
| Oxygen | 32 | 1.429 | 0.0892 |
| Sulphur dioxide | 64 | 2.926 | 0.1828 |

Specific heat capacities between 0°C and 100°C

| | <i>kJ/kg K</i> | <i>Btu/lb °F</i> | | <i>kJ/kg K</i> | <i>Btu/lb °F</i> |
|---------------------|----------------|------------------|-----------------|----------------|------------------|
| Metals | | | Liquids | | |
| Aluminium | 0.912 | 0.218 | Ice | 2.11 | 0.504 |
| Antimony | 0.214 | 0.051 | India rubber | 1.1-4.1 | 0.27-0.98 |
| Copper | 0.389 | 0.093 | Limestone | 0.84 | 0.20 |
| Gold | 0.130 | 0.031 | Marble | 0.88 | 0.21 |
| Iron | 0.460 | 0.110 | Peat | 1.88 | 0.45 |
| Lead | 0.130 | 0.031 | Plaster | 0.84 | 0.20 |
| Mercury | 0.138 | 0.033 | Porcelain | 1.07 | 0.255 |
| Nickel | 0.452 | 0.108 | Sand | 0.82 | 0.19 |
| Platinum | 0.134 | 0.032 | Sulphur | 0.72 | 0.17 |
| Silver | 0.234 | 0.056 | Wood | 2.3-2.7 | 0.55-0.65 |
| Tin | 0.230 | 0.055 | | | |
| Zinc | 0.393 | 0.094 | | | |
| Metal alloys | | | | | |
| Ball metal | 0.360 | 0.086 | Acetic acid | 2.13 | 0.51 |
| Brass | 0.377 | 0.090 | Alcohol | 2.93 | 0.70 |
| Bronze | 0.435 | 0.104 | Ammonia | 0.47 | 0.11 |
| Nickel steel | 0.456 | 0.109 | Benzol | 1.80 | 0.43 |
| Solder | 0.167 | 0.04 | Dowtherm | 1.55 | 0.37 |
| | | | Ether | 2.10 | 0.50 |
| Solids | | | Ethylene glycol | 2.38 | 0.57 |
| Asbestos | 0.84 | 0.20 | Glycerine | 2.41 | 0.58 |
| Ashes | 0.84 | 0.20 | Milk | 3.93 | 0.94 |
| Asphalt | 0.80 | 0.19 | Naphtholene | 1.78 | 0.43 |
| Brick | 0.92 | 0.22 | Oil, mineral | 1.67 | 0.40 |
| Carbon | 0.71 | 0.17 | Oil, vegetable | 1.68 | 0.40 |
| Coke | 0.85 | 0.203 | Paraffin | 2.14 | 0.51 |
| Coal | 1.31 | 0.314 | Petroleum | 2.09 | 0.50 |
| Concrete | 1.13 | 0.27 | Sulphuric acid | 1.38 | 0.33 |
| Cork | 2.03 | 0.485 | Turpentine | 1.98 | 0.47 |
| Glass | 0.84 | 0.20 | Water, fresh | 4.19 | 1.00 |
| Granite | 0.75 | 0.18 | Water, sea | 3.94 | 0.94 |
| Graphite | 0.71 | 0.17 | | | |

Boiling points at atmospheric pressure

| | $^{\circ}C$ | $^{\circ}F$ | | $^{\circ}C$ | $^{\circ}F$ |
|----------------|-------------|-------------|------------|-------------|-------------|
| Alcohol | 78 | 172.4 | Hydrogen | -253 | -423 |
| Ammonia | -33.4 | -28.1 | Nitrogen | -196 | -320 |
| Aniline | 184 | 363 | Oxygen | -183 | -297 |
| Carbon dioxide | -78.5 | -109.3 | Sulphur | 440 | 823 |
| Downtherm | 258 | 496 | Toluene | 111 | 230 |
| Ether | 35 | 95 | Turpentine | 160 | 320 |
| Glycerine | 290 | 554 | Water | 100 | 212 |
| Helium | -269 | -452 | | | |

Latent heats of vaporisation

| | <i>kJ/kg</i> | <i>Btu/lb</i> | | <i>kJ/kg</i> | <i>Btu/lb</i> |
|----------------|--------------|---------------|------------|--------------|---------------|
| Alcohol | 896 | 385 | Hydrogen | 461 | 198 |
| Ammonia | 1369 | 589 | Nitrogen | 199 | 86 |
| Aniline | 450 | 193 | Oxygen | 214 | 92 |
| Carbon dioxide | 574 | 247 | Sulphur | 1510 | 650 |
| Ether | 377 | 162 | Toluene | 351 | 151 |
| Helium | 21 | 9 | Turpentine | 293 | 126 |
| | | | Water | 2257 | 970.4 |

Melting and solidifying points at atmospheric pressure

| | $^{\circ}C$ | $^{\circ}F$ | | $^{\circ}C$ | $^{\circ}F$ |
|----------------|-------------|-------------|---------|-------------|-------------|
| Alcohol | -97 | -143 | Lead | 327 | 621 |
| Aluminium | 658 | 1218 | Mercury | -39 | -38 |
| Ammonia | -78 | -108 | Nickel | 1455 | 2646 |
| Aniline | -6 | 21 | Silver | 960 | 1761 |
| Carbon dioxide | -56 | -69 | Sulphur | 106-119 | 234-247 |
| Copper | 1083 | 1981 | Tin | 232 | 449 |
| Dowtherm | 12 | 54 | Water | 0 | 32 |
| Glycerine | -16 | 4 | Wax | 64 | 149 |
| Gold | 1063 | 1945 | Zinc | 419 | 787 |
| Iron, pure | 1530 | 2786 | | | |

Latent heats of melting

| | <i>kJ/kg</i> | <i>Btu/lb</i> | | <i>kJ/kg</i> | <i>Btu/lb</i> |
|------------------|--------------|---------------|---------|--------------|---------------|
| Aluminium | 321 | 138.2 | Lead | 22.4 | 9.65 |
| Ammonia | 339 | 146 | Mercury | 11.8 | 5.08 |
| Aniline | 113.5 | 48.8 | Nickel | 19.4 | 8.35 |
| Carbon dioxide | 184 | 79 | Silver | 88.0 | 37.9 |
| Copper | 176 | 75.6 | Sulphur | 39.2 | 16.87 |
| Glycerine | 176 | 75.6 | Tin | 58.5 | 25.2 |
| Iron, grey cast | 96 | 41.4 | Water | 334 | 144 |
| Iron, white cast | 138 | 59.4 | Zinc | 118 | 50.63 |
| Iron slag | 209 | 90.0 | | | |

Coefficients of linear expansion Average values
between 0°C and 100°C

| | $\frac{m}{mK} \times 10^6$ | $\frac{in}{in^\circ F} \times 10^6$ | | $\frac{m}{mK} \times 10^6$ | $\frac{in}{in^\circ F} \times 10^6$ |
|--------------|----------------------------|-------------------------------------|--------------------------------------|----------------------------|-------------------------------------|
| Aluminium | 22.2 | 12.3 | Lead | 28.0 | 15.1 |
| Antimony | 10.4 | 5.8 | Marble | 12 | 6.5 |
| Brass | 18.7 | 10.4 | Masonry | 4.5-9.0 | 2.5-9.0 |
| Brick | 5.5 | 3.1 | Mortar | 7.3-13.5 | 4.1-7.5 |
| Bronze | 18.0 | 10.0 | Nickel | 13.0 | 7.2 |
| Cement | 10.0 | 6.0 | Plaster | 25 | 13.9 |
| Concrete | 14.5 | 8.0 | Porcelain | 3.0 | 1.7 |
| Copper | 16.5 | 9.3 | Rubber | 77 | 42.8 |
| Glass, hard | 5.9 | 3.3 | Silver | 19.5 | 10.7 |
| Glass, plate | 9.0 | 5.0 | Solder | 24.0 | 13.4 |
| Gold | 14.2 | 8.2 | Steel, nickel | 13.0 | 7.3 |
| Graphite | 7.9 | 4.4 | Type metal | 19.0 | 10.8 |
| Iron, pure | 12.0 | 6.7 | Wood, oak parallel to grain | 4.9 | 2.7 |
| Iron, cast | 10.4 | 5.9 | Wood, oak across grain | 5.4 | 3.0 |
| Iron, forged | 11.3 | 6.3 | Zinc | 29.7 | 16.5 |

Thermal properties of water

| <i>Temp.</i> °F | <i>Abs.</i> <i>pressure</i> lb/in ² | <i>Density</i> lb/ft ³ | <i>Specific</i> <i>gravity</i> | <i>Specific</i> <i>volume</i> ft ³ /lb | <i>Specific</i> <i>heat</i> Btu lb °F | <i>Specific</i> <i>entropy</i> Btu lb °F | <i>Dynamic</i> <i>viscosity</i> <i>in</i> <i>poises</i> | <i>Specific</i> <i>enthalpy</i> Btu/lb |
|--------------------|--|--------------------------------------|-----------------------------------|---|--|---|--|--|
| 32 | 0.088 | 62.42 | 1.000 | 0.0160 | 1.0093 | 0.0000 | 0.0179 | 0 |
| 40 | 0.122 | 62.42 | 1.000 | 0.0160 | 1.0048 | 0.01615 | 0.0155 | 8 |
| 50 | 0.178 | 62.42 | 1.000 | 0.0160 | 1.0015 | 0.03595 | 0.0131 | 18 |
| 60 | 0.256 | 62.38 | 1.000 | 0.0160 | 0.9995 | 0.05765 | 0.0113 | 28 |
| 62 | 0.275 | 62.35 | 1.000 | 0.0160 | 0.9992 | 0.05919 | 0.0110 | 30 |
| 70 | 0.363 | 62.30 | 0.999 | 0.0160 | 0.9982 | 0.0754 | 0.0098 | 38 |
| 80 | 0.507 | 62.22 | 0.998 | 0.0160 | 0.9975 | 0.0929 | 0.0086 | 48 |
| 90 | 0.698 | 62.11 | 0.996 | 0.0161 | 0.9971 | 0.1112 | 0.0076 | 58 |
| 100 | 0.949 | 61.99 | 0.994 | 0.0161 | 0.9970 | 0.1292 | 0.0068 | 68 |
| 110 | 1.27 | 61.86 | 0.992 | 0.0161 | 0.9971 | 0.1469 | 0.0062 | 78 |
| 120 | 1.69 | 61.71 | 0.990 | 0.0162 | 0.9974 | 0.1641 | 0.0056 | 88 |
| 130 | 2.22 | 61.55 | 0.987 | 0.0162 | 0.9978 | 0.1816 | 0.0051 | 98 |
| 140 | 2.89 | 61.38 | 0.984 | 0.0163 | 0.9984 | 0.1981 | 0.0047 | 108 |
| 150 | 3.72 | 61.20 | 0.982 | 0.0163 | 0.9990 | 0.2147 | 0.0043 | 118 |
| 160 | 4.74 | 61.00 | 0.979 | 0.0164 | 0.9988 | 0.2309 | 0.0040 | 128 |
| 170 | 5.99 | 60.80 | 0.975 | 0.0164 | 1.0007 | 0.2472 | 0.0037 | 138 |
| 180 | 7.51 | 60.58 | 0.971 | 0.0165 | 1.0017 | 0.2629 | 0.00345 | 148 |
| 190 | 9.33 | 60.36 | 0.969 | 0.0166 | 1.0028 | 0.2787 | 0.00323 | 158 |
| 200 | 11.53 | 60.12 | 0.965 | 0.0166 | 1.0039 | 0.2938 | 0.00302 | 168 |
| 210 | 14.13 | 59.92 | 0.958 | 0.0167 | 1.0052 | 0.3089 | 0.00287 | 178 |
| 212 | 14.70 | 59.88 | 0.957 | 0.0167 | 1.0055 | 0.3118 | 0.00285 | 180 |
| 220 | 17.19 | 59.66 | 0.955 | 0.0168 | 1.0068 | 0.3237 | 0.00272 | 188.1 |
| 230 | 20.77 | 59.37 | 0.950 | 0.0168 | 1.0087 | 0.3385 | 0.00257 | 198.2 |
| 240 | 24.97 | 59.17 | 0.946 | 0.0169 | 1.0104 | 0.3531 | 0.00254 | 208.3 |
| 250 | 29.81 | 58.84 | 0.941 | 0.0170 | 1.0126 | 0.3676 | 0.00230 | 218.4 |
| 260 | 35.42 | 58.62 | 0.940 | 0.0171 | 1.0148 | 0.3818 | 0.00217 | 228.6 |
| 270 | 41.85 | 58.25 | 0.933 | 0.0172 | 1.0174 | 0.3962 | 0.00208 | 238.7 |
| 280 | 49.18 | 58.04 | 0.929 | 0.0172 | 1.0200 | 0.4097 | 0.00200 | 248.9 |
| 290 | 57.55 | 57.65 | 0.923 | 0.0173 | 1.0230 | 0.4236 | 0.00193 | 259.2 |
| 300 | 67.00 | 57.41 | 0.920 | 0.0174 | 1.0260 | 0.4272 | 0.00186 | 262.5 |
| 310 | 77.67 | 57.00 | 0.913 | 0.0175 | 1.0296 | 0.4507 | 0.00179 | 279.8 |
| 320 | 89.63 | 56.65 | 0.906 | 0.0177 | 1.0332 | 0.4643 | 0.00173 | 290.2 |
| 330 | 103.00 | 56.31 | 0.900 | 0.0178 | 1.0368 | 0.4777 | 0.00168 | 300.6 |
| 340 | 118.0 | 55.95 | 0.897 | 0.0179 | 1.0404 | 0.4908 | 0.00163 | 311.1 |
| 350 | 134.6 | 55.65 | 0.890 | 0.0180 | 1.0440 | 0.5040 | 0.00158 | 321.7 |
| 360 | 153.0 | 55.19 | 0.883 | 0.0181 | 1.0486 | 0.5158 | 0.00153 | 332.3 |
| 370 | 173.3 | 54.78 | 0.876 | 0.0182 | 1.0532 | 0.5292 | 0.00149 | 342.9 |
| 380 | 195.6 | 54.36 | 0.870 | 0.0184 | 1.0578 | 0.5420 | 0.00145 | 353.5 |
| 390 | 220.2 | 53.96 | 0.865 | 0.0187 | 1.0624 | 0.5548 | 0.00141 | 364.3 |
| 400 | 247.1 | 53.62 | 0.834 | 0.0186 | 1.0670 | 0.5677 | 0.00137 | 375.3 |
| 450 | 422 | 51.3 | 0.821 | 0.0195 | 1.0950 | 0.6298 | — | 430.2 |
| 500 | 679 | 48.8 | 0.781 | 0.0205 | 1.1300 | 0.6907 | — | 489.1 |
| 550 | 1043 | 45.7 | 0.730 | 0.0219 | 1.2000 | 0.7550 | — | 553.5 |
| 600 | 1540 | 41.5 | 0.666 | 0.0241 | 1.3620 | 0.8199 | — | 623.2 |
| 706.1 | 3226 | 19.2 | 0.307 | 0.0522 | — | 1.0785 | — | 925.0 |

Thermal properties of water

| <i>Temp</i> °C | <i>Abs</i> <i>pressure</i> kN/m ² | <i>Density</i> kg/m ³ | <i>Specific</i> <i>volume</i> m ³ /kg | <i>Specific</i> <i>heat capacity</i> kJ/kg K | <i>Specific</i> <i>entropy</i> kJ/kg K | <i>Dynamic</i> <i>viscosity</i> centipoise | <i>Specific</i> <i>enthalpy</i> kJ/kg |
|-------------------|--|-------------------------------------|--|--|--|--|---|
| 0 | 0.6 | 1000 | 0.00100 | 4.217 | 0 | 1.78 | 0 |
| 5 | 0.9 | 1000 | 0.00100 | 4.204 | 0.075 | 1.52 | 21.0 |
| 10 | 1.2 | 1000 | 0.00100 | 4.193 | 0.150 | 1.31 | 41.9 |
| 15 | 1.7 | 999 | 0.00100 | 4.186 | 0.223 | 1.14 | 62.9 |
| 20 | 2.3 | 990 | 0.00100 | 4.182 | 0.296 | 1.00 | 83.8 |
| 25 | 3.2 | 997 | 0.00100 | 4.181 | 0.367 | 0.890 | 104.8 |
| 30 | 4.3 | 996 | 0.00100 | 4.179 | 0.438 | 0.798 | 125.7 |
| 35 | 5.6 | 994 | 0.00101 | 4.178 | 0.505 | 0.719 | 146.7 |
| 40 | 7.7 | 991 | 0.00101 | 4.179 | 0.581 | 0.653 | 167.6 |
| 45 | 9.6 | 990 | 0.00101 | 4.181 | 0.637 | 0.596 | 188.6 |
| 50 | 12.5 | 988 | 0.00101 | 4.182 | 0.707 | 0.547 | 209.6 |
| 55 | 15.7 | 986 | 0.00101 | 4.183 | 0.767 | 0.504 | 230.5 |
| 60 | 20.0 | 980 | 0.00102 | 4.185 | 0.832 | 0.467 | 251.5 |
| 65 | 25.0 | 979 | 0.00102 | 4.188 | 0.893 | 0.434 | 272.4 |
| 70 | 31.3 | 978 | 0.00102 | 4.190 | 0.966 | 0.404 | 293.4 |
| 75 | 38.6 | 975 | 0.00103 | 4.194 | 1.016 | 0.378 | 314.3 |
| 80 | 47.5 | 971 | 0.00103 | 4.197 | 1.076 | 0.355 | 335.3 |
| 85 | 57.8 | 969 | 0.00103 | 4.203 | 1.134 | 0.334 | 356.2 |
| 90 | 70.0 | 962 | 0.00104 | 4.205 | 1.192 | 0.314 | 377.2 |
| 95 | 84.5 | 962 | 0.00104 | 4.213 | 1.250 | 0.297 | 398.1 |
| 100 | 101.33 | 962 | 0.00104 | 4.216 | 1.307 | 0.281 | 419.1 |
| 105 | 121 | 955 | 0.00105 | 4.226 | 1.382 | 0.267 | 440.2 |
| 110 | 143 | 951 | 0.00105 | 4.233 | 1.418 | 0.253 | 461.3 |
| 115 | 169 | 947 | 0.00106 | 4.240 | 1.473 | 0.241 | 482.5 |
| 120 | 199 | 943 | 0.00106 | 4.240 | 1.527 | 0.230 | 503.7 |
| 125 | 228 | 939 | 0.00106 | 4.254 | 1.565 | 0.221 | 524.3 |
| 130 | 270 | 935 | 0.00107 | 4.270 | 1.635 | 0.212 | 546.3 |
| 135 | 313 | 931 | 0.00107 | 4.280 | 1.687 | 0.204 | 567.7 |
| 140 | 361 | 926 | 0.00108 | 4.290 | 1.739 | 0.196 | 588.7 |
| 145 | 416 | 922 | 0.00108 | 4.300 | 1.790 | 0.190 | 610.0 |
| 150 | 477 | 918 | 0.00109 | 4.310 | 1.842 | 0.185 | 631.8 |
| 155 | 543 | 912 | 0.00110 | 4.335 | 1.892 | 0.180 | 653.8 |
| 160 | 618 | 907 | 0.00110 | 4.350 | 1.942 | 0.174 | 674.5 |
| 165 | 701 | 902 | 0.00111 | 4.364 | 1.992 | 0.169 | 697.3 |
| 170 | 792 | 897 | 0.00111 | 4.380 | 2.041 | 0.163 | 718.1 |
| 175 | 890 | 893 | 0.00112 | 4.389 | 2.090 | 0.158 | 739.8 |
| 180 | 1000 | 887 | 0.00113 | 4.420 | 2.138 | 0.153 | 763.1 |
| 185 | 1120 | 882 | 0.00113 | 4.444 | 2.187 | 0.149 | 785.3 |
| 190 | 1260 | 876 | 0.00114 | 4.460 | 2.236 | 0.145 | 807.5 |
| 195 | 1400 | 870 | 0.00115 | 4.404 | 2.282 | 0.141 | 829.9 |
| 200 | 1550 | 863 | 0.00116 | 4.497 | 2.329 | 0.138 | 851.7 |
| 225 | 2550 | 834 | 0.00120 | 4.648 | 2.569 | 0.121 | 966.8 |
| 250 | 3990 | 800 | 0.00125 | 4.867 | 2.797 | 0.110 | 1087 |
| 275 | 5950 | 756 | 0.00132 | 5.202 | 3.022 | 0.0972 | 1211 |
| 300 | 8600 | 714 | 0.00140 | 5.769 | 3.256 | 0.0897 | 1345 |
| 325 | 12 130 | 654 | 0.00153 | 6.861 | 3.501 | 0.0790 | 1494 |
| 350 | 16 540 | 575 | 0.00174 | 10.10 | 3.781 | 0.0648 | 1672 |
| 360 | 18 680 | 526 | 0.00190 | 14.60 | 3.921 | 0.0582 | 1764 |

Properties of water

Density: At 4 °C 1 litre = 1 kg

At 62°F 1 gal = 10 lb

| | | |
|----------------------------|--------------------------|--------------------------|
| Freezing temperature | 0°C | 32°F |
| Boiling temperature | 100°C | 212°F |
| Latent heat of melting | 334 kJ/kg | 144 Btu/lb |
| Latent heat of evaporation | 2,270 kJ/kg | 977 Btu/lb |
| Critical temperature | 380-386°C | 706-716°F |
| Critical pressure | 23,520 kN/m ² | 3,200 lb/in ² |
| Specific heat capacity | | |
| water | 4.187 kJ/kg K | 1.00 Btu/lb °F |
| ice | 2.108 kJ/kg K | 0.504 Btu/lb °F |
| water vapour | 1.996 kJ/kg K | 0.477 Btu/lb °F |

Thermal expansion

From 4°C to 100°C water expands by $\frac{1}{24}$ of its original volume.

| | |
|----------------------------|-----------------------------|
| Bulk modulus of elasticity | 2,068,500 kN/m ² |
| | 300,000 lb/in ² |

5

Properties of steam and air

Properties of steam and other vapours

A **vapour** is any substance in the gaseous state which does not even approximately follow the general gas laws.

Highly superheated vapours are gases, if the superheat is sufficiently great, and they then approximately follow the general gas law.

Conditions of vapours

- 1 **Dry Saturated vapour** is free from unvaporised liquid particles.
- 2 **Wet Saturated vapour** carries liquid globules in suspension.
- 3 **Superheated vapour** is vapour the temperature of which is higher than that of the boiling point corresponding to the pressure.

Dryness fraction or quality of saturated vapour (X) is the percentage of dry vapour present in the given amount of the wet saturated vapour.

$$X = \frac{W_s}{W_s + W_w} \times 100\%$$

W_s = Weight of dry steam in steam considered

W_w = Weight of water in steam

The heat of the liquid 'h' is the heat in Joules per kg required to raise the temperature of the liquid from 0°C to the temperature at which the liquid begins to boil at the given pressure.

$$h = ct$$

c = Mean specific heat capacity of water

t = Temperature of formation of steam at pressure considered $^\circ\text{C}$

The latent heat of evaporation 'L' is the heat required to change a liquid at a given temperature and pressure into a vapour at the same temperature and pressure. It is divided into two parts

- 1 External latent heat of vapour = External work heat
- 2 Internal latent heat of vapour = Heat due to change of state

The total heat of a vapour (or enthalpy) is the amount of heat which must be supplied to 1 kg of the liquid which is at 0°C to convert it at constant pressure into vapour at the temperature and pressure considered.

Total heat of dry saturated vapour

$$H = h + L \text{ (Joules per kg)}$$

h = Heat of liquid at the temperature of the wet vapour, Joules per kg

L = Latent heat, Joules per kg

Total heat of wet saturated vapour

$$H_w = h + xL \text{ (Joules per kg)}$$

x = Dryness factor

Total heat of superheated vapour

$$H_s = h + L + c(t_s - t) \text{ (Joules per kg)}$$

c = Mean specific heat capacity of superheated vapour at the pressure and degree of superheat considered

t_s = Temperature of superheat °C

t_1 = Temperature of formation of steam °C

Specific volumes of wet vapour

$$V_w = (1 - x)V + xV_D$$

$$V_w = xV_D, \quad x = \frac{V_w}{V_D}, \quad \text{when } x = \text{very small}$$

V_w = Specific volume of the wet vapour, m³ per kg

V_D = Specific volume of dry saturated vapour of the same pressure, m³ per kg (Can be found from the Vapour Tables).

Specific volume of superheated vapour

Approximate method by using Charles' Law

$$V = \frac{V_s T_s}{T_1}$$

Entropy of steam**1 Entropy of water**

Change of Entropy = $\log_e (T_1/T)$

T_1, T = Absolute temperature.

Entropy of water above freezing point = $\phi_w = \log_e (T_1/273)$

2 Entropy of evaporation

Change of Entropy during evaporation = dL/T

Entropy of 1 kg of wet steam above freezing point

$$\phi_s = \phi_w + \frac{xL_1}{T_1}$$

3 Entropy of superheated steam

Change of entropy per kg of steam during superheating = $C_p \log_e (T/T_1)$

Total entropy of 1 kg of superheated steam above freezing point

$$= \phi_w + \frac{L_1}{T_1} + C_p \log_e \frac{T_s}{T_1}$$

L_1 = Latent heat of evaporation at $T_1^\circ\text{C}$ absolute

T_1 = Absolute temperature of evaporation

T_s = Absolute temperature of superheat

Temperature – entropy diagram for steam

Shows the relationship between Pressure, Temperature, Dryness Fraction and Entropy.


When two of these factors are given the two others can be found on the chart.

The ordinates represent the Absolute Temperature and the Entropy.

The chart consists of the following lines:

- 1 Isothermal lines
- 2 Pressure lines
- 3 Lines of dryness fraction
- 4 Water line between water and steam
- 5 Dry steam lines
- 6 Constant volume lines

The total heat is given by the area, enclosed by absolute zero base water line and horizontal and vertical line from the respective points.



An adiabatic expansion is a vertical line (expansion at constant entropy, no transfer of heat).

C = Critical temperature of steam

= 706°F to 716°F

= 375°C to 380°C

Critical pressure: $3200 \text{ lb/in}^2 = 217.8 \text{ atm} = 23,500 \text{ kN/m}^2$

Mollier or total heat – entropy chart

Contains the same lines as the temperature-entropy diagram, but with ordinates representing the total heat and entropy of steam. This diagram is used to find the drop in the total heat of steam during an adiabatic expansion.

Total heat of superheated steam (Btu per lb)

| <i>Abs. Pres.</i> <i>lb/in²</i> | <i>Sat. temp.</i> <i>°F</i> | <i>Degrees of Superheat °F</i> | | | | | | |
|---|--------------------------------|--------------------------------|-----------|-----------|------------|------------|------------|------------|
| | | <i>0</i> | <i>40</i> | <i>80</i> | <i>120</i> | <i>160</i> | <i>200</i> | <i>280</i> |
| 20 | 228 | 1157.1 | 1177.2 | 1197.2 | 1216.9 | 1236.6 | 1256.1 | 1294.9 |
| 30 | 250.3 | 1165.5 | 1185.9 | 1206.1 | 1226.1 | 1245.9 | 1265.6 | 1304.7 |
| 40 | 267.2 | 1171.6 | 1192.3 | 1212.9 | 1233.0 | 1253.0 | 1272.8 | 1312.2 |
| 50 | 280.9 | 1176.3 | 1197.3 | 1218.1 | 1238.5 | 1258.6 | 1278.5 | 1317.9 |
| 60 | 292.6 | 1180.1 | 1201.4 | 1222.2 | 1242.8 | 1263.1 | 1283.2 | 1322.9 |
| 70 | 302.8 | 1183.3 | 1204.7 | 1225.8 | 1246.6 | 1266.9 | 1287.2 | 1327.1 |
| 80 | 311.9 | 1186.1 | 1207.9 | 1229.1 | 1250.0 | 1270.5 | 1290.9 | 1330.8 |
| 90 | 320.2 | 1188.5 | 1210.5 | 1232.1 | 1253.0 | 1273.7 | 1294.0 | 1334.2 |
| 100 | 327.9 | 1190.7 | 1212.9 | 1234.6 | 1255.7 | 1276.5 | 1297.0 | 1337.3 |
| 120 | 341.3 | 1194.3 | 1216.9 | 1239.0 | 1260.4 | 1281.3 | 1302.0 | 1342.6 |
| 140 | 353.0 | 1197.2 | 1220.2 | 1242.5 | 1264.2 | 1285.5 | 1306.3 | 1347.1 |
| 160 | 363.6 | 1199.7 | 1222.9 | 1245.6 | 1267.6 | 1289.1 | 1310.0 | 1351.1 |
| 180 | 373.1 | 1201.7 | 1225.5 | 1248.3 | 1270.7 | 1292.2 | 1313.2 | 1354.6 |
| 200 | 381.8 | 1203.5 | 1227.6 | 1250.7 | 1273.1 | 1295.0 | 1316.2 | 1358.0 |
| 250 | 401.0 | 1207.0 | 1231.7 | 1255.7 | 1278.9 | 1301.2 | 1322.6 | 1364.9 |
| 300 | 417.4 | 1209.4 | 1235.0 | 1259.5 | 1283.2 | 1305.8 | 1327.6 | 1370.3 |
| 400 | 444.7 | 1212.1 | 1239.6 | 1265.4 | 1289.9 | 1313.3 | 1335.8 | 1379.6 |
| 500 | 467.1 | 1213.2 | 1242.2 | 1269.1 | 1294.7 | 1318.8 | 1341.9 | 1386.6 |

Entropy of superheated steam (Btu per °F per lb)

| <i>Abs. Pres.</i> <i>lb/in²</i> | <i>Sat. temp.</i> <i>°F</i> | <i>Degrees of Superheat °F</i> | | | | | | |
|---|--------------------------------|--------------------------------|-----------|-----------|------------|------------|------------|------------|
| | | <i>0</i> | <i>40</i> | <i>80</i> | <i>120</i> | <i>160</i> | <i>200</i> | <i>280</i> |
| 20 | 228 | 1.7333 | 1.7617 | 1.7883 | 1.8134 | 1.8372 | 1.8596 | 1.9017 |
| 30 | 250.3 | 1.7017 | 1.7298 | 1.7560 | 1.7807 | 1.8041 | 1.8261 | 1.8472 |
| 40 | 267.2 | 1.6793 | 1.7071 | 1.7331 | 1.7575 | 1.7806 | 1.8025 | 1.8233 |
| 50 | 280.9 | 1.6619 | 1.6895 | 1.7153 | 1.7397 | 1.7626 | 1.7843 | 1.8049 |
| 60 | 292.6 | 1.6477 | 1.6752 | 1.7010 | 1.7253 | 1.7480 | 1.7694 | 1.7899 |
| 70 | 302.8 | 1.6357 | 1.6632 | 1.6889 | 1.7130 | 1.7357 | 1.7570 | 1.7774 |
| 80 | 311.9 | 1.6254 | 1.6527 | 1.6784 | 1.7024 | 1.7251 | 1.7463 | 1.7665 |
| 90 | 320.2 | 1.6161 | 1.6436 | 1.6692 | 1.6931 | 1.7157 | 1.7367 | 1.7569 |
| 100 | 327.9 | 1.6079 | 1.6353 | 1.6608 | 1.6847 | 1.7073 | 1.7283 | 1.7484 |
| 120 | 341.3 | 1.5935 | 1.6210 | 1.6467 | 1.6705 | 1.6928 | 1.7138 | 1.7337 |
| 140 | 353.0 | 1.5813 | 1.6088 | 1.6345 | 1.6583 | 1.6805 | 1.7014 | 1.7212 |
| 160 | 363.6 | 1.5706 | 1.5983 | 1.6240 | 1.6479 | 1.6701 | 1.6909 | 1.7107 |
| 180 | 373.1 | 1.5610 | 1.5890 | 1.6148 | 1.6386 | 1.6607 | 1.6815 | 1.7013 |
| 200 | 381.8 | 1.5525 | 1.5806 | 1.6063 | 1.6301 | 1.6523 | 1.6730 | 1.6929 |
| 250 | 401.0 | 1.5342 | 1.5628 | 1.5886 | 1.6125 | 1.6347 | 1.6554 | 1.6751 |
| 300 | 417.4 | 1.5190 | 1.5479 | 1.5740 | 1.5980 | 1.6203 | 1.6410 | 1.6607 |
| 400 | 444.7 | 1.4941 | 1.5240 | 1.5506 | 1.5749 | 1.5973 | 1.6181 | 1.6379 |
| 500 | 467.1 | 1.4740 | 1.5049 | 1.5322 | 1.5568 | 1.5795 | 1.6004 | 1.6201 |

Properties of saturated steam

(Based on Callendar's Values)

| Abs. pres. p lb in ² | Temp. t °F | Specific volume v ft ³ /lb | Density w lb/ft ³ | Heat of | | | Entropy S Btu/lb °F |
|--|--------------------|--|--------------------------------------|-------------------------|------------------------|----------------------------|-----------------------------|
| | | | | Liquid h Btu/lb | Evap. L Btu/lb | Sat. vap. H Btu/lb | |
| 0.5 | 79.5 | 640.5 | 0.00156 | 47.4 | 1045 | 1092 | 2.0299 |
| 1 | 101.7 | 333.1 | 0.0030 | 69.5 | 1033 | 1102 | 1.9724 |
| 2 | 126.1 | 173.5 | 0.0058 | 93.9 | 1020 | 1114 | 1.9159 |
| 3 | 141.5 | 118.6 | 0.0085 | 109.3 | 1012 | 1121 | 1.8833 |
| 4 | 153.0 | 90.5 | 0.0111 | 120.8 | 1005 | 1126 | 1.8600 |
| 5 | 162.3 | 73.4 | 0.0136 | 130.1 | 1000 | 1130 | 1.8422 |
| 6 | 170.1 | 61.9 | 0.0162 | 137.9 | 995 | 1133 | 1.8277 |
| 7 | 176.9 | 53.6 | 0.0187 | 144.8 | 991 | 1136 | 1.8156 |
| 8 | 182.9 | 47.3 | 0.0212 | 150.8 | 988 | 1139 | 1.8049 |
| 9 | 188.3 | 42.4 | 0.0236 | 156.3 | 985 | 1141 | 1.7956 |
| 10 | 193.2 | 38.4 | 0.0261 | 161.1 | 982 | 1143 | 1.7874 |
| 12 | 202.0 | 32.4 | 0.0309 | 169.9 | 977 | 1147 | 1.7731 |
| 14 | 209.6 | 28.0 | 0.0357 | 177.6 | 972 | 1150 | 1.7611 |
| 14.7 | 212.0 | 26.8 | 0.0373 | 180.0 | 970 | 1151 | 1.7573 |
| 16 | 216.3 | 24.7 | 0.0404 | 184.4 | 968 | 1152.5 | 1.7506 |
| 18 | 222.4 | 22.2 | 0.0451 | 190.5 | 964 | 1155 | 1.7414 |
| 20 | 228.0 | 20.1 | 0.0498 | 196.1 | 961 | 1157 | 1.7333 |
| 22 | 233.1 | 18.37 | 0.0545 | 201.3 | 958 | 1159 | 1.7258 |
| 24 | 237.8 | 16.93 | 0.0591 | 206.1 | 955 | 1161 | 1.7189 |
| 26 | 242.2 | 15.71 | 0.0636 | 210.5 | 952 | 1162.5 | 1.7126 |
| 28 | 246.4 | 14.66 | 0.0682 | 214.8 | 949 | 1164 | 1.7069 |
| 30 | 250.3 | 13.72 | 0.0728 | 218.8 | 947 | 1165.5 | 1.7017 |
| 35 | 259.3 | 11.86 | 0.0843 | 228 | 941 | 1169 | 1.6898 |
| 40 | 267.2 | 10.48 | 0.0953 | 236 | 936 | 1172 | 1.6793 |
| 45 | 274.4 | 9.37 | 0.1067 | 243 | 931 | 1174 | 1.6701 |
| 50 | 281.0 | 8.50 | 0.1175 | 250 | 926 | 1176 | 1.6619 |
| 55 | 287.0 | 7.74 | 0.1292 | 256 | 922 | 1178 | 1.6547 |
| 60 | 292.6 | 7.16 | 0.1397 | 262 | 919 | 1180 | 1.6479 |
| 65 | 297.9 | 6.64 | 0.1506 | 267 | 914 | 1182 | 1.6415 |
| 70 | 303.0 | 6.20 | 0.1613 | 272 | 911 | 1183 | 1.6357 |
| 75 | 307.5 | 5.81 | 0.1721 | 277 | 907 | 1185 | 1.6304 |
| 80 | 312.0 | 5.47 | 0.1828 | 282 | 904 | 1186 | 1.6254 |
| 85 | 316.2 | 5.16 | 0.1938 | 286 | 901 | 1187 | 1.6206 |
| 90 | 320.2 | 4.89 | 0.2045 | 290 | 898 | 1189 | 1.6161 |
| 95 | 324.1 | 4.65 | 0.2150 | 295 | 895 | 1190 | 1.6120 |
| 100 | 327.9 | 4.43 | 0.2257 | 298 | 893 | 1191 | 1.6079 |
| 105 | 331.4 | 4.23 | 0.2364 | 302 | 890 | 1192 | 1.6041 |
| 110 | 334.8 | 4.04 | 0.2475 | 306 | 887 | 1193 | 1.6004 |
| 115 | 338.1 | 3.88 | 0.2577 | 309 | 884 | 1194 | 1.5969 |

Properties of saturated steam

| <i>Abs. pres.</i> <i>p</i> <i>lb in²</i> | <i>Temp.</i> <i>t</i> <i>°F</i> | <i>Specific volume</i> <i>v</i> <i>ft³/lb</i> | <i>Density</i> <i>w</i> <i>lb/ft³</i> | <i>Heat of</i> | | | <i>Entropy</i> <i>S</i> <i>Btu/lb °F</i> |
|---|---------------------------------------|--|--|--|---|---|--|
| | | | | <i>Liquid</i> <i>h</i> <i>Btu/lb</i> | <i>Evap.</i> <i>L</i> <i>Btu/lb</i> | <i>Sat. vap.</i> <i>H</i> <i>Btu/lb</i> | |
| 120 | 341.3 | 3.73 | 0.2681 | 312 | 882 | 1194 | 1.5935 |
| 125 | 344.4 | 3.59 | 0.2786 | 316 | 879 | 1195 | 1.5903 |
| 130 | 347.3 | 3.46 | 0.2890 | 319 | 877 | 1196 | 1.5872 |
| 135 | 350.2 | 3.33 | 0.3003 | 322 | 875 | 1197 | 1.5842 |
| 140 | 353.0 | 3.22 | 0.3106 | 325 | 872 | 1197 | 1.5813 |
| 145 | 355.8 | 3.12 | 0.3205 | 328 | 870 | 1198 | 1.5785 |
| 150 | 358.4 | 3.02 | 0.3311 | 331 | 868 | 1199 | 1.5758 |
| 160 | 363.6 | 2.84 | 0.3521 | 336 | 864 | 1200 | 1.5706 |
| 170 | 368.4 | 2.68 | 0.3731 | 341 | 860 | 1201 | 1.5657 |
| 180 | 373.1 | 2.54 | 0.3937 | 346 | 856 | 1202 | 1.5610 |
| 190 | 377.5 | 2.41 | 0.4149 | 351 | 852 | 1203 | 1.5567 |
| 200 | 382 | 2.29 | 0.4347 | 356 | 848 | 1203 | 1.5525 |
| 220 | 390 | 2.09 | 0.4785 | 364 | 841 | 1205 | 1.5448 |
| 240 | 387 | 1.93 | 0.5181 | 372 | 834 | 1206 | 1.5376 |
| 260 | 404.5 | 1.78 | 0.5618 | 380 | 827 | 1207.5 | 1.5310 |
| 280 | 411.1 | 1.66 | 0.6024 | 387 | 821 | 1208.5 | 1.5241 |
| 300 | 417.4 | 1.55 | 0.6452 | 394 | 815 | 1209.4 | 1.5190 |
| 350 | 431.8 | 1.34 | 0.7463 | 410 | 801 | 1211.1 | 1.5058 |
| 400 | 444.7 | 1.17 | 0.8547 | 425 | 787.5 | 1212.1 | 1.4941 |
| 450 | 456.4 | 1.04 | 0.9615 | 437.8 | 775 | 1212.8 | 1.4836 |
| 500 | 467.1 | 0.94 | 1.0638 | 450.1 | 763.1 | 1213.2 | 1.4740 |

Specific enthalpy of superheated steam (kJ/kg)

| Absolute pressure kN/m^2 | Sat. temp. $^{\circ}C$ | Steam temperature $^{\circ}C$ | | | | | | |
|-------------------------------|---------------------------|-------------------------------|------|------|------|------|------|------|
| | | 120 | 150 | 180 | 200 | 230 | 250 | 280 |
| 150 | 114.4 | 2711 | 2772 | 2832 | 2872 | 2932 | 2972 | 3033 |
| 200 | 120.2 | — | 2769 | 2830 | 2870 | 2931 | 2971 | 3031 |
| 250 | 127.4 | — | 2765 | 2827 | 2868 | 2929 | 2969 | 3030 |
| 350 | 138.9 | — | 2756 | 2821 | 2863 | 2925 | 2966 | 3028 |
| 400 | 143.6 | — | 2752 | 2818 | 2860 | 2923 | 2964 | 3026 |
| 500 | 151.8 | — | — | 2811 | 2855 | 2919 | 2961 | 3023 |
| 600 | 158.8 | — | — | 2805 | 2850 | 2915 | 2958 | 3021 |
| 700 | 165.0 | — | — | 2798 | 2844 | 2911 | 2954 | 3018 |
| 800 | 170.4 | — | — | 2791 | 2839 | 2907 | 2950 | 3015 |
| 900 | 175.4 | — | — | 2784 | 2833 | 2902 | 2947 | 3012 |
| 1000 | 179.9 | — | — | 2777 | 2827 | 2898 | 2943 | 3009 |
| 1100 | 184.1 | — | — | — | 2821 | 2893 | 2939 | 3006 |
| 1200 | 188.0 | — | — | — | 2814 | 2889 | 2935 | 3003 |
| 1400 | 195.0 | — | — | — | 2801 | 2879 | 2928 | 2997 |
| 1600 | 201.4 | — | — | — | — | 2869 | 2919 | 2991 |
| 2000 | 212.4 | — | — | — | — | 2848 | 2902 | 2978 |
| 2500 | 223.9 | — | — | — | — | 2820 | 2880 | 2960 |
| 3500 | 242.5 | — | — | — | — | — | 2828 | 2922 |

Specific entropy of superheated steam (kJ/kg K)

| Absolute pressure kN/m^2 | Sat. temp. $^{\circ}C$ | Steam temperature $^{\circ}C$ | | | | | | |
|-------------------------------|---------------------------|-------------------------------|-------|-------|-------|-------|-------|-------|
| | | 120 | 150 | 180 | 200 | 230 | 250 | 280 |
| 150 | 111.4 | 7.269 | 7.419 | 7.557 | 7.664 | 7.767 | 7.845 | 7.957 |
| 200 | 120.2 | — | 7.279 | 7.420 | 7.507 | 7.631 | 7.710 | 7.822 |
| 250 | 127.4 | — | 7.169 | 7.311 | 7.400 | 7.525 | 7.604 | 7.717 |
| 350 | 138.9 | — | 6.998 | 7.146 | 7.237 | 7.364 | 7.444 | 7.558 |
| 400 | 143.6 | — | 6.929 | 7.079 | 7.171 | 7.299 | 7.380 | 7.495 |
| 500 | 151.8 | — | — | 6.965 | 7.059 | 7.190 | 7.272 | 7.388 |
| 600 | 158.8 | — | — | 6.869 | 6.966 | 7.100 | 7.183 | 7.300 |
| 700 | 165.0 | — | — | 6.786 | 6.886 | 7.022 | 7.107 | 7.225 |
| 800 | 170.4 | — | — | 6.712 | 6.815 | 6.954 | 7.040 | 7.156 |
| 900 | 175.4 | — | — | 6.645 | 6.751 | 6.893 | 6.980 | 7.101 |
| 1000 | 179.9 | — | — | 6.584 | 6.692 | 6.838 | 6.926 | 7.049 |
| 1100 | 184.1 | — | — | — | 6.638 | 6.787 | 6.876 | 7.001 |
| 1200 | 188.0 | — | — | — | 6.587 | 6.739 | 6.831 | 6.956 |
| 1400 | 195.0 | — | — | — | 6.494 | 6.653 | 6.748 | 6.877 |
| 1600 | 201.4 | — | — | — | — | 6.577 | 6.674 | 6.806 |
| 2000 | 212.4 | — | — | — | — | 6.440 | 6.546 | 6.685 |
| 2500 | 223.9 | — | — | — | — | 6.292 | 6.407 | 6.558 |
| 3500 | 242.5 | — | — | — | — | — | 6.173 | 6.349 |

Properties of saturated steam

| Absolute pressure kN/m^2 | Temp. $^{\circ}C$ | Specific volume m^3/kg | Density kg/m^3 | Specific enthalpy of | | | Specific entropy of steam $kJ/kg K$ |
|-------------------------------|----------------------|-----------------------------|---------------------|----------------------|------------------------|------------------|--|
| | | | | Liquid kJ/kg | Evaporation kJ/kg | Steam kJ/kg | |
| 0.8 | 3.8 | 160 | 0.00626 | 15.8 | 2493 | 2509 | 9.058 |
| 2.0 | 17.5 | 67.0 | 0.0149 | 73.5 | 2460 | 2534 | 8.725 |
| 5.0 | 32.9 | 28.2 | 0.0354 | 137.8 | 2424 | 2562 | 8.396 |
| 10.0 | 45.8 | 14.7 | 0.0682 | 191.8 | 2393 | 2585 | 8.151 |
| 20.0 | 60.1 | 7.65 | 0.131 | 251.5 | 2358 | 2610 | 7.909 |
| 28 | 67.5 | 5.58 | 0.179 | 282.7 | 2340 | 2623 | 7.793 |
| 35 | 72.7 | 4.53 | 0.221 | 304.3 | 2327 | 2632 | 7.717 |
| 45 | 78.7 | 3.58 | 0.279 | 329.6 | 2312 | 2642 | 7.631 |
| 55 | 83.7 | 2.96 | 0.338 | 350.6 | 2299 | 2650 | 7.562 |
| 65 | 88.0 | 2.53 | 0.395 | 368.6 | 2288 | 2657 | 7.506 |
| 75 | 91.8 | 2.22 | 0.450 | 384.5 | 2279 | 2663 | 7.457 |
| 85 | 95.2 | 1.97 | 0.507 | 398.6 | 2270 | 2668 | 7.415 |
| 95 | 98.2 | 1.78 | 0.563 | 411.5 | 2262 | 2673 | 7.377 |
| 100 | 99.6 | 1.69 | 0.590 | 417.5 | 2258 | 2675 | 7.360 |
| 101.33 | 100 | 1.67 | 0.598 | 419.1 | 2257 | 2676 | 7.355 |
| 110 | 102.3 | 1.55 | 0.646 | 428.8 | 2251 | 2680 | 7.328 |
| 130 | 107.1 | 1.33 | 0.755 | 449.2 | 2238 | 2687 | 7.271 |
| 150 | 111.4 | 1.16 | 0.863 | 467.1 | 2226 | 2693 | 7.223 |
| 170 | 115.2 | 1.03 | 0.970 | 483.2 | 2216 | 2699 | 7.181 |
| 190 | 118.6 | 0.929 | 1.08 | 497.8 | 2206 | 2704 | 7.144 |
| 220 | 123.3 | 0.810 | 1.23 | 517.6 | 2193 | 2711 | 7.095 |
| 260 | 128.7 | 0.693 | 1.44 | 540.9 | 2177 | 2718 | 7.039 |
| 280 | 131.2 | 0.646 | 1.55 | 551.4 | 2170 | 2722 | 7.014 |
| 320 | 135.8 | 0.570 | 1.75 | 570.9 | 2157 | 2728 | 6.969 |
| 360 | 139.9 | 0.510 | 1.96 | 588.5 | 2144 | 2733 | 6.930 |
| 400 | 143.6 | 0.462 | 2.16 | 604.7 | 2133 | 2738 | 6.894 |
| 440 | 147.1 | 0.423 | 2.36 | 619.6 | 2122 | 2742 | 6.862 |
| 480 | 150.3 | 0.389 | 2.57 | 633.5 | 2112 | 2746 | 6.833 |
| 500 | 151.8 | 0.375 | 2.67 | 640.1 | 2107 | 2748 | 6.819 |
| 550 | 155.5 | 0.342 | 2.92 | 655.8 | 2096 | 2752 | 6.787 |
| 600 | 158.8 | 0.315 | 3.175 | 670.4 | 2085 | 2756 | 6.758 |
| 650 | 162.0 | 0.292 | 3.425 | 684.1 | 2075 | 2759 | 6.730 |
| 700 | 165.0 | 0.273 | 3.66 | 697.1 | 2065 | 2762 | 6.705 |
| 750 | 167.8 | 0.255 | 3.915 | 709.3 | 2056 | 2765 | 6.682 |
| 800 | 170.4 | 0.240 | 4.16 | 720.9 | 2047 | 2768 | 6.660 |
| 850 | 172.9 | 0.229 | 4.41 | 732.0 | 2038 | 2770 | 6.639 |
| 900 | 175.4 | 0.215 | 4.65 | 742.6 | 2030 | 2772 | 6.619 |
| 950 | 177.7 | 0.204 | 4.90 | 752.8 | 2021 | 2774 | 6.601 |
| 1000 | 179.9 | 0.194 | 5.15 | 762.6 | 2014 | 2776 | 6.583 |

Properties of saturated steam (continued)

| Absolute pressure kN/m^2 | Temp. $^{\circ}C$ | Specific volume m^3/kg | Density kg/m^3 | Specific enthalpy of | | | Specific entropy of steam $kJ/kg K$ |
|----------------------------------|----------------------|--------------------------------|---------------------|----------------------|------------------------|------------------|--|
| | | | | Liquid kJ/kg | Evaporation kJ/kg | Steam kJ/kg | |
| 1050 | 182.0 | 0.186 | 5.39 | 772 | 2006 | 2778 | 6.566 |
| 1150 | 186.0 | 0.170 | 5.89 | 790 | 1991 | 2781 | 6.534 |
| 1250 | 189.8 | 0.157 | 6.38 | 807 | 1977 | 2784 | 6.505 |
| 1300 | 191.6 | 0.151 | 6.62 | 815 | 1971 | 2785 | 6.491 |
| 1500 | 198.3 | 0.132 | 7.59 | 845 | 1945 | 2790 | 6.441 |
| 1600 | 201.4 | 0.124 | 8.03 | 859 | 1933 | 2792 | 6.418 |
| 1800 | 207.1 | 0.110 | 9.07 | 885 | 1910 | 2795 | 6.375 |
| 2000 | 212.4 | 0.0995 | 10.01 | 909 | 1889 | 2797 | 6.337 |
| 2100 | 214.9 | 0.0949 | 10.54 | 920 | 1878 | 2798 | 6.319 |
| 2300 | 219.6 | 0.0868 | 11.52 | 942 | 1858 | 2800 | 6.285 |
| 2400 | 221.8 | 0.0832 | 12.02 | 952 | 1849 | 2800 | 6.269 |
| 2600 | 226.0 | 0.0769 | 13.01 | 972 | 1830 | 2801 | 6.239 |
| 2700 | 228.1 | 0.0740 | 13.52 | 981 | 1821 | 2802 | 6.224 |
| 2900 | 232.0 | 0.0689 | 14.52 | 1000 | 1803 | 2802 | 6.197 |
| 3000 | 233.8 | 0.0666 | 15.00 | 1008 | 1794 | 2802 | 6.184 |
| 3200 | 237.4 | 0.0624 | 16.02 | 1025 | 1779 | 2802 | 6.158 |
| 3400 | 240.9 | 0.0587 | 17.04 | 1042 | 1760 | 2802 | 6.134 |
| 3600 | 244.2 | 0.0554 | 18.06 | 1058 | 1744 | 2802 | 6.112 |
| 3800 | 247.3 | 0.0524 | 19.08 | 1073 | 1728 | 2801 | 6.090 |
| 4000 | 250.3 | 0.0497 | 21.0 | 1087 | 1713 | 2800 | 6.069 |

Taken by permission of Cambridge University Press from *Thermodynamic Tables in S.I. (metric) Units* by Haywood.

Properties of air

Symbols

| | | |
|----------|---|--------------------|
| V | volume of air-vapour mixture | m^3 |
| m | mass of air-vapour mixture | kg |
| p_a | partial pressure of dry air | N/m^2 |
| p_{wa} | actual partial pressure of water vapour | N/m^2 |
| p_{ws} | saturation pressure of water vapour | N/m^2 |
| p_t | total pressure of mixture | N/m^2 |
| t | dry bulb temperature | $^{\circ}\text{C}$ |
| T | absolute dry bulb temperature = $273+t$ | K |
| ϕ | relative humidity | per cent |
| X | specific humidity of air-vapour mixture | g/kg |
| X_s | specific humidity of saturated air | g/kg |
| ρ_a | density of dry air | kg/m^3 |
| ρ_w | density of water vapour | kg/m^3 |
| ρ | density of air-vapour mixture | kg/m^3 |
| R | gas constant | J/kg K |
| | = 286 for air | |
| | = 455 for water vapour | |

Atmospheric air is a mixture of dry air and water vapour. It can be treated as an ideal gas without great discrepancies and the gas laws can be applied to it.

General Gas Law

$$pV = mRT$$

$$\rho = \frac{m}{V} = \frac{p}{RT}$$

Density of Dry Air

$$\rho_a = 0.00350 \frac{p_a}{T}$$

Density of Water Vapour

$$\rho_w = 0.00220 \frac{p_w}{T}$$

Density of Air-Water Vapour Mixture

$$\rho = 0.00350 \frac{p_t}{T} - 0.00133 \frac{p_{ws} \phi}{100T}$$

Air-water vapour mixture is always lighter than dry air.

Humidity is the term applied to the quantity of water vapour present in the air.

Absolute Humidity is the actual mass of water vapour present, expressed in grams water vapour per kilogram mixture.

Specific Humidity is the actual mass of water vapour present, expressed in grams water vapour per kilogram dry air.

$$X = \frac{622\phi\rho_{ws}}{(\rho - \rho_{ws})100} \text{ g/kg}$$

Specific Humidity of Saturated Air

$$X_s = \frac{622\rho_{ws}}{\rho - \rho_{ws}} \text{ g/kg}$$

Relative Humidity is

either ratio of actual partial pressure of water vapour to vapour pressure at saturation at actual dry bulb temperature.

or ratio of actual vapour density to vapour density at saturation at actual dry bulb temperature.

or ratio of actual mass of water vapour in given air volume to mass of water vapour required to saturate this volume.

It is usually expressed in %

$$\phi = \frac{p_{wa}}{p_{ws}} \times 100 = \frac{\rho_w}{\rho_{ws}} \times 100 = \frac{X}{X_s} \times 100\%$$

Saturated Air holds the maximum mass of water vapour at the given temperature. Any lowering of the air temperature will cause condensation of water vapour.

Dry Bulb Temperature is the air temperature as indicated by a thermometer which is not affected by the moisture of the air.

Wet Bulb Temperature is the temperature of adiabatic saturation. It is the temperature indicated by a moistened thermometer bulb exposed to a current of air.

Dew Point Temperature is the temperature to which air with a given moisture content must be cooled to produce saturation of the air and the commencement of condensation of the vapour in the air.

Specific Enthalpy of dry air

$$H = 1.01t \text{ kJ/kg}$$

Specific Enthalpy of air-water vapour mixture is composed of the sensible heat of the air and the latent heat of vaporisation of the water vapour present in the air and the sensible heat of the vapour.

$$H = 1.01t + X(2463 + 1.88t) \text{ kJ/kg}$$

1.01 is the specific heat capacity of dry air.

2463 is the latent heat of vaporisation of water at 0°C.

1.88 is the specific heat capacity of water vapour at constant pressure.

Thermal expansion of air

Dry air expands or contracts uniformly 1/886 of its volume per °C under constant pressure.

Humidity Chart for Air (Psychrometric Chart)

See Chart No. 5. The chart shows the relationship between

- 1 Dry bulb temperature.
- 2 Wet bulb temperature.
- 3 Dew point.
- 4 Relative humidity.
- 5 Moisture content.
- 6 Specific volume.
- 7 Specific enthalpy.

When any two of these are given the other five can be read from the chart. The chart contains the following lines

- (i) Lines of constant temperature.
- (ii) Lines of constant specific enthalpy.
- (iii) Lines of constant wet bulb temperature.
- (iv) Lines of constant relative humidity.
- (v) Lines of constant dewpoint, which are also lines of constant moisture content.
- (vi) Lines of constant specific volume.



Specific Heat Capacity of dry air

$$\begin{aligned} s &= 1.01 \text{ kJ/kg K} \\ &= 1.23 \text{ kJ/m}^3 \text{ K at standard density} \end{aligned}$$

Viscosity of air

$$= 0.018 \times 10^{-3} \text{ N s/m}^2$$

Air condition



LINES OF CONSTANT ENTHALPY ARE NOT QUITE PARALLEL TO WET BULB LINES
 DP DEW POINT
 WB WET BULB TEMPERATURE
 DB DRY BULB TEMPERATURE

| Change of condition of air | Indicated in sketch above | Remarks |
|--|---------------------------|---|
| Mixing of air volume V_A at condition A with air volume V_B at condition B | A-C B-C | $\frac{\text{Distance AC}}{\text{Distance BC}} = \frac{\text{Volume } V_B}{\text{Volume } V_A}$ |
| Heating | A-D | Dewpoint at F |
| Cooling | A-E-F | |
| Humidification with water injection | A-G | Slope depends on temperature of water but is approximately equal to slope of wet bulb line |
| Humidification with steam injection | A-H | Temperature increases slightly but for practical purposes can be assumed to be constant |
| Constant temperature Cooling with dehumidification | A-J A-K | Coil dewpoint L Coil contact factor = $\frac{DB_A - DB_k}{DB_A - DB_L}$ |

Relative humidity in per cent

For various room temperatures and various differences between wet and dry bulb temperatures

| <i>Dry bulb temp.</i> °C | <i>Difference between dry bulb and wet bulb temperatures (°C)</i> | | | | | | | | | | | |
|-----------------------------|---|----|----|----|----|----|----|----|----|----|----|----|
| | 0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 |
| 10 | 100 | 88 | 77 | 66 | 55 | 44 | 34 | 25 | 15 | 6 | 0 | 0 |
| 11 | 100 | 89 | 78 | 67 | 56 | 46 | 36 | 27 | 18 | 9 | 2 | 0 |
| 12 | 100 | 89 | 78 | 68 | 58 | 48 | 39 | 29 | 21 | 12 | 3 | 0 |
| 13 | 100 | 90 | 79 | 69 | 60 | 50 | 41 | 32 | 34 | 15 | 6 | 1 |
| 14 | 100 | 90 | 80 | 70 | 61 | 52 | 43 | 34 | 26 | 17 | 8 | 2 |
| 15 | 100 | 90 | 81 | 71 | 62 | 53 | 44 | 36 | 28 | 20 | 11 | 5 |
| 16 | 100 | 90 | 81 | 71 | 63 | 54 | 46 | 37 | 30 | 22 | 14 | 8 |
| 17 | 100 | 91 | 82 | 72 | 64 | 56 | 48 | 39 | 32 | 25 | 17 | 11 |
| 18 | 100 | 91 | 82 | 73 | 65 | 57 | 49 | 41 | 34 | 27 | 20 | 13 |
| 19 | 100 | 91 | 83 | 74 | 66 | 59 | 51 | 43 | 36 | 29 | 23 | 16 |
| 20 | 100 | 91 | 83 | 74 | 67 | 59 | 52 | 44 | 38 | 31 | 25 | 18 |
| 21 | 100 | 92 | 83 | 75 | 68 | 61 | 53 | 46 | 40 | 33 | 27 | 20 |
| 22 | 100 | 92 | 83 | 75 | 68 | 61 | 54 | 47 | 41 | 34 | 28 | 22 |
| 23 | 100 | 92 | 84 | 76 | 69 | 62 | 55 | 48 | 42 | 36 | 30 | 24 |
| 24 | 100 | 92 | 84 | 76 | 70 | 63 | 56 | 49 | 43 | 37 | 31 | 26 |
| 25 | 100 | 92 | 85 | 77 | 71 | 64 | 57 | 51 | 45 | 39 | 33 | 28 |
| 26 | 100 | 92 | 85 | 77 | 71 | 64 | 58 | 52 | 46 | 40 | 34 | 29 |
| 27 | 100 | 93 | 85 | 78 | 72 | 65 | 59 | 53 | 47 | 42 | 36 | 31 |
| 28 | 100 | 93 | 85 | 78 | 72 | 66 | 59 | 54 | 48 | 43 | 37 | 32 |
| 29 | 100 | 93 | 86 | 79 | 73 | 67 | 60 | 55 | 49 | 44 | 39 | 34 |
| 30 | 100 | 93 | 86 | 79 | 73 | 67 | 61 | 56 | 50 | 45 | 40 | 35 |
| 31 | 100 | 93 | 86 | 80 | 74 | 68 | 62 | 57 | 51 | 46 | 41 | 36 |
| 32 | 100 | 93 | 86 | 80 | 74 | 68 | 63 | 57 | 52 | 47 | 42 | 37 |
| 33 | 100 | 93 | 87 | 81 | 75 | 69 | 64 | 58 | 53 | 48 | 43 | 38 |
| 34 | 100 | 93 | 87 | 81 | 75 | 69 | 64 | 59 | 53 | 49 | 44 | 39 |
| 35 | 100 | 94 | 87 | 82 | 76 | 70 | 65 | 60 | 54 | 50 | 45 | 40 |
| 36 | 100 | 94 | 87 | 82 | 76 | 70 | 65 | 60 | 55 | 50 | 46 | 41 |
| 37 | 100 | 94 | 88 | 82 | 76 | 71 | 66 | 61 | 56 | 51 | 47 | 42 |
| 38 | 100 | 94 | 88 | 82 | 76 | 71 | 66 | 61 | 56 | 52 | 47 | 43 |

Relative humidity in per cent

For various room temperatures and various differences between wet and dry bulb temperatures

| Dry bulb temp. (°F) | Difference between dry bulb and wet bulb temperature (°F) | | | | | | | | | | |
|---------------------------|---|----|----|----|----|----|----|----|----|----|----|
| | 0 | 2 | 4 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 |
| 50 | 100 | 87 | 74 | 62 | 50 | 39 | 28 | 17 | 7 | 0 | 0 |
| 52 | 100 | 88 | 75 | 63 | 52 | 41 | 30 | 20 | 10 | 0 | 0 |
| 54 | 100 | 88 | 76 | 65 | 54 | 43 | 33 | 23 | 14 | 5 | 0 |
| 56 | 100 | 88 | 77 | 66 | 55 | 45 | 35 | 26 | 17 | 8 | 0 |
| 58 | 100 | 88 | 77 | 67 | 57 | 47 | 38 | 28 | 20 | 11 | 3 |
| 60 | 100 | 89 | 78 | 68 | 58 | 49 | 40 | 31 | 22 | 14 | 6 |
| 62 | 100 | 89 | 79 | 69 | 60 | 50 | 41 | 33 | 25 | 17 | 9 |
| 64 | 100 | 90 | 79 | 70 | 61 | 52 | 43 | 35 | 27 | 20 | 12 |
| 66 | 100 | 90 | 80 | 71 | 62 | 53 | 45 | 37 | 29 | 22 | 15 |
| 68 | 100 | 90 | 81 | 72 | 63 | 55 | 47 | 39 | 31 | 24 | 17 |
| 70 | 100 | 90 | 81 | 72 | 64 | 56 | 48 | 40 | 33 | 26 | 20 |
| 72 | 100 | 91 | 82 | 73 | 65 | 57 | 49 | 42 | 35 | 28 | 22 |
| 74 | 100 | 91 | 82 | 74 | 66 | 58 | 51 | 44 | 37 | 30 | 24 |
| 76 | 100 | 91 | 83 | 74 | 67 | 59 | 52 | 45 | 38 | 32 | 26 |
| 78 | 100 | 91 | 83 | 75 | 67 | 60 | 53 | 46 | 40 | 34 | 28 |
| 80 | 100 | 91 | 83 | 76 | 68 | 61 | 54 | 47 | 41 | 35 | 29 |
| 82 | 100 | 92 | 84 | 76 | 69 | 62 | 55 | 49 | 43 | 37 | 31 |
| 84 | 100 | 92 | 84 | 77 | 70 | 63 | 56 | 50 | 44 | 38 | 32 |
| 86 | 100 | 92 | 85 | 77 | 70 | 63 | 57 | 51 | 45 | 39 | 34 |
| 88 | 100 | 92 | 85 | 78 | 71 | 64 | 58 | 52 | 46 | 41 | 35 |
| 90 | 100 | 92 | 85 | 78 | 71 | 65 | 59 | 53 | 47 | 42 | 37 |
| 92 | 100 | 92 | 85 | 78 | 72 | 65 | 59 | 54 | 48 | 43 | 38 |
| 94 | 100 | 93 | 86 | 79 | 72 | 66 | 60 | 54 | 49 | 44 | 39 |
| 96 | 100 | 93 | 86 | 79 | 73 | 67 | 61 | 55 | 50 | 45 | 40 |
| 98 | 100 | 93 | 86 | 79 | 73 | 67 | 61 | 56 | 51 | 46 | 41 |
| 100 | 100 | 93 | 86 | 80 | 74 | 68 | 62 | 57 | 52 | 47 | 42 |

Mixture of air and saturated water vapour

| <i>Temp.</i> °C | <i>Pressure of</i> <i>sat. vapour</i> kN/m ³ | <i>Mass of sat. vapour</i> | | <i>Vol. of vapour</i> | | <i>Specific</i> <i>entropy of</i> <i>sat. vapour</i> kJ/kg |
|--------------------|---|--|--|---|---|---|
| | | <i>per m</i> ³ <i>of mixture</i> g/m ³ | <i>per kg of</i> <i>dry air</i> g/kg | <i>of dry</i> <i>air</i> m ³ /kg | <i>of mixture</i> m ³ /kg | |
| -15 | 0.160 | 1.6 | 1.0 | 0.731 | 0.732 | -12.6 |
| -10 | 0.266 | 2.3 | 1.6 | 0.745 | 0.746 | -6.1 |
| -5 | 0.399 | 3.4 | 2.5 | 0.759 | 0.761 | +1.09 |
| 0 | 0.612 | 4.9 | 3.8 | 0.773 | 0.775 | 9.4 |
| 1 | 0.652 | 5.2 | 4.1 | 0.776 | 0.778 | 11.3 |
| 2 | 0.705 | 5.6 | 4.4 | 0.779 | 0.781 | 12.9 |
| 3 | 0.758 | 6.0 | 4.7 | 0.782 | 0.784 | 14.7 |
| 4 | 0.811 | 6.4 | 5.0 | 0.784 | 0.787 | 16.6 |
| 5 | 0.865 | 6.8 | 5.4 | 0.787 | 0.790 | 18.5 |
| 6 | 0.931 | 7.3 | 5.8 | 0.791 | 0.793 | 20.5 |
| 7 | 0.998 | 7.7 | 6.2 | 0.793 | 0.796 | 22.6 |
| 8 | 1.06 | 8.3 | 6.7 | 0.796 | 0.800 | 24.7 |
| 9 | 1.14 | 8.8 | 7.1 | 0.799 | 0.802 | 26.9 |
| 10 | 1.22 | 9.4 | 7.6 | 0.801 | 0.805 | 29.2 |
| 11 | 1.30 | 10 | 8.2 | 0.805 | 0.808 | 31.5 |
| 12 | 1.40 | 11 | 8.8 | 0.807 | 0.812 | 34.1 |
| 13 | 1.49 | 11 | 9.4 | 0.810 | 0.814 | 36.6 |
| 14 | 1.60 | 12 | 10.0 | 0.813 | 0.818 | 39.2 |
| 15 | 1.70 | 13 | 10.6 | 0.816 | 0.821 | 41.8 |
| 16 | 1.81 | 14 | 11.4 | 0.818 | 0.824 | 44.8 |
| 17 | 1.93 | 14 | 12.1 | 0.822 | 0.828 | 47.7 |
| 18 | 2.06 | 15 | 12.9 | 0.824 | 0.831 | 50.7 |
| 19 | 2.19 | 16 | 13.8 | 0.827 | 0.833 | 54.0 |
| 20 | 2.33 | 17 | 14.7 | 0.830 | 0.837 | 57.8 |
| 21 | 2.49 | 18 | 15.6 | 0.833 | 0.840 | 61.1 |
| 22 | 2.63 | 19 | 16.6 | 0.835 | 0.844 | 64.1 |
| 23 | 2.81 | 20 | 17.7 | 0.838 | 0.847 | 67.8 |
| 24 | 2.98 | 22 | 18.8 | 0.841 | 0.850 | 72.0 |
| 25 | 3.17 | 23 | 20.0 | 0.844 | 0.854 | 75.8 |
| 26 | 3.35 | 24 | 21.4 | 0.847 | 0.858 | 80.4 |
| 27 | 3.55 | 26 | 22.6 | 0.850 | 0.861 | 84.6 |
| 28 | 3.78 | 27 | 24.0 | 0.853 | 0.865 | 89.2 |
| 29 | 3.99 | 29 | 25.6 | 0.855 | 0.869 | 94.3 |
| 30 | 4.23 | 30 | 27.2 | 0.858 | 0.873 | 99.6 |
| 35 | 5.61 | 39 | 36.6 | 0.873 | 0.892 | 129 |
| 40 | 7.35 | 51 | 48.8 | 0.887 | 0.912 | 166 |
| 45 | 9.56 | 65 | 65.0 | 0.901 | 0.935 | 213 |
| 50 | 12.3 | 82 | 86.2 | 0.915 | 0.959 | 273 |
| 55 | 15.7 | 104 | 114 | 0.929 | 0.987 | 352 |
| 60 | 19.9 | 130 | 152 | 0.943 | 1.020 | 456 |
| 65 | 24.9 | 161 | 204 | 0.958 | 1.057 | 599 |

Mixture of air and saturated water vapour

| Temp °F | Press. of sat. vapour in Hg | Weight of sat. vapour | | Volume in ft ³ | | Enthalpy of mixture Btu/lb |
|------------|-----------------------------------|-------------------------------|---|---------------------------|--|-------------------------------------|
| | | Grains per ft ³ | per lb of dry air. Grains per lb | of 1 lb of dry air | of 1 lb of dry air & vapour to saturate | |
| 0 | 0.0375 | 0.472 | 5.47 | 11.58 | 11.59 | 0.852 |
| 10 | 0.00628 | 0.772 | 9.16 | 11.83 | 11.58 | 3.831 |
| 20 | 0.01027 | 1.238 | 15.01 | 12.09 | 12.13 | 7.137 |
| 30 | 0.1646 | 1.943 | 24.11 | 12.34 | 12.41 | 10.933 |
| 32 | 0.1806 | 2.124 | 26.47 | 12.39 | 12.47 | 11.83 |
| 33 | 0.1880 | 2.206 | 27.57 | 12.41 | 12.49 | 12.18 |
| 34 | 0.1957 | 2.292 | 28.70 | 12.44 | 12.52 | 12.60 |
| 35 | 0.2036 | 2.380 | 29.88 | 12.47 | 12.55 | 13.02 |
| 36 | 0.2119 | 2.471 | 31.09 | 12.49 | 12.58 | 13.44 |
| 37 | 0.2204 | 2.566 | 32.35 | 12.52 | 12.61 | 13.87 |
| 38 | 0.2292 | 2.663 | 33.66 | 12.54 | 12.64 | 14.31 |
| 39 | 0.2384 | 2.764 | 35.01 | 12.57 | 12.67 | 14.76 |
| 40 | 0.2478 | 2.868 | 36.41 | 12.59 | 12.70 | 15.21 |
| 41 | 0.2576 | 2.976 | 37.87 | 12.62 | 12.73 | 15.67 |
| 42 | 0.2678 | 3.087 | 39.38 | 12.64 | 12.76 | 16.14 |
| 43 | 0.2783 | 3.201 | 40.93 | 12.67 | 12.79 | 16.62 |
| 44 | 0.2897 | 3.319 | 42.55 | 12.69 | 12.82 | 17.10 |
| 45 | 0.3003 | 3.442 | 44.21 | 12.72 | 12.85 | 17.59 |
| 46 | 0.3120 | 3.568 | 45.94 | 12.74 | 12.88 | 18.09 |
| 47 | 0.3240 | 3.698 | 47.73 | 12.77 | 12.91 | 18.60 |
| 48 | 0.3364 | 3.832 | 49.58 | 12.79 | 12.94 | 19.12 |
| 49 | 0.3492 | 3.970 | 51.49 | 12.82 | 12.97 | 19.65 |
| 50 | 0.3624 | 4.113 | 53.47 | 12.84 | 13.00 | 20.19 |
| 51 | 0.3761 | 4.260 | 55.52 | 12.87 | 13.03 | 20.74 |
| 52 | 0.3903 | 4.411 | 57.64 | 12.89 | 13.07 | 21.30 |
| 53 | 0.4049 | 4.568 | 59.83 | 12.92 | 13.10 | 21.87 |
| 54 | 0.4200 | 4.729 | 62.09 | 12.95 | 13.13 | 22.45 |
| 55 | 0.4356 | 4.895 | 64.43 | 12.97 | 13.16 | 23.04 |
| 56 | 0.4517 | 5.066 | 66.85 | 13.00 | 13.20 | 23.64 |
| 57 | 0.4684 | 5.242 | 69.35 | 13.02 | 13.23 | 24.25 |
| 58 | 0.4855 | 5.424 | 71.93 | 13.05 | 13.26 | 24.88 |
| 59 | 0.5032 | 5.611 | 74.60 | 13.07 | 13.30 | 25.52 |
| 60 | 0.5214 | 5.804 | 77.30 | 13.10 | 13.33 | 26.18 |

Mixture of air and saturated water vapour (continued)

| <i>Temp</i> °F | <i>Pressure of</i> <i>sat. vapour</i> <i>in Hg</i> | <i>Weight of sat. vapour</i> | | <i>Volume in ft³</i> | | <i>Enthalpy</i> <i>of mixture</i> <i>Btu/lb</i> |
|-------------------|--|--|---|---|--|---|
| | | <i>Grains</i> <i>per ft³</i> | <i>per lb of</i> <i>dry air.</i> <i>Grains</i> <i>per lb</i> | <i>of 1 lb</i> <i>of dry</i> <i>air</i> | <i>of 1 lb of</i> <i>dry air &</i> <i>vapour to</i> <i>saturate</i> | |
| 61 | 0.5403 | 6.003 | 80.2 | 13.12 | 13.36 | 26.84 |
| 62 | 0.5597 | 6.208 | 83.2 | 13.15 | 13.40 | 27.52 |
| 63 | 0.5798 | 6.418 | 86.2 | 13.17 | 13.43 | 28.22 |
| 64 | 0.6005 | 6.633 | 89.3 | 13.20 | 13.47 | 28.93 |
| 65 | 0.6218 | 6.855 | 92.6 | 13.22 | 13.50 | 29.65 |
| 66 | 0.6438 | 7.084 | 95.9 | 13.25 | 13.54 | 30.39 |
| 67 | 0.6664 | 7.320 | 99.4 | 13.27 | 13.58 | 31.15 |
| 68 | 0.6898 | 7.563 | 103.0 | 13.30 | 13.61 | 31.92 |
| 69 | 0.7139 | 7.813 | 106.6 | 13.32 | 13.65 | 32.71 |
| 70 | 0.7386 | 8.069 | 110.5 | 13.35 | 13.69 | 33.51 |
| 71 | 0.7642 | 8.332 | 114.4 | 13.38 | 13.73 | 34.33 |
| 72 | 0.7906 | 8.603 | 118.4 | 13.40 | 13.76 | 35.17 |
| 73 | 0.8177 | 8.882 | 122.6 | 13.43 | 13.80 | 36.03 |
| 74 | 0.8456 | 9.168 | 126.9 | 13.45 | 13.84 | 36.91 |
| 75 | 0.8744 | 9.46 | 131.4 | 13.48 | 13.88 | 37.81 |
| 76 | 0.9040 | 9.76 | 135.9 | 13.50 | 13.92 | 38.73 |
| 77 | 0.9345 | 10.07 | 140.7 | 13.53 | 13.96 | 39.67 |
| 78 | 0.9658 | 10.39 | 145.6 | 13.55 | 14.00 | 40.64 |
| 79 | 0.9981 | 10.72 | 150.6 | 13.58 | 14.05 | 41.63 |
| 80 | 1.0314 | 11.06 | 155.8 | 13.60 | 14.09 | 42.64 |
| 85 | 1.212 | 12.89 | 184.4 | 13.73 | 14.31 | 48.04 |
| 90 | 1.421 | 14.96 | 217.6 | 13.86 | 14.55 | 54.13 |
| 95 | 1.659 | 17.32 | 256.3 | 13.98 | 14.80 | 61.01 |
| 100 | 1.931 | 19.98 | 301.3 | 14.11 | 15.08 | 68.79 |
| 105 | 2.241 | 22.99 | 354 | 14.24 | 15.39 | 77.63 |
| 110 | 2.594 | 26.38 | 415 | 14.36 | 15.73 | 87.69 |
| 115 | 2.993 | 31.8 | 486 | 14.49 | 16.10 | 99.10 |
| 120 | 3.444 | 34.44 | 569 | 14.62 | 16.52 | 112.37 |
| 125 | 3.952 | 39.19 | 667 | 14.75 | 16.99 | 127.54 |
| 130 | 4.523 | 44.49 | 780 | 14.88 | 17.53 | 145.06 |
| 135 | 5.163 | 50.38 | 913 | 15.00 | 18.13 | 165.34 |
| 140 | 5.878 | 56.91 | 1072 | 15.13 | 18.84 | 189.22 |
| 150 | 7.566 | 72.10 | 1485 | 15.39 | 20.60 | 250.30 |

Man and air

(a) **Respiration.** An adult at rest breathes 16 respirations per minute, about $0.5 \text{ m}^3/\text{hr}$ (about $17.5 \text{ ft}^3/\text{hr}$). When working the rate is 3 to 6 times more.

Average composition of exhaled air

Oxygen 16.5%

Carbon dioxide 4.0%

Nitrogen and argon 79.5%

Quantity of carbon dioxide exhaled in 24 hrs is about 1 kg (2.2 lb).

(b) **Equilibrium of Heat.** Heat is generated within the human body by combustion of food. Heat is lost from the human body by

- 1 Conduction and convection about 25%
- 2 Radiation about 43%
- 3 Evaporation of moisture about 30%
- 4 Exhaled air about 2%

Evaporation prevails at high ambient temperatures. Conduction and convection prevail at low ambient temperatures.

Heat is liberated at a rate such that the internal body temperature is maintained at 37°C (98.6°F).

Proportion of sensible and latent heat dissipated by man at fairly hard work

| <i>Dry bulb temp</i> | $^\circ\text{C}$ | 13 | 15 | 18 | 21 | 24 | 27 | 30 | 32 |
|----------------------|------------------|----|----|----|----|----|----|----|----|
| | $^\circ\text{F}$ | 55 | 60 | 65 | 70 | 75 | 80 | 85 | 90 |
| Sensible heat | % | 75 | 68 | 60 | 51 | 42 | 31 | 20 | 10 |
| Latent heat | % | 25 | 32 | 40 | 49 | 58 | 69 | 80 | 90 |

(c) **Heat Loss of Human Body.** The total heat loss of an adult (sensible and latent) is approximately 117 W at room temperatures between 18°C and 30°C (about 400 Btu/hr).

Thermal indices are combinations of air temperature, radiant temperature, air movement and humidity to give a measure of a person's feeling of warmth.

- (i) *Equivalent temperature* combines the effects of air temperature, radiation and air movement. Numerically it is the temperature of a uniform enclosure in which a sizeable black body maintained at 24°C in still air would lose heat at the same rate as in the environment under consideration. It is measured by a Eupatheoscope.
- (ii) *Effective temperature* is an arbitrary index on the basis of subjective assessments of the degree of comfort felt by people in various environments. It takes into account air temperature, air movement and humidity. Numerically it is the temperature of still, saturated air which would produce an identical degree of comfort.
- (iii) *Globe temperature* combines the effects of air temperature, radiation and air movement. Numerically it is the reading of a thermometer with its bulb at the centre of a blackened globe 150 mm dia. It is similar to the equivalent temperature but easier to measure.
- (iv) *Dry resultant temperature* is similar to globe temperature but the globe used is 100 mm dia. This makes it rather less sensitive to radiation.
- (v) *Environmental temperature* combines air temperature and radiation. Numerically it is given by the formula

$$t_{ei} = \frac{2}{3}t_r + \frac{1}{3}t_a$$

where t_{ei} = environmental temperature, °C

t_r = mean radiant temperature of surroundings, °C

t_a = air temperature, °C

It is not very different from the other scales when air velocity is low and air and radiant temperatures are not widely different, and is easier to use in calculations.

Atmospheric data. Composition of air

Dry air is a mechanical mixtures of gases.

| | <i>Dry air per cent</i> | | <i>Atmospheric at sea level</i> |
|----------------|-------------------------|------------------|---------------------------------|
| | <i>By volume</i> | <i>By weight</i> | <i>By volume</i> |
| Oxygen | 21.00 | 23.2 | 20.75 |
| Nitrogen | 78.03 | 75.5 | 77.08 |
| Carbon dioxide | 0.03 | 0.046 | 0.03 |
| Hydrogen | 0.01 | 0.007 | 0.01 |
| Rare gases | 0.93 | 1.247 | 0.93 |
| Water vapour | — | — | 1.20 |

The composition of air is unchanged to a height of approximately 10 000 metres. The average air temperature diminishes at the rate of about 0.6°C for each 100 m of vertical height.

Altitude-density tables for air

| <i>Altitude m</i> | <i>Barometer mm Hg</i> | <i>Altitude m</i> | <i>Barometer mm Hg</i> | <i>Altitude m</i> | <i>Barometer mm Hg</i> |
|-----------------------|----------------------------|-----------------------|----------------------------|-----------------------|----------------------------|
| 0 | 749 | 600 | 695 | 1,350 | 632 |
| 75 | 743 | 750 | 681 | 1,500 | 620 |
| 150 | 735 | 900 | 668 | 1,800 | 598 |
| 250 | 726 | 1,000 | 658 | 2,100 | 577 |
| 300 | 723 | 1,200 | 643 | 2,400 | 555 |
| 450 | 709 | | | | |

| <i>Altitude ft</i> | <i>Barometer in Hg</i> | <i>Altitude ft</i> | <i>Barometer in Hg</i> | <i>Altitude ft</i> | <i>Barometer in Hg</i> |
|------------------------|----------------------------|------------------------|----------------------------|------------------------|----------------------------|
| 0 | 29.92 | 2,000 | 27.72 | 4,500 | 25.20 |
| 250 | 29.64 | 2,500 | 27.20 | 5,000 | 24.72 |
| 500 | 29.36 | 3,000 | 26.68 | 6,000 | 23.79 |
| 750 | 29.08 | 3,500 | 26.18 | 7,000 | 22.90 |
| 1,000 | 28.80 | 4,000 | 25.58 | 8,000 | 22.04 |
| 1,500 | 28.31 | | | | |

Normal Temperature and Pressure (NTP) is 0°C and 101.325 kN/m². Standard Temperature and Pressure (STP) used for determination of fan capacities is 20°C and 101.6 kN/m² or 60°F and 30 in Hg. (These two sets of conditions do no convert directly, but the density of dry air is 1.22 kg/m³ = 0.0764 lb/ft³ at both conditions.)

6 Heat losses


Heat input has to balance heat loss by

- 1 conduction and convection through walls, windows, etc.
- 2 infiltration of cold air.

1 Heat loss through walls, windows, doors, ceilings, floors, etc.

$$H = AU(t_i - t_o)$$

$$U = \frac{1}{\frac{1}{f_1} + \frac{x_1}{k_1} + \frac{x_2}{k_2} + \frac{x_3}{k_3} + \frac{1}{f_o}}$$



where

H = heat transmitted (W)

A = area of exposed surface (m^2)

U = overall coefficient of heat transmission ($W/m^2 K$)

t_i = inside air temperature ($^{\circ}C$)

t_o = outside air temperature ($^{\circ}C$)

x = thickness of material (m)

k = thermal conductivity of material ($W/m K$)

f_i = surface conductance for inside wall ($W/m^2 K$)

f_o = surface conductance for outside wall ($W/m^2 K$)

$C = \frac{k}{x}$ = conductance = heat flow through unit area in unit time ($W/m^2 K$)

$R = \frac{x}{k} = \frac{1}{C}$ = thermal resistivity

2 Heat loss by infiltration

$$H = sdnV(t_i - t_o)$$

where

- H = heat loss (kW)
- s = specific heat capacity of air (kJ/kg K)
- d = density of air (kg/m³)
- n = number of air changes (1/s)
- V = volume of room (m³)
- t_1 = inside air temperature (°C)
- t_o = outside air temperature (°C)

Safety additions to heat loss calculations

- 1 For aspect
 - North East, 10%.
 - West, 5%
- 2 For exposure 5%–10% for surfaces exposed to wind
- 3 For intermittent heating
 - Buildings heated during day only, 10–15%
 - Buildings not in use daily, 25–30%
 - Buildings with long periods between use (e.g. churches), up to 50%
- 4 For height

| | | | | | | | | | |
|----------------|---|-----|---|-----|----|------|----|------|-------------|
| Height of room | m | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 and more |
| Addition | % | 2.5 | 5 | 7.5 | 10 | 12.5 | 15 | 17.5 | 20 |

Air movement. Air movement makes any conditions of temperature and humidity feel colder; it lowers the effective temperature. An air velocity of 0.12 m/s may be considered as practically still air. A slight air movement is desirable for comfort to remove layers of humid and warm air from the surface of the human body. A higher air velocity is required in air at high temperature and high relative humidity than in air at low temperature and low relative humidity.

Entering air temperature in plenum heating systems must not be too much above or below the room temperature.

For heating

- normally air entering temperature 26–32°C
- with good mixing air entering temperature 38–49°C

For cooling

- inlets near occupied zones 5–9°C below room temperature
- high velocity jets, diffusion nozzles 17°C below room temperature

Allowance for warming up

(a) rooms heated daily (not at night)

$$H = \frac{0.063(n - 1)H_o}{Z} \text{ W}$$

(b) rooms not heated daily

$$H = \frac{0.1(Z + 8)H_t}{Z} \text{ W}$$

where

- H = heat required for warming up (W)
- H_o = heat loss through outside surface (W)
- H_t = total heat loss (W)
- n = interruption of heating (hr)
- Z = warming up time (hr)

Air temperatures at various levels


Increase of temperature from 1.5 m to 6 m is at the rate of 7% of temperature at 1.5 m per m. No further increase after 6 m.

$$t' = t + 0.07(h - 1.5)t$$

- t' = temperature at given level above floor (°C)
- t = temperature of 1.5 m above floor (°C)
- h = height of given level above floor (m)

Temperature of unheated spaces

$$t = \frac{t_i A_c U_c + t_o A_r U_r}{A_c U_c + A_r U_r}$$



where

- t = temperature of unheated space (°C)
- t_i = temperature of adjacent room (°C)
- t_o = outside temperature (°C)
- A_c = area of surface between space and adjacent room - ceiling (m²)
- A_r = area of surface between space and outside - roof (m²)
- U_c = coefficient of heat transmission between space and adjacent room (W/m² K)
- U_r = coefficient of heat transmission between space and outside (W/m² K)

Combined coefficient for ceiling and roof

$$U_E = \frac{U_R U_c}{U_R + \frac{U_c}{r}}$$

where

U_E = combined coefficient of heat transmission from inside to outside, based on ceiling area ($\text{W/m}^2 \text{K}$)

U_R = coefficient of heat transmission of roof ($\text{W/m}^2 \text{K}$)

U_c = coefficient of heat transmission of ceiling ($\text{W/m}^2 \text{K}$)

r = ratio of roof area to ceiling area (dimensionless)

Design winter indoor temperatures ($^{\circ}\text{C}$)

| | | | |
|---------------------|----|-----------------------|----|
| <i>Heated rooms</i> | | Libraries | 20 |
| Bars | 18 | Living rooms | 21 |
| Bathrooms | 22 | Museums | 20 |
| Bedrooms | 18 | Offices | 20 |
| Changing rooms | 22 | Operating theatres | 24 |
| Churches | 18 | Prisons | 18 |
| Cloakrooms | 16 | Recreation rooms | 18 |
| Classrooms | 20 | Restaurants | 18 |
| Corridors | 16 | Shops | 18 |
| Dining rooms | 20 | Stores | 15 |
| Dressing rooms | 21 | Swimming baths | 27 |
| Exhibition halls | 18 | Waiting rooms | 18 |
| Factories | | Wards | 18 |
| sedentary work | 18 | Warehouses | 16 |
| light work | 16 | | |
| heavy work | 13 | <i>Unheated rooms</i> | |
| Gyms | 15 | Attics | 0 |
| Halls, | | Attics under | |
| assembly | 18 | insulated roof | 4 |
| entrance | 16 | Cellars | 0 |
| Hotel rooms | 21 | Foyers with doors | |
| Kitchens | 16 | frequently opened | 0 |
| Laboratories | 20 | not frequently opened | 4 |
| Lecture rooms | 20 | Internal rooms | 2 |

Design winter outdoor temperatures

For England -4°C to 0°C .

Design infiltration rates

| | <i>Air changes per hour</i> | | <i>Air changes per hour</i> |
|------------------|-------------------------------------|--------------------|-------------------------------------|
| Bars | 1 | Laboratories | 1 |
| Bathrooms | 2 | Lecture rooms | $1\frac{1}{2}$ |
| Bedrooms | 1 | Libraries | $\frac{1}{2}$ |
| Changing rooms | $\frac{1}{2}$ | Living rooms | $1\frac{1}{2}$ |
| Churches | $\frac{1}{2}$ | Museums | 1 |
| Cloakrooms | 1 | Offices | 1 |
| Classrooms | 2 | Operating theatres | $\frac{3}{4}$ |
| Corridors | $1\frac{1}{2}$ | Prisons | 2 |
| Dining rooms | 1 | Recreation rooms | 1 |
| Dressing rooms | 1 | Restaurants | 1 |
| Exhibition halls | $\frac{1}{2}$ | Shops | 1 |
| Factories | $1-1\frac{1}{2}$ | Stores | $\frac{1}{2}$ |
| Gyms | 1 | Swimming baths | $\frac{1}{2}$ |
| Halls, assembly | $\frac{1}{2}$ | Waiting rooms | 1 |
| entrance | 2 | Wards | 2 |
| Hotel rooms | 1 | Warehouses | $\frac{1}{2}$ |

Typical Air Infiltration Rates

10–27 m³/hr per m² of facade at 50 N/m² pressure difference between inside and outside

Heat loss calculations for high buildings

| <i>Floor</i> | <i>Addition to infiltration rate</i> | <i>Designation of U-value</i> |
|--------------|--------------------------------------|-------------------------------|
| Ground, 1st | nil | Normal |
| 2nd to 4th | 25% | Normal |
| 5th to 11th | 50% | Normal |
| Above 11th | 100% | Severe |

Infiltration heat loss

Heat loss for 1 air change per hour = 0.34 W/m³ K (0.018 Btu/hr ft³ °F).

Heat loss calculation

Contract temperatures and their equivalents

Inside temperatures obtained with a certain system with outside temperatures other than for which the system is designed. (Empirical formula by J. Roger Preston.)

$$t_4 = (t_1^{12} - t_2^{12} + t_3^{12})^{1/12}$$

where

t_1 = Contract inside temperature (K)

t_2 = Contract outside temperature (K)

t_3 = Existing outside temperature (K)

t_4 = Estimated inside temperature (K)

(Formula remains unchanged if all temperatures are in °F absolute.)

Table for 30°F contract outside and 60°F contract inside

| Existing | | | | | | | | | | | |
|------------------|----|----|----|----|----|-----------|----|----|----|----|----|
| Outside temp. °F | 20 | 22 | 24 | 26 | 28 | 30 | 32 | 34 | 36 | 38 | 40 |
| Inside temp. °F | 55 | 56 | 57 | 58 | 59 | 60 | 61 | 62 | 63 | 64 | 65 |

Table for 0°C contract outside and 20°C contract inside

| Existing | | | | | | | | | | | |
|------------------|------|------|------|------|------|-----------|------|------|------|------|------|
| Outside temp. °C | -5 | -4 | -3 | -2 | -1 | 0 | +1 | 2 | 3 | 4 | 5 |
| Inside temp. °C | 17.8 | 18.3 | 18.8 | 19.0 | 19.6 | 20 | 20.5 | 21.0 | 21.4 | 21.7 | 22.5 |

Thermal conductivities

| <i>Material</i> | <i>Conductivity</i> <i>k</i> | | <i>Resistivity</i> <i>1/k</i> | |
|--------------------|--------------------------------------|----------------|--------------------------------------|--------------|
| | $\frac{Btu\ in}{ft^2\ hr\ ^\circ F}$ | <i>W/m K</i> | $\frac{ft^2\ hr\ ^\circ F}{Btu\ in}$ | <i>m K/W</i> |
| Air | 0.18 | 0.026 | 5.56 | 38.6 |
| Aluminium | 1050 | 150 | | |
| Asbetolux | 0.8 | 0.12 | 1.25 | 8.67 |
| Asbestos: | | | | |
| flues and pipes | 1.9 | 0.27 | 0.53 | 3.68 |
| insulating board | 1.0 | 0.14 | 1.0 | 6.93 |
| lightweight slab | 0.37 | 0.053 | 2.70 | 18.7 |
| Asphalt: | | | | |
| light | 4.0 | 0.58 | 0.25 | 1.73 |
| heavy | 8.5 | 1.23 | 0.12 | 0.83 |
| Brass | 550 | 150 | | |
| Bricks: | | | | |
| common | 9.9 | 1.43 | 0.10 | 0.69 |
| engineering | 5.5 | 0.79 | 0.18 | 1.25 |
| Brine | 3.3 | 0.48 | 0.30 | 2.10 |
| Building | | | | |
| board | 0.55 | 0.079 | 1.82 | 12.62 |
| paper | 0.45 | 0.065 | 2.22 | 15.39 |
| Caposite | 0.36 | 0.052 | 2.78 | 19.28 |
| Cardboard | 1.0 to 2.0 | 0.144 to 0.288 | 1.0 to 0.5 | 6.9 to 3.5 |
| Celotex | 0.33 | 0.048 | 3.0 | 21.0 |
| Concrete: | | | | |
| 1:2:4 | 10.0 | 1.4 | 0.10 | 0.69 |
| lightweight | 2.8 | 0.40 | 0.36 | 2.5 |
| Copper | 2100 | 300 | | |
| Cork | 0.30 | 0.043 | 3.33 | 23.1 |
| Densotape | 1.7 | 0.25 | 0.58 | 4.0 |
| Diatomaceous earth | 0.60 | 0.087 | 1.66 | 11.5 |
| Econite | 0.68 | 0.098 | 1.47 | 10.19 |
| Felt | 0.27 | 0.039 | 3.70 | 25.7 |
| Fibreglass | 0.25 | 0.036 | 4.0 | 27.7 |
| Firebrick | 9.0 | 1.30 | 0.11 | 0.76 |
| Fosalsil | 1.0 | 0.14 | 0.10 | 0.69 |
| Glass | 7.3 | 1.05 | 0.14 | 0.97 |
| Glasswool | 0.28 | 0.04 | 3.6 | 24.8 |
| Gold | 2150 | 310 | | |

Thermal conductivities (continued)

| Material | Conductivity k | | Resistivity $1/k$ | |
|------------------------|--|-------|--|--------|
| | $\frac{\text{Btu in}}{\text{ft}^2 \text{ hr } ^\circ\text{F}}$ | W/m K | $\frac{\text{ft}^2 \text{ hr } ^\circ\text{F}}{\text{Btu in}}$ | m K/W |
| Granwood floor blocks | 2.20 | 0.32 | 0.45 | 3.1 |
| Gyproc plasterboard | 1.1 | 0.16 | 0.91 | 6.3 |
| Gypsum plasterboard | 1.1 | 0.16 | 0.91 | 6.3 |
| Hardboard | 0.65 | 0.094 | 1.54 | 10.68 |
| Holoplast: 25 mm panel | 0.95 | 0.14 | 1.05 | 7.3 |
| Ice | 16.0 | 2.31 | 0.0625 | 0.43 |
| Insulating board | 0.41 | 0.059 | 2.45 | 16.99 |
| Iron: | | | | |
| cast | 450 | 65 | 0.0022 | 0.154 |
| wrought | 400 | 58 | 0.0025 | 0.0172 |
| Jute | 0.25 | 0.036 | 4.0 | 27.7 |
| Kapok | 0.25 | 0.036 | 4.0 | 27.7 |
| Lead | 240 | 35 | 0.0042 | 0.029 |
| Linoleum: | | | | |
| cork | 0.5 | 0.072 | 2.0 | 13.9 |
| p.v.c. | 1.5 | 0.22 | 0.67 | 4.65 |
| rubber | 2.1 | 0.30 | 0.48 | 3.33 |
| Marinite | 0.74 | 0.11 | 1.35 | 9.36 |
| Mercury | 48 | 7 | 0.021 | 0.143 |
| Mica sheet | 4.5 | 0.65 | 0.22 | 1.53 |
| Mineral wool | 0.39 | 0.056 | 3.33 | 23.1 |
| Nickel | 400 | 58 | 0.0025 | 0.0172 |
| On ozote | 0.20 | 0.029 | 5.0 | 34.7 |
| Paper | 0.90 | 0.13 | 0.11 | 7.69 |
| Perspex | 1.45 | 0.21 | 0.69 | 4.8 |
| Plaster | 3.3 | 0.48 | 0.30 | 2.1 |
| Platinum | 480 | 69 | 0.0021 | 0.0145 |
| Polystyrene: cellular | 0.23 | 0.033 | 4.3 | 29.8 |
| Polyurethane: cellular | 0.29 | 0.042 | 3.45 | 23.9 |
| Polyzote | 0.22 | 0.032 | 4.55 | 31.5 |
| Porcelain | 7.2 | 1.04 | 0.14 | 0.96 |

Thermal conductivities (continued)

| <i>Material</i> | <i>Conductivity</i> <i>k</i> | | <i>Resistivity</i> <i>1/k</i> | |
|---------------------------|--|--------------|--|--------------|
| | <i>Btu in</i> <i>ft² hr °F</i> | <i>W/m K</i> | <i>ft² hr °F</i> <i>Btu in</i> | <i>m K/W</i> |
| Refractory brick alumina | 2.2 | 0.32 | 0.45 | 3.1 |
| diatomaceous | 0.9 | 0.13 | 1.11 | 7.70 |
| silica | 10.0 | 1.44 | 0.10 | 0.69 |
| vermiculite insulating | 1.35 | 0.19 | 0.74 | 5.13 |
| Refractory concrete: | | | | |
| diatomaceous | 1.8 | 0.26 | 0.56 | 3.9 |
| aluminous cement | 3.2 | 0.46 | 0.31 | 2.15 |
| Rubber: | | | | |
| natural | 1.1 | 0.16 | 0.91 | 6.3 |
| silicone | 1.6 | 0.23 | 0.63 | 4.4 |
| Sand | 2.9 | 0.42 | 0.35 | 2.4 |
| Scale, boiler | 16.0 | 2.3 | 0.0625 | 0.43 |
| Silver | 2900 | 420 | | |
| Sisalkraft building paper | 0.46 | 0.066 | 2.17 | 15.0 |
| Slate | 14.0 | 2.0 | 0.071 | 0.5 |
| Snow | 1.5 | 0.22 | 0.67 | 4.65 |
| Steel, soft | 320 | 46 | | |
| Steel wool | 0.75 | 0.108 | 1.33 | 9.22 |
| Stillite | 0.25 | 0.036 | 4.0 | 27.7 |
| Stone: | | | | |
| granite | 20.3 | 2.9 | 0.05 | 0.35 |
| limestone | 10.6 | 1.5 | 0.09 | 0.62 |
| marble | 17.4 | 2.5 | 0.06 | 0.42 |
| sandstone | 13.0 | 1.9 | 0.08 | 0.55 |
| Sundeala: | | | | |
| insulating board | 0.36 | 0.052 | 2.78 | 19.3 |
| medium hardboard | 0.51 | 0.074 | 2.0 | 13.9 |
| Tentest | 0.35 | 0.05 | 2.86 | 19.8 |
| Thermalite | 1.4 | 0.20 | 0.71 | 4.9 |
| Tiles: | | | | |
| asphalt and | | | | |
| asbestos | 3.8 | 0.55 | 0.26 | 1.8 |
| burnt clay | 5.8 | 0.84 | 0.17 | 1.2 |
| concrete | 8.0 | 1.2 | 0.13 | 0.90 |
| cork | 0.58 | 0.084 | 1.72 | 11.9 |
| plaster | 2.6 | 0.37 | 0.38 | 2.63 |

Thermal conductivities (continued)

| <i>Material</i> | <i>Conductivity</i> <i>k</i> | | <i>Resistivity</i> <i>1/k</i> | |
|-----------------|--|--------------|--|--------------|
| | $\frac{\text{Btu in}}{\text{ft}^2 \text{ hr } ^\circ\text{F}}$ | <i>W/m K</i> | $\frac{\text{ft}^2 \text{ hr } ^\circ\text{F}}{\text{Btu in}}$ | <i>m K/W</i> |
| Timber: | | | | |
| balsa | 0.33 | 0.048 | 3.0 | 20.8 |
| beech | 1.16 | 0.17 | 0.86 | 5.97 |
| cypress | 0.67 | 0.097 | 1.49 | 10.3 |
| deal | 0.87 | 0.13 | 1.15 | 7.97 |
| fir | 0.76 | 0.11 | 1.3 | 9.1 |
| oak | 1.11 | 0.16 | 0.90 | 6.24 |
| plywood | 0.96 | 0.14 | 1.04 | 7.21 |
| teak | 0.96 | 0.14 | 1.04 | 7.21 |
| Treetex | 0.39 | 0.056 | 2.56 | 17.8 |
| Water | 4.15 | 0.60 | 0.24 | 1.7 |
| Weyboard | 0.63 | 0.091 | 1.60 | 11.1 |
| Weyroc | 1.0 | 0.14 | 1.0 | 6.9 |
| Woodwool | 0.28 | 0.040 | 3.58 | 24.8 |
| Wool | 0.30 | 0.043 | 3.33 | 23.1 |
| Zinc | 440 | 64 | | |
| Sawdust | 0.49 | 0.071 | 2.04 | 14.1 |
| Cotton waste | 0.41 | 0.059 | 2.4 | 16.9 |

Thermal transmittance coefficients for building elements

| | | <i>Exposure</i> | | | | | | | | | | | | |
|--------------------|----------------|-------------------------------------|------------------------------|-------------------------------------|------------------------------|-------------------------------------|------------------------------|-------------------------------------|------------------------------|-------------------------------------|------------------------------|-------------------------------------|------------------------------|-----|
| | | <i>S</i> | | <i>Sheltered</i> | | <i>Normal</i> | | <i>Severe</i> | | – | | – | | |
| <i>Orientation</i> | <i>W SW SE</i> | – | | <i>Sheltered</i> | | <i>Normal</i> | | <i>Severe</i> | | – | | – | | |
| | <i>NW</i> | – | | – | | <i>Sheltered</i> | | <i>Normal</i> | | <i>Severe</i> | | – | | |
| | <i>N NE E</i> | – | | – | | <i>Sheltered</i> | | <i>Normal</i> | | – | | <i>Severe</i> | | |
| | | <i>Btu/ft² hr °F</i> | <i>W/m² K</i> | <i>Btu/ft² hr °F</i> | <i>W/m² K</i> | <i>Btu/ft² hr °F</i> | <i>W/m² K</i> | <i>Btu/ft² hr °F</i> | <i>W/m² K</i> | <i>Btu/ft² hr °F</i> | <i>W/m² K</i> | <i>Btu/ft² hr °F</i> | <i>W/m² K</i> | |
| <i>Walls</i> | | | | | | | | | | | | | | |
| Solid brick | 100 mm | 0.50 | 2.9 | 0.55 | 3.1 | 0.59 | 3.4 | 0.64 | 3.6 | 0.69 | 3.9 | 0.75 | 4.3 | |
| | Unplastered | 225 mm | 0.39 | 2.2 | 0.42 | 2.4 | 0.44 | 2.5 | 0.47 | 2.7 | 0.50 | 2.9 | 0.53 | 3.0 |
| | | 340 mm | 0.32 | 1.8 | 0.34 | 1.9 | 0.35 | 2.0 | 0.37 | 2.1 | 0.39 | 2.2 | 0.41 | 2.3 |
| Solid brick | 100 mm | 0.46 | 2.6 | 0.49 | 2.8 | 0.53 | 3.0 | 0.57 | 3.2 | 0.61 | 3.5 | 0.65 | 3.7 | |
| | Plastered | 225 mm | 0.36 | 2.1 | 0.38 | 2.2 | 0.41 | 2.3 | 0.43 | 2.4 | 0.45 | 2.6 | 0.48 | 2.7 |
| | | 340 mm | 0.30 | 1.7 | 0.32 | 1.8 | 0.33 | 1.9 | 0.35 | 2.0 | 0.36 | 2.1 | 0.38 | 2.2 |
| | | 455 mm | 0.26 | 1.5 | 0.27 | 1.5 | 0.28 | 1.6 | 0.29 | 1.6 | 0.30 | 1.7 | 0.31 | 1.8 |
| | | 560 mm | 0.23 | 1.3 | 0.23 | 1.3 | 0.24 | 1.4 | 0.25 | 1.4 | 0.26 | 1.5 | 0.26 | 1.5 |
| Cavity brick | 270 mm | 0.27 | 1.5 | 0.28 | 1.6 | 0.29 | 1.6 | 0.30 | 1.7 | 0.31 | 1.8 | 0.32 | 1.8 | |
| | Unventilated | 390 mm | 0.23 | 1.3 | 0.24 | 1.4 | 0.25 | 1.4 | 0.26 | 1.5 | 0.27 | 1.5 | 0.27 | 1.5 |
| | | 500 mm | 0.21 | 1.2 | 0.21 | 1.2 | 0.22 | 1.2 | 0.22 | 1.2 | 0.23 | 1.3 | 0.24 | 1.4 |
| Cavity brick | 270 mm | 0.30 | 1.7 | 0.31 | 1.8 | 0.33 | 1.9 | 0.34 | 1.9 | 0.36 | 2.0 | 0.37 | 2.1 | |
| | Ventilated | 390 mm | 0.26 | 1.5 | 0.27 | 1.5 | 0.28 | 1.6 | 0.29 | 1.6 | 0.30 | 1.7 | 0.31 | 1.8 |
| | | 500 mm | 0.22 | 1.2 | 0.23 | 1.3 | 0.24 | 1.4 | 0.25 | 1.4 | 0.25 | 1.4 | 0.26 | 1.5 |
| Cavity brick | 200 mm | 0.31 | 1.8 | 0.32 | 1.8 | 0.34 | 1.9 | 0.36 | 2.0 | 0.37 | 2.1 | 0.39 | 2.2 | |
| | Plastered | 270 mm | 0.23 | 1.3 | 0.23 | 1.3 | 0.23 | 1.3 | 0.24 | 1.4 | 0.25 | 1.4 | 0.26 | 1.5 |
| | | 390 mm | 0.18 | 1.0 | 0.19 | 1.1 | 0.19 | 1.1 | 0.20 | 1.1 | 0.20 | 1.1 | 0.21 | 1.2 |
| Concrete | 100 mm | 0.55 | 3.1 | 0.60 | 3.4 | 0.66 | 3.8 | 0.71 | 4.0 | 0.78 | 4.4 | 0.85 | 4.8 | |
| | 150 mm | 0.49 | 2.8 | 0.53 | 3.0 | 0.58 | 3.3 | 0.63 | 3.6 | 0.68 | 3.9 | 0.73 | 4.1 | |
| | 200 mm | 0.45 | 2.5 | 0.48 | 2.7 | 0.52 | 3.0 | 0.56 | 3.2 | 0.60 | 3.4 | 0.64 | 3.6 | |
| | 250 mm | 0.41 | 2.3 | 0.44 | 2.5 | 0.47 | 2.7 | 0.50 | 2.8 | 0.53 | 3.0 | 0.57 | 3.2 | |

| | | | | | | | | | | | | | |
|---|--------|------|------|------|------|------|------|------|------|------|-----|------|-----|
| Wood | 25 mm | 0.41 | 2.3 | 0.44 | 2.5 | 0.47 | 2.7 | 0.50 | 2.8 | 0.53 | 3.0 | 0.56 | 3.2 |
| Tongued and grooved | 38 mm | 0.34 | 1.9 | 0.36 | 2.0 | 0.38 | 2.2 | 0.40 | 2.3 | 0.42 | 2.4 | 0.44 | 2.5 |
| <i>Walls</i> | | | | | | | | | | | | | |
| Asbestos sheeting | 6 mm | 0.64 | 3.1 | 0.72 | 4.1 | 0.80 | 4.6 | 0.89 | 5.1 | 1.00 | 5.7 | 1.12 | 6.4 |
| Corrugated iron | 1.6 mm | 0.79 | 4.5 | 0.91 | 5.2 | 1.04 | 5.9 | 1.20 | 6.8 | 1.40 | 8.0 | 1.67 | 9.5 |
| Stone | 300 mm | 0.41 | 2.3 | 0.44 | 2.5 | 0.47 | 2.7 | 0.50 | 2.8 | 0.53 | 3.0 | 0.56 | 3.2 |
| | 450 mm | 0.34 | 1.9 | 0.36 | 2.0 | 0.38 | 2.2 | 0.40 | 2.3 | 0.42 | 2.4 | 0.44 | 2.5 |
| | 600 mm | 0.29 | 1.6 | 0.31 | 1.8 | 0.32 | 1.8 | 0.33 | 1.9 | 0.35 | 2.0 | 0.36 | 2.0 |
| <hr/> | | | | | | | | | | | | | |
| Cavity, inner leaf 100 mm thermalite, outer leaf 100 mm brick, 50 mm cavity | | 0.18 | 1.0 | 0.18 | 1.0 | 0.19 | 1.1 | 0.19 | 1.1 | 0.19 | 1.1 | 0.21 | 1.2 |
| Cavity, inner leaf thermalite 100 mm, outer leaf brick 100 mm, air gap 50 mm, lined internally plasterboard | | 0.16 | 0.92 | 0.17 | 0.95 | 0.17 | 0.97 | 0.17 | 0.99 | 0.18 | 1.0 | 0.18 | 1.0 |
| <hr/> | | | | | | | | | | | | | |
| Insulated, inner leaf 100 mm brick, 50 mm Polyurethane foam, outer leaf 100 mm brick internally plastered | | 0.31 | 1.8 | 0.32 | 1.8 | 0.34 | 1.9 | 0.36 | 2.0 | 0.37 | 2.1 | 0.39 | 2.2 |

Thermal transmittance coefficients for building elements (*continued*)

| Orientation | Exposure | | | | | | | | | | | | |
|--|----------------|-------------------------------------|------------------------------|-------------------------------------|------------------------------|-------------------------------------|------------------------------|-------------------------------------|------------------------------|-------------------------------------|------------------------------|-------------------------------------|------------------------------|
| | <i>S</i> | <i>Sheltered</i> | | <i>Normal</i> | | <i>Severe</i> | | — | — | — | — | — | |
| | <i>W SW SE</i> | — | <i>Sheltered</i> | | <i>Normal</i> | | <i>Severe</i> | | — | — | — | — | |
| | <i>NW</i> | — | — | <i>Sheltered</i> | | <i>Normal</i> | | <i>Severe</i> | | — | — | — | |
| | <i>N NE E</i> | — | — | <i>Sheltered</i> | | <i>Normal</i> | | — | — | — | <i>Severe</i> | | |
| | | <i>Btu/ft² hr °F</i> | <i>W/m² K</i> | <i>Btu/ft² hr °F</i> | <i>W/m² K</i> | <i>Btu/ft² hr °F</i> | <i>W/m² K</i> | <i>Btu/ft² hr °F</i> | <i>W/m² K</i> | <i>Btu/ft² hr °F</i> | <i>W/m² K</i> | <i>Btu/ft² hr °F</i> | <i>W/m² K</i> |
| Insulated, outer leaf | | | | | | | | | | | | | |
| 110 mm brick, 50 mm cavity, inner leaf | | | | | | | | | | | | | |
| 110 mm lightweight concrete, 50 mm fibreglass insulation, lined with plasterboard | | | | | | | | | | | | | |
| as above, 75 mm fibreglass | | | | | | | | | | | | | |
| as above, 100 mm fibreglass | | | | | | | | | | | | | |
| Insulated, outer leaf 110 mm brick, inner leaf 110 mm lightweight concrete lined with plaster or plasterboard, insulation between leaves | | | | | | | | | | | | | |
| 50 mm fibreglass | | | | | | | | | | | | | |
| as above, 75 mm fibreglass | | | | | | | | | | | | | |
| as above, 50 mm polystyrene | | | | | | | | | | | | | |
| as above, 75 mm polystyrene | | | | | | | | | | | | | |

| | | | | | | | | | | | | |
|---|-------|------|-------|------|-------|------|-------|------|-------|------|-------|------|
| Outer leaf 110 mm brick inner leaf 110 mm thermalite, lined with plaster or plasterboard, insulation between leaves 50 mm fibreglass | 0.080 | 0.44 | 0.081 | 0.45 | 0.081 | 0.45 | 0.082 | 0.46 | 0.083 | 0.46 | 0.084 | 0.46 |
| as above, 75 mm fibreglass | 0.061 | 0.34 | 0.061 | 0.34 | 0.062 | 0.34 | 0.062 | 0.35 | 0.063 | 0.35 | 0.063 | 0.35 |
| as above, 50 mm polystyrene | 0.076 | 0.42 | 0.077 | 0.43 | 0.078 | 0.43 | 0.078 | 0.44 | 0.079 | 0.44 | 0.080 | 0.44 |
| as above, 75 mm polystyrene | 0.058 | 0.32 | 0.058 | 0.32 | 0.059 | 0.33 | 0.059 | 0.33 | 0.060 | 0.33 | 0.060 | 0.33 |
| Outer leaf 150 mm concrete inner leaf 225 mm thermalite, plastered, insulation between leaves 50 mm fibreglass | 0.062 | 0.35 | 0.062 | 0.35 | 0.063 | 0.36 | 0.063 | 0.36 | 0.064 | 0.36 | 0.064 | 0.37 |
| as above 75 mm fibreglass | 0.050 | 0.28 | 0.050 | 0.28 | 0.050 | 0.29 | 0.051 | 0.29 | 0.051 | 0.29 | 0.051 | 0.29 |
| Outer leaf 150 mm concrete inner leaf 150 mm lightweight concrete, plastered, insulation between leaves 50 mm fibreglass | 0.083 | 0.47 | 0.084 | 0.48 | 0.085 | 0.48 | 0.086 | 0.49 | 0.087 | 0.49 | 0.088 | 0.50 |
| as above 75 mm fibreglass | 0.063 | 0.36 | 0.063 | 0.36 | 0.064 | 0.36 | 0.065 | 0.37 | 0.065 | 0.37 | 0.065 | 0.37 |

Thermal transmittance coefficients for building elements (continued)

| | | <i>Exposure</i> | | | | | | | | | | | |
|-------------------------|-----------------------------|-------------------------------------|------------------------------|-------------------------------------|------------------------------|-------------------------------------|------------------------------|-------------------------------------|------------------------------|-------------------------------------|------------------------------|-------------------------------------|------------------------------|
| | | <i>S</i> | <i>Sheltered</i> | | <i>Normal</i> | | <i>Severe</i> | | – | – | – | | |
| <i>Orientation</i> | <i>W SW SE</i> | – | <i>Sheltered</i> | | <i>Normal</i> | | <i>Severe</i> | | – | – | – | | |
| | <i>NW</i> | – | – | <i>Sheltered</i> | | <i>Normal</i> | | <i>Severe</i> | | – | – | – | |
| | <i>N NE E</i> | – | – | <i>Sheltered</i> | | <i>Normal</i> | | <i>Severe</i> | | – | – | – | |
| | | | | | | | | | | | | | |
| | | <i>Btu/ft² hr °F</i> | <i>W/m² K</i> | <i>Btu/ft² hr °F</i> | <i>W/m² K</i> | <i>Btu/ft² hr °F</i> | <i>W/m² K</i> | <i>Btu/ft² hr °F</i> | <i>W/m² K</i> | <i>Btu/ft² hr °F</i> | <i>W/m² K</i> | <i>Btu/ft² hr °F</i> | <i>W/m² K</i> |
| <i>Walls, concrete,</i> | | | | | | | | | | | | | |
| 250 mm concrete, | | | | | | | | | | | | | |
| lined internally | | | | | | | | | | | | | |
| with 50mm fibreglass | | | | | | | | | | | | | |
| and plasterboard | | | | | | | | | | | | | |
| | | 0.096 | 0.53 | 0.098 | 0.54 | 0.099 | 0.55 | 0.10 | 0.56 | 0.10 | 0.56 | 0.10 | 0.57 |
| | as above, 75 mm fibreglass | 0.070 | 0.39 | 0.071 | 0.39 | 0.072 | 0.40 | 0.072 | 0.40 | 0.073 | 0.41 | 0.073 | 0.41 |
| | as above, 50 mm polystyrene | 0.091 | 0.51 | 0.092 | 0.51 | 0.094 | 0.52 | 0.095 | 0.53 | 0.096 | 0.53 | 0.096 | 0.54 |
| | as above, 75 mm polystyrene | 0.066 | 0.37 | 0.067 | 0.37 | 0.067 | 0.37 | 0.068 | 0.38 | 0.069 | 0.38 | 0.069 | 0.38 |
| <i>Windows</i> | | | | | | | | | | | | | |
| | Single glazed | 0.70 | 4.0 | 0.79 | 4.5 | 0.88 | 5.0 | 1.00 | 5.7 | 1.14 | 6.5 | 1.30 | 7.4 |
| | Double | | | | | | | | | | | | |
| | glazed | | | | | | | | | | | | |
| | 20 mm air gap | 0.41 | 2.3 | 0.44 | 2.5 | 0.47 | 2.7 | 0.50 | 2.8 | 0.53 | 3.0 | 0.56 | 3.2 |
| | 12 mm air gap | 0.44 | 2.4 | 0.47 | 2.6 | 0.51 | 2.9 | 0.54 | 2.9 | 0.58 | 3.1 | 0.62 | 3.3 |
| | 6 mm air gap | 0.47 | 2.7 | 0.51 | 2.9 | 0.54 | 3.1 | 0.58 | 3.3 | 0.63 | 3.6 | 0.67 | 3.8 |
| | 3 mm air gap | 0.52 | 2.9 | 0.57 | 3.2 | 0.61 | 3.5 | 0.68 | 3.9 | 0.73 | 4.1 | 0.79 | 4.5 |
| | Triple | | | | | | | | | | | | |
| | glazed | | | | | | | | | | | | |
| | 20 mm air gap | 0.29 | 1.6 | 0.31 | 1.8 | 0.32 | 1.8 | 0.33 | 1.9 | 0.35 | 2.0 | 0.36 | 2.0 |
| | 12 mm air gap | 0.32 | 1.7 | 0.34 | 1.8 | 0.35 | 2.0 | 0.37 | 2.0 | 0.39 | 2.1 | 0.41 | 2.2 |
| | 6 mm air gap | 0.35 | 2.0 | 0.37 | 2.1 | 0.39 | 2.2 | 0.41 | 2.3 | 0.43 | 2.4 | 0.46 | 2.6 |
| | 3 mm air gap | 0.41 | 2.3 | 0.44 | 2.5 | 0.47 | 2.7 | 0.50 | 2.8 | 0.54 | 3.1 | 0.57 | 3.2 |

| <i>Internal floors and ceilings</i> | $\frac{Btu}{ft^2 hr ^\circ F}$ | W/m^2K |
|---|--------------------------------|----------|
| 25 mm screed on 150 mm concrete | 0.48 | 2.7 |
| 50 mm screed on 150 mm concrete | 0.46 | 2.6 |
| 25 mm floorboards on joists, plastered ceiling | 0.080 | 0.45 |
| 25 mm floorboards on joists, plasterboard ceiling | 0.079 | 0.45 |
| <i>Internal partitions</i> | $\frac{Btu}{ft^2 hr ^\circ F}$ | W/m^2K |
| 110 mm brick | 0.55 | 3.1 |
| 225 mm brick | 0.44 | 2.5 |
| 340 mm brick | 0.37 | 2.1 |
| 110 mm brick, plastered both sides | 0.53 | 3.0 |
| 225 mm brick, plastered both sides | 0.43 | 2.4 |
| 340 mm brick, plastered both sides | 0.36 | 2.0 |
| 100 mm thermalite, plastered both sides | 0.24 | 1.3 |
| 225 mm thermalite, plastered both sides | 0.13 | 0.73 |
| 100 mm lightweight concrete, plastered both sides | 0.35 | 2.0 |
| 150 mm lightweight concrete, plastered both sides | 0.28 | 1.6 |
| 250 mm lightweight concrete, plastered both sides | 0.20 | 1.1 |
| Plasterboard, air gap, plasterboard | 0.36 | 2.1 |

| | <i>Exposure</i> | | | | | |
|---|-------------------------------|---------|-------------------------------|---------|-------------------------------|---------|
| | <i>Sheltered</i> | | <i>Normal</i> | | <i>Severe</i> | |
| | $\frac{Btu}{ft^2 hr^\circ F}$ | W/m^2 | $\frac{Btu}{ft^2 hr^\circ F}$ | W/m^2 | $\frac{Btu}{ft^2 hr^\circ F}$ | W/m^2 |
| <i>Flat roofs</i> | | | | | | |
| Asphalt on 150 mm concrete | 0.58 | 3.3 | 0.64 | 3.6 | 0.70 | 4.0 |
| Asphalt on 150 mm concrete with plaster underneath | 0.51 | 2.9 | 0.55 | 3.1 | 0.61 | 3.5 |
| Asphalt on 150 mm hollow tiles | 0.45 | 2.5 | 0.48 | 2.7 | 0.52 | 3.0 |
| Asphalt on 150 mm hollow tiles with lightweight screed and plaster underneath | 0.30 | 1.7 | 0.32 | 1.8 | 0.33 | 1.9 |
| Asphalt with screed on 50 mm woodwool slabs on timber joists and plaster ceiling | 0.16 | 0.9 | 0.18 | 1.0 | 0.21 | 1.2 |
| Asphalt with screed on 50 mm woodwool slabs on steel framing | 0.24 | 1.4 | 0.26 | 1.5 | 0.28 | 1.6 |
| Asphalt on 50 mm screed on 50 mm fibreglass on steel sheet over 50 mm air gap with plasterboard underneath | 0.092 | 0.51 | 0.094 | 0.52 | 0.095 | 0.53 |
| as above, 75 mm fibreglass | 0.068 | 0.38 | 0.069 | 0.38 | 0.069 | 0.39 |
| as above, 100mm fibreglass | 0.054 | 0.30 | 0.054 | 0.30 | 0.055 | 0.30 |
| Asphalt on felt over 50 mm fibreglass on 150 mm concrete | 0.10 | 0.57 | 0.10 | 0.58 | 0.11 | 0.58 |
| as above, 75 mm fibreglass | 0.073 | 0.41 | 0.074 | 0.41 | 0.075 | 0.42 |
| as above, 100 mm fibreglass | 0.057 | 0.32 | 0.058 | 0.32 | 0.058 | 0.32 |
| Stone chippings on steel deck over 50 mm air gap above 50 mm fibreglass on plasterboard | 0.098 | 0.54 | 0.099 | 0.55 | 0.10 | 0.56 |
| as above, 75 mm fibreglass | 0.076 | 0.39 | 0.071 | 0.40 | 0.072 | 0.42 |
| as above, 100 mm fibreglass | 0.056 | 0.31 | 0.056 | 0.31 | 0.057 | 0.31 |
| <i>Pitched roofs</i> | | | | | | |
| Corrugated aluminium sheeting | 0.90 | 5.1 | 1.15 | 6.6 | 1.45 | 8.3 |
| Corrugated steel sheeting | 0.90 | 5.1 | 1.15 | 6.6 | 1.45 | 8.3 |
| Tiles on battens and roofing felt with rafters and plasterboard ceiling | 0.32 | 1.8 | 0.35 | 2.0 | 0.39 | 2.2 |
| Tiles on battens and roofing felt with rafters and plasterboard ceiling with boarding on rafters | 0.26 | 1.5 | 0.30 | 1.7 | 0.33 | 1.9 |
| Tiles on battens and rafters with plasterboard ceiling | 0.44 | 2.5 | 0.49 | 2.8 | 0.53 | 3.0 |
| Tiles on battens and rafters with plasterboard ceiling and boarding on rafters | 0.32 | 1.8 | 0.35 | 2.0 | 0.39 | 2.2 |

| | <i>Exposure</i> | | | | | |
|---|---|------------------------------------|---|------------------------------------|---|------------------------------------|
| | <i>Sheltered</i> | | <i>Normal</i> | | <i>Severe</i> | |
| | $\frac{\text{Btu}}{\text{ft}^2 \text{ hr } ^\circ\text{F}}$ | $\frac{\text{W}}{\text{m}^2}$ K | $\frac{\text{Btu}}{\text{ft}^2 \text{ hr } ^\circ\text{F}}$ | $\frac{\text{W}}{\text{m}^2}$ K | $\frac{\text{Btu}}{\text{ft}^2 \text{ hr } ^\circ\text{F}}$ | $\frac{\text{W}}{\text{m}^2}$ K |
| Tiles on battens and roofing felt with rafters and no ceiling below | 0.69 | 3.9 | 0.76 | 4.3 | 0.83 | 4.7 |
| Tiles on battens and boarding with rafters and no ceiling below | 0.53 | 3.0 | 0.58 | 3.3 | 0.63 | 3.6 |
| Tiles on battens only with rafters and no ceiling below | 1.00 | 5.7 | 1.11 | 6.3 | 1.23 | 7.0 |
| Tiles on battens and roofing felt, plasterboard ceiling with fibreglass insulation | | | | | | |
| insulation thickness | | | | | | |
| 50 mm | 0.090 | 0.51 | 0.090 | 0.51 | 0.092 | 0.52 |
| 75 mm | 0.066 | 0.38 | 0.067 | 0.38 | 0.068 | 0.38 |
| 100 mm | 0.053 | 0.30 | 0.053 | 0.30 | 0.053 | 0.30 |
| 150 mm | 0.037 | 0.21 | 0.037 | 0.21 | 0.038 | 0.21 |
| Tiles on roofing felt and battens with boarding, plasterboard ceiling with fibreglass insulation and boarding | | | | | | |
| insulation thickness | | | | | | |
| 50 mm | 0.085 | 0.48 | 0.086 | 0.49 | 0.087 | 0.49 |
| 75 mm | 0.064 | 0.36 | 0.064 | 0.36 | 0.065 | 0.37 |
| 100 mm | 0.051 | 0.29 | 0.051 | 0.29 | 0.052 | 0.29 |
| 150 mm | 0.036 | 0.21 | 0.036 | 0.21 | 0.037 | 0.21 |
| <i>Roof glazing</i> | | | | | | |
| Skylight | 1.00 | 5.7 | 1.20 | 6.8 | 1.40 | 8.0 |
| Laylight with lantern over | 0.57 | 3.2 | 0.60 | 3.4 | 0.63 | 3.6 |
| Filon translucent GRP | | | | | | |
| single skin | 0.89 | 5.0 | 1.0 | 5.7 | 1.20 | 6.7 |
| double skin | 0.47 | 2.6 | 0.57 | 2.8 | 0.54 | 3.0 |

| <i>Floors</i> | | <i>Solid floor with four exposed edges</i> | | <i>Solid floor with two exposed edges</i> | | <i>Suspended floor</i> | |
|---------------|---------------|--|------------------------|---|------------------------|-----------------------------|------------------------|
| <i>Width</i> | <i>Length</i> | <i>Btu</i> | <i>W/m²</i> | <i>Btu</i> | <i>W/m²</i> | <i>Btu</i> | <i>W/m²</i> |
| <i>m</i> | <i>m</i> | <i>ft² hr °F</i> | <i>K</i> | <i>ft² hr °F</i> | <i>K</i> | <i>ft² hr °F</i> | <i>K</i> |
| 60 | over 100 | 0.016 | 0.09 | 0.009 | 0.05 | 0.019 | 0.11 |
| 60 | 100 | 0.021 | 0.12 | 0.012 | 0.07 | 0.025 | 0.14 |
| 60 | 60 | 0.026 | 0.15 | 0.014 | 0.08 | 0.028 | 0.16 |
| 40 | over 100 | 0.021 | 0.12 | 0.012 | 0.07 | 0.026 | 0.15 |
| 40 | 100 | 0.026 | 0.15 | 0.016 | 0.09 | 0.032 | 0.18 |
| 40 | 60 | 0.030 | 0.17 | 0.018 | 0.10 | 0.035 | 0.20 |
| 40 | 40 | 0.037 | 0.21 | 0.021 | 0.12 | 0.039 | 0.22 |
| 20 | over 100 | 0.039 | 0.22 | 0.021 | 0.12 | 0.046 | 0.26 |
| 20 | 100 | 0.042 | 0.24 | 0.025 | 0.14 | 0.049 | 0.28 |
| 20 | 60 | 0.046 | 0.26 | 0.026 | 0.15 | 0.053 | 0.30 |
| 20 | 40 | 0.049 | 0.28 | 0.028 | 0.16 | 0.055 | 0.31 |
| 20 | 20 | 0.063 | 0.36 | 0.037 | 0.21 | 0.065 | 0.37 |
| 10 | 100 | 0.062 | 0.35 | 0.039 | 0.22 | 0.077 | 0.44 |
| 10 | 60 | 0.072 | 0.41 | 0.042 | 0.24 | 0.081 | 0.46 |
| 10 | 40 | 0.076 | 0.43 | 0.044 | 0.25 | 0.083 | 0.47 |
| 10 | 20 | 0.085 | 0.48 | 0.049 | 0.28 | 0.090 | 0.51 |
| 10 | 10 | 0.11 | 0.62 | 0.063 | 0.36 | 0.10 | 0.59 |
| 6 | 40 | 0.10 | 0.59 | 0.062 | 0.35 | 0.11 | 0.63 |
| 6 | 20 | 0.11 | 0.64 | 0.067 | 0.38 | 0.11 | 0.65 |
| 6 | 10 | 0.13 | 0.74 | 0.077 | 0.44 | 0.13 | 0.71 |
| 6 | 6 | 0.16 | 0.91 | 0.095 | 0.54 | 0.14 | 0.79 |
| 4 | 40 | 0.12 | 0.66 | 0.069 | 0.39 | 0.13 | 0.71 |
| 4 | 20 | 0.14 | 0.82 | 0.086 | 0.49 | 0.14 | 0.79 |
| 4 | 10 | 0.16 | 0.90 | 0.095 | 0.54 | 0.15 | 0.83 |
| 4 | 6 | 0.18 | 1.03 | 0.11 | 0.62 | 0.16 | 0.89 |
| 4 | 4 | 0.21 | 1.22 | 0.13 | 0.73 | 0.17 | 0.96 |
| 2 | 20 | 0.18 | 1.03 | 0.13 | 0.75 | 0.17 | 0.96 |
| 2 | 10 | 0.23 | 1.31 | 0.14 | 0.82 | 0.19 | 1.08 |
| 2 | 6 | 0.25 | 1.40 | 0.15 | 0.87 | 0.20 | 1.11 |
| 2 | 4 | 0.27 | 1.52 | 0.17 | 0.95 | 0.20 | 1.15 |
| 2 | 2 | 0.35 | 1.96 | 0.21 | 1.22 | 0.22 | 1.27 |

External resistance R_{S2}

| Orientation | Exposure | | | | | |
|-------------------|--------------------|---------|--------------------|---------|--------------------|---------|
| | Sheltered | | Normal | | Severe | |
| | $ft^2 hr ^\circ F$ | $m^2 K$ | $ft^2 hr ^\circ F$ | $m^2 K$ | $ft^2 hr ^\circ F$ | $m^2 K$ |
| | Btu | W | Btu | W | Btu | W |
| S | 0.73 | 0.128 | 0.57 | 0.100 | 0.43 | 0.076 |
| W, SW, SE | 0.57 | 0.100 | 0.43 | 0.076 | 0.30 | 0.053 |
| NW | 0.43 | 0.076 | 0.30 | 0.053 | 0.18 | 0.032 |
| N, NE, E | 0.43 | 0.076 | 0.30 | 0.053 | 0.07 | 0.012 |
| Horizontal (roof) | 0.40 | 0.070 | 0.25 | 0.044 | 0.10 | 0.018 |

Internal resistance R_{S1}

| | $ft^2 hr ^\circ F$ | $m^2 K$ |
|--------------------|--------------------|---------|
| | Btu | W |
| Walls | 0.70 | 0.123 |
| Floors | 0.85 | 0.150 |
| Ceilings and roofs | 0.60 | 0.106 |

Note: The data for surface resistances are applicable to plain surfaces but not to bright metallic surfaces.

The resistance of a corrugated surface is less than that of a plain one, generally by about 20%.

Thermal resistivity of air spaces

| Material bounding space | resistivity (x/k) in $m^2 K/W$ for thickness of air space in mm | | | | | | | | | |
|-------------------------|---|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| | 15 | 20 | 25 | 35 | 50 | 65 | 75 | 90 | 100 | 115 |
| Glass | 0.141 | 0.145 | 0.148 | 0.155 | 0.165 | 0.172 | 0.176 | 0.183 | 0.186 | 0.188 |
| Brick | 0.150 | 0.153 | 0.158 | 0.165 | 0.175 | 0.185 | 0.190 | 0.197 | 0.200 | 0.203 |


| Material bounding space | resistivity (x/k) in $ft^2 hr ^\circ F/Btu$ for thickness of air space in in | | | | | | | | | | |
|-------------------------|--|---------------|------|----------------|------|----------------|------|----------------|------|----------------|------|
| | $\frac{1}{2}$ | $\frac{3}{4}$ | 1 | $1\frac{1}{2}$ | 2 | $2\frac{1}{2}$ | 3 | $3\frac{1}{2}$ | 4 | $4\frac{1}{2}$ | 5 |
| Glass | 0.79 | 0.82 | 0.85 | 0.89 | 0.94 | 0.97 | 1.00 | 1.04 | 1.06 | 1.07 | 1.08 |
| Brick | 0.84 | 0.87 | 0.90 | 0.95 | 1.04 | 1.04 | 1.08 | 1.11 | 1.14 | 1.16 | 1.17 |

Condensation on glass windows

The chart gives the maximum permissible heat transfer coefficient of the glass necessary to prevent condensation at various indoor and outdoor temperatures and humidity.

Example

Inside temp. 15°C
 Inside rel. humidity 30%
 Outside temps. -5°C



From chart, maximum permissible thermal transmittance coefficient is $7.0 \text{ W/m}^2 \text{ K}$.

Fuel consumption

1 Direct method

$$F = \frac{Hn(t_i - t_a)100}{EC(t_i - t_o)}$$

where

F = fuel consumption during time n (kg)

H = heat loss for temperature difference $(t_i - t_o)$ (kW)

n = time over which fuel consumption is required (s)

E = efficiency of utilisation of fuel (%)

C = calorific value of fuel (kJ/kg)

t_i = inside temperature ($^{\circ}\text{C}$)

t_a = average outside temperature during period considered ($^{\circ}\text{C}$)

t_o = outside design temperature ($^{\circ}\text{C}$)

$$E = E_1 E_2 E_3 E_4$$

where

E_1 = boiler efficiency (60–75%)

E_2 = efficiency of pipework (loss of heat from pipes) (80–90%)

E_3 = efficiency of heaters (90–100%)

E_4 = efficiency of control (loss due to over heating) (80–95%)

E = efficiency of utilisation of fuel (35–65%)

2 Degree day method

Degree days give the extent and length of time that the outdoor temperature is below 15.5°C .

number of degree days in a stated period

= number of days \times (15.5°C – average outdoor temperature $^{\circ}\text{C}$)

$$F = \frac{hD100}{EC}$$

$$h = \frac{24 \times 3600 \times H}{(15.5 - t_o)}$$

where

F = fuel consumption over period considered (kg)

h = heat loss per degree day (kJ/degree day)

E = efficiency of utilisation of fuel, as above (%)

C = calorific value of fuel (kJ/kg)

H = heat loss for design conditions (kW)

t_o = outside design temperature ($^{\circ}\text{C}$)

D = actual number of degree days in period considered (number)

Degree days for United Kingdom

Base temperature 15.5°C

| <i>Region</i> | <i>Month</i> | | | | | | | | | | | | <i>Total</i> |
|------------------------|--------------|-------------|-------------|-------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| | <i>Jan.</i> | <i>Feb.</i> | <i>Mar.</i> | <i>Apr.</i> | <i>May</i> | <i>Jun.</i> | <i>Jul.</i> | <i>Aug.</i> | <i>Sep.</i> | <i>Oct.</i> | <i>Nov.</i> | <i>Dec.</i> | |
| Thames Valley | 346 | 304 | 282 | 197 | 113 | 47 | 24 | 27 | 56 | 132 | 256 | 333 | 2118 |
| South Eastern | 370 | 329 | 310 | 224 | 145 | 74 | 44 | 48 | 84 | 163 | 280 | 356 | 2427 |
| Southern | 339 | 307 | 294 | 214 | 141 | 68 | 41 | 42 | 76 | 145 | 258 | 328 | 2253 |
| South Western | 293 | 272 | 267 | 197 | 131 | 58 | 32 | 30 | 55 | 114 | 215 | 276 | 1940 |
| Severn Valley | 344 | 311 | 292 | 209 | 129 | 56 | 31 | 34 | 69 | 143 | 259 | 328 | 2205 |
| Midland | 371 | 335 | 318 | 233 | 152 | 76 | 46 | 51 | 92 | 172 | 290 | 358 | 2494 |
| West Pennines | 359 | 323 | 304 | 222 | 139 | 66 | 41 | 43 | 79 | 155 | 280 | 346 | 2357 |
| North Western | 366 | 333 | 319 | 239 | 163 | 82 | 55 | 56 | 94 | 169 | 296 | 357 | 2531 |
| Borders | 376 | 343 | 332 | 259 | 193 | 176 | 73 | 72 | 108 | 184 | 300 | 361 | 2718 |
| North Eastern | 374 | 334 | 317 | 234 | 154 | 76 | 48 | 50 | 87 | 171 | 295 | 360 | 2500 |
| East Pennines | 362 | 323 | 304 | 217 | 139 | 66 | 40 | 42 | 77 | 157 | 281 | 350 | 2358 |
| East Anglia | 378 | 334 | 315 | 232 | 143 | 71 | 46 | 43 | 74 | 154 | 283 | 360 | 2433 |
| West Scotland | 368 | 335 | 316 | 235 | 163 | 83 | 61 | 63 | 106 | 179 | 303 | 354 | 2565 |
| East Scotland | 379 | 343 | 326 | 252 | 189 | 100 | 69 | 71 | 106 | 185 | 308 | 368 | 2696 |
| North East Scotland | 396 | 359 | 345 | 270 | 206 | 111 | 85 | 86 | 124 | 199 | 322 | 381 | 2884 |
| Wales | 323 | 301 | 292 | 228 | 156 | 80 | 49 | 43 | 72 | 136 | 239 | 301 | 2220 |
| Northern Ireland | 359 | 325 | 311 | 237 | 167 | 86 | 61 | 63 | 100 | 170 | 288 | 343 | 2510 |

7 Cooling loads

Cooling load for air conditioning consists of:

- conduction and convection through walls, windows, etc.
- absorption of solar radiation on walls, windows, etc.
- heat emission of occupants.
- infiltration of warm outdoor air.
- heat emission of lights and other electrical or mechanical appliances.

1 Heat gain through walls, windows, doors, etc.

$$H = AU(t_o - t_i)$$

where

- H = Heat gained (W)
- A = area of exposed surface (m^2)
- U = coefficient of heat transmission ($W/m^2 K$)
- t_o = outside air temperature ($^{\circ}C$)
- T_i = indoor air temperature ($^{\circ}C$)

Coefficients of heat transmission are the same as for heat losses in winter.

2 Solar radiation

$$H = AF\alpha J$$

where

- H = heat gained (W)
- A = area of exposed surface (m^2)
- F = radiation factor
 - = proportion of absorbed radiation which is transmitted to interior
- α = absorption coefficients
 - = proportion of incident radiation which is absorbed
- J = intensity of solar radiation striking the surface (W/m^2)

3 Heat emission of occupants

Heat and moisture given off by human body; tabulated data.

4 Heat gain by infiltration

$$H = nVd(h_o - h_i)$$

where

H = heat gain (kW)

n = number of air changes (s^{-1})

V = volume of room (m^3)

d = density of air (kg/m^3)

h_o = enthalpy of outdoor air with water vapour (kJ/kg)

h_i = enthalpy of indoor air with water vapour (kJ/kg)

5 Heat emission of appliances

All power consumed is assumed to be dissipated as heat.

heat emission in kW = appliance input rating in kW

Lighting 10–14 W/m²

Small power, including IT equipment 10–25 W/m²

Design summer indoor conditions

Optimum temperature 20°C to 22°C

Optimum relative humidity 40% to 65%


Desirable indoor conditions in summer for exposures less than 3 hours

| Outside dry bulb temp. | Inside air conditions with dewpoint constant at 14°C | | |
|---------------------------|--|----------|-------------------|
| | Dry bulb | Wet bulb | Relative humidity |
| °C | °C | °C | % |
| 35 | 27 | 18.5 | 44 |
| 32 | 26 | 18.0 | 46 |
| 29 | 25 | 17.8 | 52 |
| 27 | 24 | 17.5 | 51 |
| 24 | 23 | 17.2 | 57 |
| 21 | 22 | 17.0 | 57 |

Relation of effective temperature, to dry and wet bulb temperatures and humidity, with summer and winter comfort zones

Charts for velocities up to 0.1m/s i.e. practically still air.

For an air velocity of 0.4m/s the effective temperature decreases by 1°C.



Radiation factor (F)

Proportion of radiation absorbed by wall transmitted to interior.

| <i>U-value of wall</i> | | <i>U-value of wall</i> | |
|------------------------|----------|------------------------|----------|
| $W/m^2 K$ | <i>F</i> | $W/m^2 K$ | <i>F</i> |
| 0.15 | 0.006 | 2.5 | 0.10 |
| 0.25 | 0.01 | 3.0 | 0.12 |
| 0.5 | 0.02 | 3.5 | 0.14 |
| 1.0 | 0.04 | 4.0 | 0.16 |
| 1.5 | 0.06 | 4.5 | 0.18 |
| 2.0 | 0.08 | 5.0 | 0.20 |

For glass, proportion of incident radiation transmitted plus proportion absorbed and transmitted = 0.84

For translucent Filon sheeting, proportion of incident radiation transmitted plus proportion absorbed and transmitted = 0.72 for natural sheet or 0.43 for white tint sheet

Absorption coefficient (α)

Proportion of radiation falling on wall absorbed by it.

| <i>Type of surface</i> | α |
|---|----------|
| Very light surface, white stone, light cement | 0.4 |
| Medium dark surface, unpainted wood, brown stone, brick, red tile | 0.7 |
| Very dark surface, slate roofing, very dark paints | 0.9 |

Time lag in transmission of solar radiation through walls

| <i>Type of wall</i> | <i>Time lag hours</i> |
|--|-----------------------|
| 150 mm concrete | 3 |
| 100 mm lightweight blocks | $2\frac{1}{2}$ |
| 560 mm brick | 10 |
| 75 mm concrete with 25 mm thermal insulation board | 2 |
| 50 mm timber | $1\frac{1}{2}$ |

Transmission of radiation through shaded windows

| <i>Type of shading</i> | <i>Proportion transmitted</i> |
|---|-------------------------------|
| Canvas awning, plain | 0.28 |
| Canvas awning, aluminium bands | 0.22 |
| Inside shade, fully drawn | 0.45 |
| Inside shade, half drawn | 0.68 |
| Inside Venetian blind, slats at 45°, aluminium | 0.58 |
| Outside Venetian blind, slats at 45°, aluminium | 0.22 |

Intensity of solar radiation

For latitude 45°

| <i>Solar time</i> | <i>Intensity of solar radiation for orientation (W/m²)</i> | | | | | | | |
|-------------------|---|----------|-----------|----------|-----------|----------|-----------|-------------------|
| | <i>NE</i> | <i>E</i> | <i>SE</i> | <i>S</i> | <i>SW</i> | <i>W</i> | <i>NW</i> | <i>Horizontal</i> |
| 5 | 79 | 75 | 28 | | | | | 6 |
| 6 | 281 | 312 | 164 | | | | | 82 |
| 7 | 470 | 612 | 394 | | | | | 284 |
| 8 | 441 | 691 | 539 | 69 | | | | 492 |
| 9 | 290 | 612 | 577 | 205 | | | | 663 |
| 10 | 104 | 455 | 539 | 309 | | | | 791 |
| 11 | | 237 | 438 | 382 | 101 | | | 864 |
| 12 | | | 287 | 404 | 287 | | | 890 |
| 13 | | | 101 | 382 | 438 | 237 | | 864 |
| 14 | | | | 309 | 539 | 455 | 104 | 791 |
| 15 | | | | 205 | 577 | 612 | 290 | 663 |
| 16 | | | | 69 | 539 | 691 | 441 | 492 |
| 17 | | | | | 394 | 612 | 470 | 284 |
| 18 | | | | | 164 | 312 | 281 | 82 |

Heat emitted by human body (light office or domestic work)

Still air

| <i>Air temperature</i> | (°C) | 10 | 12 | 14 | 16 | 18 | 20 | 22 | 24 | 26 | 28 | 30 | 32 |
|------------------------|--------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Sensible heat | (W) | 136 | 126 | 115 | 106 | 98 | 92 | 85 | 77 | 69 | 58 | 47 | 33 |
| Latent heat | (W) | 21 | 21 | 21 | 21 | 23 | 27 | 33 | 41 | 49 | 60 | 69 | 81 |
| Total | (W) | 157 | 147 | 136 | 127 | 121 | 119 | 118 | 118 | 118 | 118 | 116 | 114 |
| Moisture | (g/hr) | 31 | 31 | 31 | 31 | 34 | 40 | 48 | 60 | 73 | 88 | 102 | 120 |

Air velocity 1 M/S

| <i>Air temperature</i> | (°C) | 10 | 12 | 14 | 16 | 18 | 20 | 22 | 24 | 26 | 28 | 30 | 32 |
|------------------------|--------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Sensible heat | (W) | 152 | 142 | 131 | 122 | 112 | 104 | 97 | 88 | 81 | 69 | 55 | 38 |
| Latent heat | (W) | 19 | 19 | 19 | 19 | 19 | 20 | 25 | 32 | 38 | 49 | 61 | 77 |
| Total | (W) | 171 | 161 | 150 | 143 | 131 | 124 | 122 | 120 | 119 | 118 | 116 | 115 |
| Moisture | (g/hr) | 28 | 28 | 28 | 28 | 28 | 29 | 36 | 47 | 57 | 73 | 89 | 114 |

8

Heating systems

Hot water heating

Hot water carries heat through pipes from the boiler to room or space heaters.

Classification by pressure

| <i>Type</i> | <i>Abbreviation</i> | <i>Flow temp.</i> °C | <i>Temp. drop</i> °C |
|--------------------------------|---------------------|-------------------------|-------------------------|
| Low pressure hot water heating | LPHW | | |
| (a) pumped circulation | | 50–90 | 10–15 |
| (b) gravity circulation | | 90 | 20 |
| Medium pressure hot water | MPHW | 90–120 | 15–35 |
| High pressure hot water | MPHW | 120–200 | 27–85 |

Classification by pipe system

One-pipe or two-pipe system }
Up-feed or down-feed system } See typical schemes on page 120.

Design procedure for hot water heating system

- 1 Heat losses of rooms to be heated.
- 2 Boiler output.
- 3 Selection of room heating units.
- 4 Type, size and duty of circulating pump.
- 5 Pipe scheme and pipe sizes.
- 6 Type and size of expansion tank.

1 Heat losses

Calculated with data in section 6.

2 Boiler

$$B = H(1+X)$$

where

B = boiler rating (kW)

H = total heat loss of plant (kW)


X = margin for heating up (0.10 to 0.15)

Boilers with correct rating to be selected from manufacturers' catalogues.


HOT WATER PIPE SYSTEMS

1 PUMPED SYSTEMS


(a) OPEN EXPANSION TANK



(i) ONE-PIPE SYSTEM




(ii) TWO-PIPE SYSTEM




(iii) REVERSE RETURN TOTAL LENGTH OF FLOW IS THE SAME THROUGH ALL RADIATORS

(b) CLOSED EXPANSION TANK




TWO-PIPE SYSTEM TAKEN AS EXAMPLE OTHER SYSTEMS ALSO POSSIBLE WITH EXPANSION TANK IN SAME RELATIVE POSITION


(c) COMBINED HEATING AND HOT WATER SYSTEM




2 GRAVITY SYSTEMS




(i) TWO-PIPE UPFEED SYSTEM




(ii) TWO-PIPE DROP SYSTEM




(iii) ONE-PIPE DROP SYSTEM



(iv) TWO-PIPE DROP SYSTEM WITH BOILER AND RADIATORS AT SAME LEVEL



(v) ONE-PIPE RING MAIN SYSTEM



(vi) TWO-PIPE REVERSE RETURN RING MAIN SYSTEM

[F.E.] FEED & EXPANSION TANK

[C.W.] COLD WATER TANK

[C] HOT WATER CALORIFIER

[X] VALVE
[E] CLOSED EXPANSION VESSEL
[R] RADIATOR

[P] PUMP

[B] BOILER

3 Room heaters

$$R = H(1+X)$$

where

- R = rating of heaters in room (W)
- H = heat loss of room (W)
- X = margin for heating up (0.10 to 0.15)

Heaters with correct rating to be selected from manufacturers' catalogues.

4 Pump size

$$Q = \frac{H}{(h_1 - h_2)d}$$

where

- Q = volume of water (m^3/s)
- H = total heat loss of plant (kW)
- h_1 = enthalpy of flow water (kJ/kg)
- h_2 = enthalpy of return water (kJ/kg)
- d = density of water at pump (kg/m^3)

For LPHW this reduces to

$$Q = \frac{H}{4.185(t_1 - t_2)}$$

where

- t_1 = flow temperature ($^{\circ}\text{C}$)
- t_2 = return temperature ($^{\circ}\text{C}$)

Pump head is chosen to give reasonable pipe sizes according to extent of system.

For LPHW 10 to 60 kN/m^2 with pipe friction resistance 80 to 250 N/m^2 per m run.

For HPHW 60 to 250 kN/m^2 with pipe friction resistance 100 to 300 N/m^2 per m run.

Gravity systems

$$p = hg(\rho_2 - \rho_1)$$

where

- p = circulating pressure available (N/m^2)
- h = height between centre of boiler and centre of radiator (m)
- ρ_1 = density of water at flow temperature (kg/m^3)
- ρ_2 = density of water at return temperature (kg/m^3)
- g = acceleration of gravity = 9.81 (m/s^2)

5 Pipe sizes

$$p_T = p_1 + p_2$$

$$p_1 = il$$

$$p_2 = \sum F \frac{V^2}{2}$$

alternatively,

$$p_2 = \sum l_E$$

where

p_T = total pressure loss in system (N/m^2)

p_1 = pressure loss in pipes due to friction (N/m^2)

p_2 = pressure loss in fittings (N/m^2)

i = pipe friction resistance per length (N/m^2 per m run)

l = length of pipe (m)

F = coefficient of resistance

V = velocity of water (m/s)

ρ = density of water (kg/m^3)

l_E = equivalent length of fitting (m)

i can be obtained from Chart 1.

Typical values of p_2/p_1

| | |
|------------------------------------|--------------|
| Heating installations in buildings | 0.40 to 0.50 |
| District heating mains | 0.10 to 0.30 |
| Heating mains within boiler rooms | 0.70 to 0.90 |

6 Expansion tank

(a) *Open tank* (For LPHW only)

Expansion of water from 7°C to 100°C = approx. 4%.

Requisite volume of expansion tank = $0.08X$ water contents of system. Water content for typical system is approximately 1 litre for every 1 m^2 of radiator surface.

(b) *Closed tank*

$$V_t = V_e \frac{p_w}{p_w - p_i} \quad V_e = V_w \frac{\rho_1 - \rho_2}{\rho_2}$$

where

V_t = volume of tank (m^3)

V_e = volume by which water content expands (m^3)

V_w = volume of water in system (m^3)

p_w = pressure (absolute) of tank at working temperature (kN/m^2)

p_i = pressure (absolute) of tank when filled cold (kN/m^2)

ρ_1 = density of water at filling temperature (kg/m^3)

ρ_2 = density of water at working temperature (kg/m^3)

p_w to be selected so that working pressure at highest point of system corresponds to a boiling point approximately 10 K above working temperature.

p_w = working pressure at highest point + static pressure difference between highest point and tank \pm pump pressure (+ or - according to position of pump).

Either p_1 or V_t can be chosen independently to determine value of the other.

Approximate size of expansion tank for LPHW

| <i>Boiler rating</i> | <i>Tank size</i> | | <i>Ball valve size</i> | <i>Cold feed size</i> | <i>Open vent size</i> | <i>Overflow size</i> |
|----------------------|------------------|----------------|------------------------|-----------------------|-----------------------|----------------------|
| <i>kw</i> | <i>litre</i> | <i>BS Ref.</i> | <i>mm n.b.</i> | <i>mm n.b.</i> | <i>mm n.b.</i> | <i>mm n.b.</i> |
| 12 | 54 | SCM 90 | 15 | 20 | 25 | 25 |
| 25 | 54 | SCM 90 | 15 | 20 | 25 | 32 |
| 30 | 68 | SCM 110 | 15 | 20 | 25 | 32 |
| 45 | 68 | SCM 110 | 15 | 20 | 25 | 32 |
| 55 | 86 | SCM 135 | 15 | 20 | 25 | 32 |
| 75 | 114 | SCM 180 | 15 | 25 | 32 | 32 |
| 150 | 191 | SCM 270 | 15 | 25 | 32 | 32 |
| 225 | 227 | SCM 320 | 20 | 32 | 40 | 40 |
| 275 | 264 | SCM 360 | 20 | 32 | 40 | 40 |
| 375 | 327 | SCM 450/1 | 20 | 40 | 50 | 40 |
| 400 | 336 | SCM 450/2 | 20 | 40 | 50 | 50 |
| 550 | 423 | SCM 570 | 25 | 40 | 50 | 50 |
| 800 | 709 | SCM 910 | 25 | 50 | 65 | 50 |
| 900 | 841 | SCM 1130 | 25 | 50 | 65 | 65 |
| 1200 | 1227 | SCM 1600 | 25 | 50 | 65 | 65 |

Safety valves

Safety valve setting = pressure on outlet side of pump + 70 kN/m².

For gravity systems, safety valve setting = pressure in system + 15 kN/m².

To prevent leakage due to shocks in system, it is recommended that the setting should be not less than 240 kN/m².

Valves should have clearances to allow a lift of $\frac{1}{5}$ × diameter.

Safety valve sizes for water boilers

| <i>Boiler rating</i> | <i>Minimum clear bore of safety valves and vents</i> |
|----------------------|--|
| <i>kW</i> | <i>mm</i> |
| 275 | 1×20 |
| 350 | 1×25 |
| 440 | 1×32 |
| 530 | 1×40 |
| 880 | 2×40 |
| 1500 | 80 to 150 |

Recommended flow temperatures for LPHW systems

| | | | | | | |
|-------------------------|----|----|----|----|----|----|
| Outside temperature | °C | 0 | 2 | 4 | 7 | 10 |
| Boiler flow temperature | °C | 80 | 70 | 56 | 45 | 37 |










Resistance of fittings for LPHW pipe systems

Values of F for different fittings

| | | | |
|------------------------|-----|-------------------|-----|
| Radiators | 3.0 | Tee, straight way | 1.0 |
| Boilers | 2.5 | branch | 1.5 |
| Abrupt velocity change | 1.0 | counter current | 3.0 |
| Cross-over | 0.5 | | |

| | | <i>Nominal bore mm</i> | | | | | |
|-----------------|----------|------------------------|-----------|-----------|-----------|-----------|-----------|
| <i>Fitting</i> | | <i>15</i> | <i>20</i> | <i>25</i> | <i>32</i> | <i>40</i> | <i>50</i> |
| Radiator valve: | angle | 7 | 4 | 4 | 4 | — | — |
| | straight | 4 | 2 | 2 | 2 | — | — |
| Gate valve: | screwed | 1.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| | flanged | 0 | 0 | 0 | 0 | 0 | 0 |
| Elbow | | 2 | 2 | 1.5 | 1.5 | 1.0 | 1.0 |
| Bend | | 1.5 | 1.5 | 1.0 | 1.0 | 0.5 | 0.5 |

Resistance of valves and fittings to flow of fluids in terms of equivalent length of straight pipe

| | | <i>Nominal diameter</i> | | | | | | | | | | |
|--|-----------------------------|-------------------------|---------------|------|----------------|----------------|------|----------------|------|------|-----|-----|
| <i>Description of fitting</i> | <i>in</i> | $\frac{1}{2}$ | $\frac{3}{4}$ | 1 | $1\frac{1}{4}$ | $1\frac{1}{2}$ | 2 | $2\frac{1}{2}$ | 3 | 4 | 5 | 6 |
| | <i>mm</i> | 15 | 20 | 25 | 32 | 40 | 50 | 65 | 80 | 100 | 125 | 150 |
| Globe Valve | E.L. ft | 13 | 16 | 26 | 35 | 40 | 55 | 65 | 80 | | | |
| | m | 4 | 5 | 8 | 11 | 12 | 17 | 20 | 24.5 | | | |
| Angle Valve | E.L. ft | 8 | 11 | 15 | 18 | 20 | 27 | 32 | 40 | | | |
| | m | 2.5 | 3.5 | 4.5 | 5.5 | 6 | 8.3 | 10 | 12 | | | |
| Gate Valve | E.L. ft | 0.3 | 0.5 | 0.5 | 0.5 | 1 | 1 | 1.5 | 2 | 2.5 | 3 | 3 |
| | m | 0.09 | 0.15 | 0.15 | 0.15 | 0.3 | 0.3 | 0.45 | 0.6 | 0.75 | 0.9 | 0.9 |
| Elbow | E.L. ft | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 8 | 11 | 13 | 17 |
| | m | 0.3 | 0.6 | 0.6 | 0.9 | 1.2 | 1.5 | 1.8 | 2.5 | 3.5 | 4 | 5.2 |
| Long Sweep Elbow | E.L. ft | 1 | 1.5 | 2 | 2.5 | 3 | 3 | 5 | 4 | 6 | 8 | 10 |
| | m | 0.3 | 0.45 | 0.6 | 0.75 | 0.9 | 1.0 | 1.2 | 1.5 | 1.8 | 2.5 | 3.0 |
| Run of Tee  | E.L. ft | 1 | 1.5 | 2.5 | 2.5 | 3 | 3 | 4 | 5 | 6 | 8 | 10 |
| | m | 0.3 | 0.45 | 0.75 | 0.8 | 0.9 | 1.0 | 1.2 | 1.5 | 1.8 | 2.5 | 3.0 |
| Run of Tee, reduced to $\frac{1}{2}$ | E.L. ft | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 8 | 11 | 13 | 17 |
| | m | 0.3 | 0.5 | 0.7 | 0.9 | 1.2 | 1.5 | 1.8 | 2.5 | 3.5 | 4 | 5.2 |
| Branch of Tee  | E.L. ft | 3.5 | 5 | 6 | 8 | 10 | 13 | 15 | 18 | 24 | 30 | 35 |
| | m | 1.1 | 1.5 | 1.8 | 2.5 | 3.0 | 4 | 4.5 | 5.5 | 7.3 | 9 | 11 |
| Sudden Enlargement  | $\frac{d}{D} = \frac{1}{4}$ | E.L. ft | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 8 | 11 | 13 |
| | m | 0.3 | 0.5 | 0.7 | 0.9 | 1.2 | 1.5 | 1.8 | 2.5 | 3.5 | 4 | 5.2 |
|  | $\frac{d}{D} = \frac{1}{2}$ | E.L. ft | 1 | 1.5 | 2 | 2.5 | 3 | 3.5 | 4 | 5 | 7 | 9 |
| | m | 0.3 | 0.45 | 0.6 | 0.75 | 0.9 | 1.1 | 1.2 | 1.5 | 2.1 | 2.7 | 3.5 |
|  | $\frac{d}{D} = \frac{3}{4}$ | E.L. ft | 0.3 | 0.5 | 0.5 | 1 | 1 | 1 | 1.5 | 2 | 2.3 | 3 |
| | m | 0.09 | 0.15 | 0.15 | 0.25 | 0.3 | 0.35 | 0.45 | 0.6 | 0.75 | 0.9 | 1.0 |
| Sudden Contraction  | $\frac{d}{D} = \frac{1}{4}$ | E.L. ft | 0.8 | 1.0 | 1.2 | 1.5 | 2.0 | 2.5 | 3 | 4 | 5 | 6 |
| | m | 0.25 | 0.3 | 0.35 | 0.45 | 0.6 | 0.75 | 0.9 | 1.2 | 1.5 | 1.8 | 2.5 |
|  | $\frac{d}{D} = \frac{1}{2}$ | E.L. ft | 0.5 | 0.8 | 1.0 | 1.2 | 1.5 | 2 | 2 | 3 | 4 | 5 |
| | m | 0.15 | 0.25 | 0.3 | 0.35 | 0.45 | 0.6 | 0.6 | 0.9 | 1.2 | 1.5 | 1.8 |
|  | $\frac{d}{D} = \frac{3}{4}$ | E.L. ft | 0.4 | 0.5 | 0.6 | 1.0 | 1.0 | 1.5 | 1.5 | 2.0 | 2.5 | 3 |
| | m | 0.12 | 0.15 | 0.18 | 0.3 | 0.3 | 0.4 | 0.5 | 0.6 | 0.8 | 0.9 | 1.1 |
| Ordinary Entrance  | E.L. ft | 1 | 1 | 1.5 | 2 | 2.5 | 3 | 3.5 | 4.5 | 6 | 8 | 10 |
| | m | 0.3 | 0.3 | 0.45 | 0.6 | 0.75 | 0.9 | 11 | 1.4 | 1.8 | 2.5 | 3.0 |

Circulating pressures for gravity heating

Pressure in N/m^2 per m circulating height

| <i>Return temp.</i> (°C) | <i>Flow temperature (°C)</i> | | | | | | | |
|-----------------------------|------------------------------|-----|-----|-----|-----|-----|----|----|
| | 95 | 90 | 85 | 80 | 75 | 70 | 65 | 60 |
| 50 | 257 | 223 | 190 | 159 | 129 | 101 | 74 | 39 |
| 55 | 332 | 200 | 168 | 136 | 106 | 97 | 50 | 24 |
| 60 | 209 | 176 | 143 | 112 | 82 | 53 | 26 | — |
| 65 | 183 | 150 | 117 | 87 | 56 | 27 | — | — |
| 70 | 156 | 123 | 90 | 59 | 28 | — | — | — |
| 75 | 127 | 94 | 61 | 30 | — | — | — | — |
| 80 | 98 | 64 | 31 | — | — | — | — | — |
| 85 | 66 | 32 | — | — | — | — | — | — |

Head in inches water gauge per foot circulating height

| <i>Return temp.</i> (°F) | <i>Flow temperature (°F)</i> | | | | | | |
|-----------------------------|------------------------------|-------|-------|-------|-------|-------|-------|
| | 200 | 190 | 180 | 170 | 160 | 150 | 140 |
| 120 | 0.324 | 0.277 | 0.230 | 0.187 | 0.145 | 0.104 | 0.068 |
| 130 | 0.293 | 0.244 | 0.198 | 0.153 | 0.111 | 0.070 | 0.035 |
| 140 | 0.258 | 0.210 | 0.163 | 0.118 | 0.077 | 0.036 | — |
| 150 | 0.221 | 0.172 | 0.126 | 0.081 | 0.040 | — | — |
| 160 | 0.181 | 0.133 | 0.086 | 0.040 | — | — | — |
| 170 | 0.140 | 0.090 | 0.044 | — | — | — | — |
| 180 | 0.096 | 0.046 | — | — | — | — | — |
| 190 | 0.048 | — | — | — | — | — | — |

Boiler and radiators at same level

Circulating pressure in N/m^2 for 90°C flow temperature 70°C return, return downcomers bare.

| <i>Horizontal extent of plant (m)</i> | <i>Horizontal distance of downcomer from main riser (m)</i> | | | | | | |
|---------------------------------------|---|------|-------|-------|-------|-------|-------|
| | 5 | 5-10 | 10-15 | 15-20 | 20-30 | 30-40 | 40-50 |
| Up to 10 | 69 | 177 | — | — | — | — | — |
| 10-15 | 69 | 108 | 147 | 196 | 245 | — | — |
| 25-50 | 49 | 78 | 108 | 137 | 177 | 235 | 294 |

Head in inches water gauge for 195°F flow temperature, 160°F return, return downcomers bare.

| <i>Horizontal extent of plant (ft)</i> | <i>Horizontal distance of downcomer from main riser (ft)</i> | | | | | | |
|--|--|-------|-------|-------|-------|--------|---------|
| | 16 | 16-32 | 32-48 | 48-64 | 64-96 | 96-125 | 125-160 |
| Up to 32 | 0.275 | 0.710 | — | — | — | — | — |
| 32-82 | 0.275 | 0.430 | 0.600 | 0.800 | 1.00 | — | — |
| 82-164 | 0.200 | 0.310 | 0.430 | 0.550 | 0.710 | 0.950 | 1.180 |

Underfloor heating

Underfloor heating uses pipes embedded in the floor structure. The pipes carry hot water which can be provided by any of the usual sources. Heat is transferred from the pipes to the floor and the room or space is heated by low temperature radiation from the entire surface of the floor.


Proprietary systems are available from a number of manufacturers.

Pipe material:


Plastic, e.g. polyamide base thermoplastic or cross-linked polyethylene.

Pipe arrangement:

Continuous loops or modules between flow and return pipes.



CONTINUOUS LOOP
ARRANGEMENT



MODULAR ARRANGEMENT

Pipe sizes:

Small bore, 10 mm nb to 22 mm nb

Pipe spacing:

300 mm centres

Flow temperature:

38°C to 60°C

Temperature drop:

5 to 15 K

Floor surface temperature:


2 to 4 K above room temperature, dependent on floor finish and covering

Output:

70 to 130 W/m²

Layout of pipes is generally determined by manufacturer or supplier of proprietary system. Installation by heating contractor in accordance with supplier's recommendations.

Individual loops or sections connected to common flow and return manifolds. A pump and mixing valve are included in the manifold assembly. Control is by mixing valve actuated in accordance with signals from a room thermostat and water flow and return temperature detectors. If required, loops from common manifolds can be controlled individually by thermostatic valves. Manifold assemblies and controls are normally included in the proprietary manufacturer's supply.



ASSEMBLY TO BE POSITIONED ABOVE
FLOOR LEVEL IN CUPBOARD, STORE, OR
OTHER SUITABLE LOCATION

TYPICAL MANIFOLD ASSEMBLY**Advantages:**


- Even heating, small temperature gradient through room.
- Loops can be arranged to overcome down draughts at windows.
- No wall space taken up.
- No high temperature surfaces, therefore safer for children, the elderly and the infirm.
- No convection currents, no staining of decorations, reduced air infiltration and therefore lower heat loss.
- Larger lower temperature heating surface produces comfort at lower air temperature (about 2 K), therefore reduced heating requirement.
- Low flow temperature makes system suitable for condensing boilers.
- Rapid response to thermostatic control.

Disadvantages:


- Extra insulation needed on underside of floor.
- Floor construction may have to be heavier and deeper than would otherwise be necessary.
- Difficult to modify after installation.
- Higher capital cost than radiator system.

Applications:


Hospitals, housing, old people's homes, sports halls, assembly halls.



TYPICAL CONSTRUCTION WITH CONCRETE FLOOR



WITH METAL HEAT DIFFUSION PLATES



WITH GROUT OR PUG FOR HEAT DIFFUSION

TYPICAL CONSTRUCTIONS WITH TIMBER FLOORS

Off peak (storage) heating

Electricity is used during off peak periods to heat thermal stores from which the heat is then extracted during periods when heat is required. The stores are usually made of stone or artificial blocks having a high specific heat capacity.

Rating of unit

$$Q_1 = \frac{100 Q_2 T_2}{\eta T_1}$$

where

- Q_1 = input rating of unit (kW)
- Q_2 = heat output required (kW)
- T_1 = duration of input to unit (hr)
- T_2 = duration of heating period (hr)
- η = storage efficiency (%)

The storage efficiency allows for loss of heat from the store during the charging period. It is 90–95%.

Electrode systems

For large plants electrode boilers with water as a storage medium may be used.

Safe storage temperature is approximately 10°C below the boiling temperature at the operating pressure.

Capacity of storage vessel

$$V = \frac{1000 H}{4.2 \rho (t_1 - t_2)}$$

where

- V = capacity of vessel (litre)
- H = heat to be stored (kJ)
- ρ = density of water at storage temp. (kg/m³)
- t_1 = storage temperature (°C)
- t_2 = return temperature (°C)

Boiler rating

$$Q = \frac{H}{3600 T}$$

where

- Q = boiler rating (kW)
- H = heat to be stored (kJ)
- T = duration of boiler operation (hr)

High temperature H.W. heating

| Return temp. (°C) | Flow temperature (°C) | | | | | | | | | | | | | | | | | | | | | |
|-------------------|-----------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| | 210 | 200 | 195 | 190 | 185 | 180 | 175 | 170 | 165 | 160 | 155 | 150 | 145 | 140 | 135 | 130 | 125 | 120 | 115 | 110 | 105 | 100 |
| 75 | 569 | 538 | 516 | 493 | 471 | 449 | 427 | 405 | 383 | 351 | 340 | 318 | 297 | 275 | 254 | 232 | 220 | 190 | 170 | 147 | 126 | 105 |
| 80 | 547 | 516 | 494 | 471 | 449 | 427 | 405 | 383 | 361 | 339 | 318 | 296 | 275 | 253 | 232 | 210 | 198 | 168 | 145 | 125 | 104 | 83 |
| 85 | 527 | 496 | 474 | 451 | 429 | 407 | 385 | 363 | 341 | 319 | 300 | 278 | 255 | 233 | 212 | 190 | 178 | 148 | 127 | 105 | 84 | 63 |
| 90 | 506 | 475 | 453 | 430 | 408 | 396 | 374 | 342 | 320 | 298 | 277 | 255 | 234 | 212 | 191 | 169 | 158 | 127 | 106 | 85 | 63 | 42 |
| 95 | 495 | 454 | 432 | 409 | 387 | 365 | 342 | 321 | 299 | 277 | 256 | 234 | 213 | 191 | 170 | 148 | 136 | 106 | 85 | 63 | 42 | 21 |
| 100 | 464 | 433 | 411 | 388 | 366 | 344 | 322 | 300 | 278 | 256 | 255 | 213 | 192 | 170 | 149 | 127 | 115 | 85 | 64 | 42 | 21 | |
| 105 | 443 | 412 | 390 | 367 | 345 | 323 | 301 | 279 | 257 | 235 | 214 | 192 | 171 | 149 | 128 | 106 | 94 | 64 | 43 | 21 | | |
| 110 | 422 | 391 | 369 | 346 | 324 | 302 | 280 | 258 | 236 | 214 | 193 | 171 | 150 | 128 | 107 | 85 | 73 | 43 | 22 | | | |
| 115 | 400 | 369 | 347 | 324 | 302 | 280 | 258 | 236 | 214 | 192 | 171 | 150 | 128 | 106 | 85 | 63 | 51 | 21 | | | | |
| 120 | 379 | 348 | 327 | 303 | 281 | 259 | 237 | 215 | 193 | 171 | 150 | 128 | 107 | 85 | 64 | 42 | 21 | | | | | |
| 125 | 349 | 317 | 296 | 273 | 251 | 229 | 207 | 185 | 163 | 141 | 120 | 98 | 77 | 55 | 33 | 21 | | | | | | |
| 130 | 337 | 306 | 284 | 259 | 239 | 217 | 195 | 173 | 151 | 129 | 108 | 86 | 65 | 43 | 22 | | | | | | | |
| 135 | 315 | 284 | 262 | 239 | 217 | 195 | 173 | 151 | 129 | 108 | 86 | 65 | 43 | 22 | | | | | | | | |
| 140 | 294 | 263 | 241 | 218 | 196 | 174 | 151 | 130 | 108 | 86 | 65 | 43 | 22 | | | | | | | | | |
| 145 | 272 | 241 | 219 | 196 | 174 | 152 | 130 | 108 | 86 | 64 | 43 | 21 | | | | | | | | | | |
| 150 | 251 | 220 | 198 | 175 | 153 | 131 | 109 | 87 | 65 | 43 | 22 | | | | | | | | | | | |
| 155 | 229 | 198 | 176 | 153 | 131 | 109 | 87 | 65 | 43 | 21 | | | | | | | | | | | | |
| 160 | 208 | 177 | 155 | 132 | 110 | 88 | 66 | 44 | 22 | | | | | | | | | | | | | |
| 165 | 186 | 155 | 133 | 110 | 88 | 66 | 44 | 22 | | | | | | | | | | | | | | |
| 170 | 124 | 133 | 111 | 88 | 66 | 44 | 22 | | | | | | | | | | | | | | | |
| 175 | 142 | 111 | 89 | 66 | 44 | 22 | | | | | | | | | | | | | | | | |
| 180 | 122 | 89 | 67 | 43 | 22 | | | | | | | | | | | | | | | | | |
| 185 | 98 | 67 | 45 | 22 | | | | | | | | | | | | | | | | | | |
| 190 | 76 | 45 | 23 | | | | | | | | | | | | | | | | | | | |
| 195 | 53 | 22 | | | | | | | | | | | | | | | | | | | | |
| 200 | 31 | | | | | | | | | | | | | | | | | | | | | |

Example: Flow temperature = 180°C
 Return temperature = 130°C
 Heat given up by 1 kg of water 217 kJ

Heat in kJ given up by 1 kg of water for various temperature drops

High temperature H.W. heating

| Return temp. (°F) | Flow temperature (°F) | | | | | | | | | | | | | | | | | | | |
|-------------------|-----------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|------|------|------|------|------|-----|
| | 400 | 390 | 380 | 370 | 360 | 350 | 340 | 330 | 320 | 310 | 300 | 290 | 280 | 270 | 260 | 250 | 240 | 230 | 220 | 210 |
| 170 | 237.3 | 226.3 | 215.5 | 204.9 | 194.3 | 183.7 | 173.1 | 162.6 | 152.2 | 141.8 | 131.5 | 121.2 | 110.9 | 100.7 | 90.5 | 80.4 | 70.3 | 60.2 | 50.1 | 40 |
| 180 | 227.3 | 216.3 | 205.5 | 194.9 | 184.3 | 173.7 | 163.1 | 152.6 | 142.2 | 131.8 | 121.5 | 111.2 | 100.9 | 90.7 | 80.5 | 70.4 | 60.3 | 50.2 | 40.1 | 30 |
| 190 | 217.3 | 206.3 | 195.5 | 184.9 | 174.3 | 163.7 | 153.1 | 142.6 | 132.2 | 121.8 | 111.5 | 101.2 | 90.9 | 80.7 | 70.5 | 60.4 | 50.3 | 40.2 | 30.1 | 20 |
| 200 | 207.3 | 196.3 | 185.5 | 174.9 | 164.3 | 153.7 | 143.1 | 132.6 | 122.2 | 111.8 | 101.5 | 91.2 | 80.9 | 70.7 | 60.5 | 50.4 | 40.3 | 30.2 | 20.1 | 10 |
| 210 | 197.3 | 186.3 | 175.5 | 164.9 | 154.3 | 143.7 | 133.1 | 122.6 | 112.2 | 101.8 | 91.5 | 81.2 | 70.9 | 60.7 | 50.5 | 40.4 | 30.3 | 20.2 | 10.1 | |
| 220 | 187.3 | 176.2 | 165.4 | 154.8 | 144.2 | 133.6 | 123.0 | 112.5 | 102.1 | 91.7 | 81.4 | 71.1 | 60.8 | 50.6 | 40.4 | 30.3 | 20.2 | 10.1 | | |
| 230 | 177.1 | 166.1 | 155.3 | 144.7 | 134.1 | 123.6 | 112.9 | 102.4 | 92.0 | 81.6 | 71.3 | 60.0 | 50.7 | 40.5 | 30.3 | 20.2 | 10.1 | | | |
| 240 | 167.0 | 156.0 | 145.2 | 134.6 | 124.0 | 113.4 | 102.8 | 92.3 | 81.9 | 71.5 | 61.2 | 50.9 | 40.6 | 30.4 | 20.2 | 10.1 | | | | |
| 250 | 156.3 | 145.9 | 135.1 | 124.5 | 113.9 | 103.3 | 92.7 | 82.2 | 71.8 | 61.4 | 51.1 | 40.8 | 30.5 | 20.3 | 10.1 | | | | | |
| 260 | 146.7 | 135.7 | 124.9 | 114.3 | 103.7 | 93.1 | 82.5 | 72.0 | 61.6 | 51.2 | 40.9 | 30.6 | 20.3 | 10.2 | | | | | | |
| 270 | 136.6 | 125.6 | 114.8 | 104.2 | 93.6 | 83.0 | 72.4 | 61.9 | 51.5 | 41.1 | 30.8 | 20.5 | 10.2 | | | | | | | |
| 280 | 126.4 | 115.4 | 104.6 | 94.0 | 83.4 | 72.8 | 61.2 | 51.9 | 41.3 | 36.9 | 20.6 | 10.3 | | | | | | | | |
| 290 | 116.1 | 105.1 | 94.3 | 83.7 | 73.1 | 62.5 | 51.9 | 41.4 | 31.0 | 20.6 | 10.3 | | | | | | | | | |
| 300 | 105.8 | 94.3 | 84.0 | 73.4 | 62.8 | 52.2 | 41.6 | 31.1 | 20.7 | 10.8 | | | | | | | | | | |
| 310 | 95.5 | 84.5 | 73.7 | 63.1 | 52.5 | 41.9 | 31.3 | 20.8 | 10.4 | | | | | | | | | | | |
| 320 | 85.0 | 74.5 | 63.2 | 51.7 | 41.1 | 30.5 | 20.9 | 10.4 | | | | | | | | | | | | |
| 330 | 74.7 | 63.7 | 52.9 | 42.3 | 31.7 | 21.1 | 10.5 | | | | | | | | | | | | | |
| 340 | 64.1 | 53.1 | 42.3 | 31.8 | 21.2 | 10.6 | | | | | | | | | | | | | | |
| 350 | 53.6 | 42.6 | 31.8 | 21.2 | 10.6 | | | | | | | | | | | | | | | |
| 360 | 42.0 | 31.0 | 21.4 | 10.6 | | | | | | | | | | | | | | | | |
| 370 | 32.4 | 21.0 | 10.6 | | | | | | | | | | | | | | | | | |
| 380 | 21.8 | 10.8 | | | | | | | | | | | | | | | | | | |
| 390 | 11.0 | | | | | | | | | | | | | | | | | | | |

Example: Flow temperature = 350°F
 Return temperature = 240°F
 Heat given up by 1 lb of water is 113.4 Btu per lb

Heat in Btu given up by 1 lb of water for various temperature drops

Heat pumps

The heat pump is a common refrigeration unit arranged in such a way that it can be used for both cooling and heating, or for heating only. The initial cost of the installation is high, and savings and advantages are achieved mainly when heating and cooling are required in winter and summer respectively.

Operation of the heat pump:

Referring to the scheme drawing below, the heat pump consists of the following parts:

Compressor, with driving motor, for raising the pressure and temperature of the refrigerant vapour.

Condenser, for extracting heat from the refrigerant.

Receiver (storage tank) to hold the liquid refrigerant in the high pressure side before it passes the expansion valve.

Expansion valve, for causing expansion of the refrigerant and for lowering the pressure from the high pressure to the low pressure side of the system.


Evaporator, in which heat is absorbed by the refrigerant from some source. Water, earth or air can be used as the source of heat.

A commercial refrigeration unit and heat pump consist of the same units and the same plant can be used either for cooling or heating.


The changing of the system from cooling to heating can be carried out by either of the following methods

- (a) Leave the flow of the refrigerant unchanged and change the circuit of the heat source and the medium to be heated.
- (b) Leave the heat source and the medium to be heated unchanged and reverse the flow of the refrigerant by a suitable pipe and valve scheme.


Schemes for a heat pump indicating suitable temperatures when used for cooling and heating are shown, the data being chosen for the purpose of illustration only.



SCHEME OF HEAT PUMP SYSTEM



COOLING CYCLE OF THE HEAT PUMP (WATER TO AIR)



HEATING CYCLE OF THE HEAT PUMP (WATER TO AIR)

9 Steam systems

Steam heating

Steam carries heat through pipes from the boiler to room or space heaters.


This is now seldom used as a method of space heating. This section is included for reference when old systems have to be examined or altered, and for design of systems in industrial premises where steam is available and steam-to-water calorifiers cannot be justified. Steam is also used for process heating in industry and the data in this section can also be used for pipe sizing.

Classification of steam heating systems


- 1 By pressure
 - (a) High pressure steam heating system
 - (b) Low pressure steam heating system
Up to about 3 lb/in² or 20 kN/m²
 - (c) Vacuum system
- 2 By method of returning condensate
 - (a) Gravity system
 - (b) Mechanical system
- 3 By pipe scheme
 - (a) One-pipe or two-pipe system
 - (b) Up-feed or down-feed system

(See illustrations on page 136.)


Steam heating systems




UP FEED TWO PIPE GRAVITY AIR VENT SYSTEM-WET RETURN




UP FEED ONE PIPE GRAVITY AIR VENT SYSTEM-WET RETURN




DOWN FEED TWO PIPE GRAVITY AIR VENT SYSTEM-WET RETURN




DOWN FEED ONE PIPE GRAVITY AIR VENT SYSTEM-WET RETURN



UP FEED VACUUM PUMP SYSTEM



ATMOSPHERIC SYSTEM HOT WELL OPEN TO ATMOSPHERE




UP FEED TWO PIPE GRAVITY SYSTEM- DRY RETURN

KEY

- B BOILER
- RADIATOR
- STEAM MAIN
- - - CONDENSATE MAIN
- · - VENT PIPE
- RADIATOR VALVE
- STEAM TRAP
- x— VENT

Vacuum differential heating system

In vacuum steam heating systems, a partial vacuum is maintained in the return line by means of a vacuum pump. The vacuum maintained is approx. 3-10 in mercury = approx. 75-250 mm mercury.



- 1 OUTSIDE THERMOSTAT
- 2 CONTROL VALVE
- 3 RADIATORS
- 4 STEAM TRAPS

- 5 CONDENSE RECEIVER
- 6 VACUUM PUMP
- 7 VENT
- 8 STEAM SUPPLY

Capacities of condensate pipes in watts

| Nominal pipe size | | Dry main with gradient | | | | Vent pipes |
|-------------------|-----------|------------------------|-----------|----------|-----------|------------|
| <i>in</i> | <i>mm</i> | Wet main | 1 in 200 | 1 in 600 | Vertical | |
| $\frac{1}{2}$ | 15 | 30 000 | 10 000 | 6 000 | 10 000 | 12 000 |
| $\frac{3}{4}$ | 20 | 70 000 | 30 000 | 18 000 | 30 000 | 47 000 |
| 1 | 25 | 120 000 | 50 000 | 34 000 | 50 000 | 94 000 |
| $1\frac{1}{4}$ | 32 | 300 000 | 120 000 | 80 000 | 120 000 | 211 000 |
| $1\frac{1}{2}$ | 40 | 420 000 | 176 000 | 117 000 | 176 000 | 293 000 |
| 2 | 50 | 760 000 | 350 000 | 225 000 | 350 000 | 530 000 |
| $2\frac{1}{2}$ | 65 | 1 900 000 | 800 000 | 510 000 | 800 000 | 1 200 000 |
| 3 | 80 | 2 700 000 | 1 200 000 | 740 000 | 1 200 000 | 1 870 000 |

Capacities of condensate pipes in Btu/hr

| Nominal pipe size | | Dry main with gradient | | | | Vent pipes |
|-------------------|-----------|------------------------|--------------------------|--------------------------|-----------|------------|
| <i>in</i> | <i>mm</i> | Wet main | $\frac{3}{16}$ in per yd | $\frac{1}{16}$ in per yd | Vertical | |
| $\frac{1}{2}$ | 15 | 100 000 | 40 000 | 24 000 | 40 000 | 40 000 |
| $\frac{3}{4}$ | 20 | 240 000 | 108 000 | 68 000 | 108 000 | 160 000 |
| 1 | 25 | 400 000 | 192 000 | 120 000 | 192 000 | 320 000 |
| $1\frac{1}{4}$ | 32 | 1 000 000 | 440 000 | 280 000 | 440 000 | 720 000 |
| $1\frac{1}{2}$ | 40 | 1 440 000 | 600 000 | 400 000 | 600 000 | 1 000 000 |
| 2 | 50 | 2 600 000 | 1 120 000 | 700 000 | 1 120 000 | 1 800 000 |
| $2\frac{1}{2}$ | 65 | 6 400 000 | 2 800 000 | 1 760 000 | 2 800 000 | 4 000 000 |
| 3 | 80 | 9 600 000 | 4 000 000 | 2 520 000 | 4 000 000 | 6 400 000 |

Safety valves for steam heating

(Working pressure = 70 kN/m²)

| Output Watts | Minimum clear bore | | Output Btu/hr | Minimum clear bore | |
|-----------------|--------------------|-----------|------------------|--------------------|-----------|
| | <i>in</i> | <i>mm</i> | | <i>in</i> | <i>mm</i> |
| 24 000 | $\frac{3}{4}$ | 20 | 80 000 | $\frac{3}{4}$ | 20 |
| 44 000 | 1 | 25 | 150 000 | 1 | 25 |
| 73 000 | $1\frac{1}{4}$ | 32 | 250 000 | $1\frac{1}{4}$ | 32 |
| 100 000 | $1\frac{1}{2}$ | 40 | 350 000 | $1\frac{1}{2}$ | 40 |
| 230 000 | 2 | 50 | 800 000 | 2 | 50 |
| 275 000 | $2\frac{1}{2}$ | 65 | 950 000 | $2\frac{1}{2}$ | 65 |
| 440 000 | Two 2 | Two 50 | 1 500 000 | Two 2 | Two 50 |

Suction lift of boiler feed pumps for various water temperatures

| Temperature of feed water °F | Maximum suction lift (ft) | Minimum pressure head (ft) | Temperature of feed water (°C) | Maximum suction lift (m) | Minimum pressure head (m) |
|------------------------------|---------------------------|----------------------------|--------------------------------|--------------------------|---------------------------|
| 130 | 10 | | 55 | 3 | |
| 150 | 2 | | 65 | 2 | |
| 170 | 7 | | 77 | 0.6 | |
| 175 | 0 | 0 | 80 | 0 | 0 |
| 190 | | 5 | 87.5 | | 1.5 |
| 200 | | 10 | 95 | | 3.5 |
| 210 | | 15 | 99 | | 4.5 |
| 212 | | 17 | 100 | | 5.0 |

Quantities of flash steam

Condensate


| Absolute pressure (kN/m ²) | Temperature (°C) | Percentage of condensate flashed off at reduction of pressure to kN/m ² absolute | | | | | |
|--|------------------|---|------|------|--------|------|------|
| | | 400 | 260 | 170 | 101.33 | 65 | 35 |
| 1500 | 198.3 | 11.3 | 14.0 | 16.4 | 18.9 | 20.4 | 23.2 |
| 1150 | 186.0 | 8.7 | 11.5 | 13.9 | 16.5 | 18.4 | 20.9 |
| 800 | 170.4 | 5.5 | 8.2 | 10.8 | 13.4 | 15.4 | 17.9 |
| 650 | 162.0 | 3.7 | 6.5 | 9.1 | 11.8 | 13.7 | 16.3 |
| 500 | 151.8 | 1.6 | 4.6 | 7.1 | 9.8 | 11.8 | 14.4 |
| 400 | 143.6 | — | 3.0 | 5.5 | 8.3 | 10.3 | 12.9 |
| 260 | 128.7 | — | — | 2.6 | 5.4 | 7.5 | 10.2 |
| 170 | 115.2 | — | — | — | 2.8 | 5.0 | 7.7 |
| 101.33 | 100 | — | — | — | — | 2.2 | 4.9 |


Condensate

| Gauge pressure (lb/in ²) | Temperature (°F) | Percentage of condensate flashed off at reduction of pressure to lb/in ² gauge or in Hg vacuum | | | | | |
|--------------------------------------|------------------|---|------|------|------|-------|-------|
| | | 40 | 20 | 10 | 0 | 10 in | 20 in |
| 200 | 388 | 11.5 | 14.3 | 16.2 | 18.8 | 20.5 | 23.2 |
| 150 | 366 | 9.0 | 11.8 | 13.0 | 16.4 | 18.2 | 20.9 |
| 100 | 338 | 5.8 | 8.6 | 10.6 | 13.3 | 15.1 | 17.9 |
| 80 | 324 | 4.2 | 7.1 | 9.1 | 11.9 | 13.7 | 16.5 |
| 60 | 308 | 2.3 | 5.2 | 7.3 | 10.0 | 11.8 | 14.7 |
| 40 | 287 | — | 3.0 | 5.0 | 7.8 | 9.7 | 12.6 |
| 20 | 259 | — | — | 2.1 | 5.0 | 6.8 | 9.8 |
| 10 | 240 | — | — | — | 2.9 | 4.8 | 7.8 |
| 0 | 212 | — | — | — | — | 1.9 | 5.0 |

CHART 1. PIPE SIZES FOR HOT WATER HEATING


$\left(\frac{1}{1,000} \text{ in. PER ft.}\right)$





FRICITIONAL RESISTANCE N/m^2 PER m \longrightarrow

CHART 1a. PIPE SIZES FOR HOT WATER HEATING







CHART 2. PIPE SIZES FOR LOW PRESSURE STEAM HEATING

$$\left(\frac{1}{1,000} \text{ lb/in}^2 \text{ PER ft RUN} \right)$$








CHART 3. PIPE SIZES FOR HIGH PRESSURE STEAM




STEAM FLO




$$\frac{b_j - b_k}{l} \frac{(kN/m^2)^{1.9375}}{m} \longrightarrow$$

STEAM FLO



Scheme of flash steam recovery



Sizing steam mains

The *Available Pressure Drop* is the difference between the initial or boiler pressure and the required final pressure at the end of the line.

$$p = p_j - p_k$$

The available pressure drop is used to overcome friction in pipes and pressure losses in fittings.

$$p_t = p_1 + p_2$$

For *low pressure steam*

$$p_1 = p_a l$$

$$p_2 = \sum F \frac{v^2 \rho}{2}$$

Alternatively

$$p_2 = p_a l_e$$

and

$$p_t = p_a (l + l_e)$$

p_a can be read from Chart 2 for given steam flow and pipe size.

For *high pressure steam* Chart 3 can be used. In this the auxiliary value b_x is used in place of the pressure drop per unit length.

$$b_x = b_j - b_k$$

$$b_j = p_j^{1.9375}$$

$$b_k = p_k^{1.9375}$$

In the above formula

- p_t = total pressure drop in system (N/m^2)
 p_j = initial or boiler pressure (N/m^2)
 p_k = final pressure (N/m^2)
 p_1 = pressure loss in pipes due to friction (N/m^2)
 p_2 = pressure loss in fittings (N/m^2)
 p_a = pipe friction resistance per length (N/m^2)
 F = coefficient of resistance
 v = steam velocity (m/s)
 ρ = density of steam (kg/m^3)
 l = length of pipe (m)
 l_e = equivalent length of fitting (m)

Ratio p_2/p_1 is generally about 0.33.

Total pressure drop is generally about 6 per cent of initial pressure per 100 m of pipe system.

Typical steam velocities

| | | |
|-------------------|-----------|----------------|
| Exhaust steam | 20–30 m/s | (70–100 ft/s) |
| Saturated steam | 30–40 m/s | (100–130 ft/s) |
| Superheated steam | 40–60 m/s | (130–200 ft/s) |

Values of F for fittings

| Fitting | Nom bore | | | | | |
|------------------------|---------------------------|---------------------------|---------------|----------------------------|----------------------------|---------------|
| | $\frac{1}{2}$ in 15 mm | $\frac{3}{4}$ in 20 mm | 1 in 25 mm | $1\frac{1}{4}$ in 32 mm | $1\frac{1}{2}$ in 40 mm | 2 in 50 mm |
| Radiator | 1.5 | 1.5 | 1.5 | 1.5 | 1.5 | 1.5 |
| Abrupt velocity change | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 |
| Cross over | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Angle valve | 9 | 9 | 9 | 9 | | |
| Globe valve | 15 | 17 | 19 | 30 | | |
| Angle cock | 7 | 4 | 4 | 4 | | |
| Straight cock | 4 | 2 | 2 | 2 | | |
| Gate valve | 1.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Damper | 3.5 | 2 | 2 | 1.5 | 1.5 | 1 |
| Elbow | 2 | 2 | 1.5 | 1.5 | 1 | 1 |
| Long sweep elbow | 1.5 | 1.5 | 1 | 1 | 0.5 | 0.5 |
| Short radius bend | 2 | 2 | 2 | 2 | 2 | 2 |
| Long radius bend | 1 | 1 | 1 | 1 | 1 | 1 |
| Tee straight | 1 | 1 | 1 | 1 | 1 | 1 |
| branch | 1.5 | 1.5 | 1.5 | 1.5 | 1.5 | 1.5 |
| counter current | 3.0 | 3.0 | 3.0 | 3.0 | 3.0 | 3.0 |
| double branch | 1.5 | 1.5 | 1.5 | 1.5 | 1.5 | 1.5 |

High pressure steam pipes

Resistance of valves and fittings to flow of steam

Expressed as an equivalent length of straight pipe

| Nom bore of pipe | | Bends of standard radius | | | | Barrel of tee | | | | | | Valves | | | | | | Lyre expansion bends | |
|---------------------|-----------|-----------------------------|----------|-----------|----------|---------------|----------|----------------|----------|------------------|----------|-----------|----------|-----------|----------|-----------|----------|----------------------------|----------|
| | | 90° | | 45° | | Plain | | Reduced 25% | | Branch of tee | | Through | | Angle | | Globe | | ft | m |
| <i>in</i> | <i>mm</i> | <i>ft</i> | <i>m</i> | <i>ft</i> | <i>m</i> | <i>ft</i> | <i>m</i> | <i>ft</i> | <i>m</i> | <i>ft</i> | <i>m</i> | <i>ft</i> | <i>m</i> | <i>ft</i> | <i>m</i> | <i>ft</i> | <i>m</i> | <i>ft</i> | <i>m</i> |
| 1 | 25 | 0.5 | 0.15 | 0.4 | 0.12 | 0.5 | 0.15 | 0.7 | 0.21 | 2.2 | 0.67 | 0.4 | 0.12 | 1.5 | 0.46 | 3.3 | 1.0 | 2.2 | 0.67 |
| 1 $\frac{1}{4}$ | 32 | 0.7 | 0.21 | 0.5 | 0.15 | 0.7 | 0.21 | 0.9 | 0.27 | 2.9 | 0.89 | 0.5 | 0.15 | 2.0 | 0.61 | 4.3 | 1.3 | 2.9 | 0.88 |
| 1 $\frac{1}{2}$ | 40 | 0.9 | 0.27 | 0.7 | 0.21 | 0.9 | 0.27 | 1.1 | 0.33 | 3.6 | 1.1 | 0.7 | 0.21 | 2.4 | 0.73 | 5.4 | 1.6 | 3.6 | 1.1 |
| 2 | 50 | 1.3 | 0.40 | 1.0 | 0.30 | 1.3 | 0.40 | 1.6 | 0.49 | 5.1 | 1.6 | 1.3 | 0.40 | 3.4 | 1.0 | 7.6 | 2.3 | 5.1 | 1.6 |
| 2 $\frac{1}{2}$ | 65 | 1.6 | 0.49 | 1.2 | 0.37 | 1.6 | 0.49 | 2.1 | 0.64 | 6.6 | 2.0 | 1.6 | 0.49 | 4.5 | 1.4 | 10.0 | 3.0 | 6.6 | 2.0 |
| 3 | 80 | 2.1 | 0.64 | 1.6 | 0.49 | 2.1 | 0.64 | 2.6 | 0.80 | 8.3 | 2.5 | 2.1 | 0.64 | 5.6 | 1.7 | 12.0 | 3.7 | 8.3 | 2.5 |
| 4 | 100 | 2.9 | 0.88 | 2.2 | 0.67 | 2.9 | 0.88 | 3.7 | 1.1 | 12.0 | 3.7 | 2.2 | 0.67 | 7.9 | 2.4 | 18.0 | 5.5 | 12.0 | 3.7 |
| 5 | 125 | 3.8 | 1.2 | 2.9 | 0.88 | 3.8 | 1.2 | 4.8 | 1.5 | 15.0 | 4.6 | 2.9 | 0.89 | 10.0 | 3.0 | 23.0 | 7.0 | 15.0 | 4.6 |
| 6 | 150 | 4.7 | 1.4 | 3.6 | 1.1 | 4.7 | 1.4 | 6.0 | 1.8 | 19.0 | 5.8 | 3.6 | 1.1 | 13.0 | 4.0 | 29.0 | 8.8 | 19.0 | 5.8 |
| 7 | 175 | 5.7 | 1.7 | 4.3 | 1.3 | 5.7 | 1.7 | 7.2 | 2.2 | 23.0 | 7.0 | 4.3 | 1.3 | 15.0 | 4.6 | 34.0 | 10 | 23.0 | 7.0 |
| 8 | 200 | 6.7 | 2.0 | 5.0 | 1.5 | 7.6 | 2.0 | 8.5 | 2.6 | 27.0 | 8.2 | 5.0 | 1.5 | 18.0 | 5.5 | 40.0 | 12 | 27.0 | 8.2 |
| 9 | 225 | 7.7 | 2.3 | 5.8 | 1.8 | 7.7 | 2.3 | 9.8 | 3.0 | 31.0 | 10 | 5.8 | 1.7 | 21.0 | 6.4 | 46.0 | 14 | 31.0 | 9.5 |
| 10 | 250 | 8.7 | 2.7 | 6.6 | 2.0 | 8.7 | 2.7 | 11.0 | 3.4 | 35.0 | 11 | 6.6 | 1.8 | 24.0 | 7.3 | 53.0 | 16 | 35.0 | 11 |

10 Domestic services

Domestic hot water supply

Classification

Direct System. Secondary water is heated by direct mixing with boiler water in a hot water cylinder.

Indirect system. Secondary water is heated by indirect heating by primary water from boiler in an indirect cylinder or calorifier.

Design procedure for domestic hot water

- 1 Determination of demand (quantity and temperature).
- 2 Selection of type, capacity and heating surface of calorifier.
- 3 Selection of boiler.
- 4 Pipe scheme and pipe sizes.

1 Demand

Hot water is normally stored and supplied at 60°C. For canteens and large kitchens it may be required at 65°C. Where lower temperatures are necessary for safety (e.g. nursery schools, centres for handicapped) it may be stored and supplied at a lower temperature (usually 40°-50°C) or stored and supplied at a higher temperature and reduced by mixing with cold water in a blender at the point of draw off.

Quantity is determined either according to number of occupants or according to number of fittings.

2 Calorifier

$$H = \frac{4.2V(\theta_2 - \theta_1)}{3600 t}$$

where

H = heating capacity (kW)

V = volume stored (litre)

θ_1 = temperature of cold feed water (°C)

θ_2 = temperature of hot water (°C)

t = time in which contents are to be raised from θ_1 to θ_2 (hr)

For instantaneous heating (non-storage calorifier or direct heater).

$$H = 4.2 v (\theta_2 - \theta_1)$$

where

v = demand in litre/s.

Storage systems are usually designed for $t=1$ hr or 2 hr. A shorter warming up time enables the volume of the calorifier to be reduced but may require a higher rate of heating.

Heating Surface

$$A = \frac{1000 H}{k \theta_m}$$

$$\theta_m = \frac{\theta_f - \theta_r + \theta_2 - \theta_1}{2.3 \log_{10} \theta_f - \theta_1 / \theta_r - \theta_2}$$

where

- A = heating surface of calorifier (m^2)
- H = rate of heating (kW)
- k = heat transmission coefficient ($\text{W}/\text{m}^2 \text{K}$)
- θ_m = logarithmic mean temperature difference (K)
- θ_f = primary flow temperature ($^{\circ}\text{C}$)
- θ_r = primary return temperature ($^{\circ}\text{C}$)
- θ_1 = secondary inlet temperature ($^{\circ}\text{C}$)
- θ_2 = secondary final temperature ($^{\circ}\text{C}$)

3 Boiler

Boiler rating = Heating capacity of calorifier

Boiler with correct rating to be selected from manufacturers' catalogues.

4 Pipe sizes

Pipes can be sized as for hot water heating systems (see section 8, page 122).

Volume flow through pipes to draw offs is determined by maximum demand. Volume flow through return pipes of circulating system is made sufficient to keep temperature drop between flow and return connections of calorifier down to about 5 K.

For most schemes pipe sizing table on page 155 is satisfactory.

Pump duties can be determined as for hot water heating systems (see section 8, page 121).


Precautions against legionellosis

Infection is caused by inhalation of airborne droplets containing viable legionella. Sources can be hot and cold water services, cooling towers, humidifiers, air washers.

- 1 Pipe lengths and dead legs as short as possible.
Design temperatures to be maintained by adequate insulation, including insulation of cold pipes to prevent rise of temperature.
Adequate access for regular cleaning.
Water should not stand for long periods in conditions where its temperature may rise above 20°C .
- 2 Hot water storage at 60°C with at last 50°C attained at outlets after one minute of running. Stratification in calorifiers to be avoided.
Cold water storage and distribution at 20°C or below.
There is a risk of scalding at 43°C and above. Thermostatic mixing valves to be used as close as possible to outlets.


- Alternatives to temperature control are water treatment by ionisation with copper and silver, dosing with chlorine dioxide, and biocidal treatment with ozone or ultra violet light.

Domestic hot water schemes




DIRECT SYSTEM

DIRECT SYSTEM WITH PUMPED SECONDARY CIRCULATION













INDIRECT SYSTEM WITH PUMPED PRIMARY AND PUMPED SECONDARY



UNVENTED INDIRECT SYSTEM

LEGEND

| | | | |
|---|---------------------------------|---|-------------------------|
|  | COLD WATER TANK |  | CLOSED EXPANSION VESSEL |
|  | PRIMARY FEED AND EXPANSION TANK |  | BOILER |
|  | DIRECT CYLINDER |  | PUMP |
|  | INDIRECT CALORIFIER |  | VALVE |
| | |  | DRAW-OFF TAP |
| | |  | NON-RETURN VALVE |

Hot water consumption per fitting

| <i>Fitting</i> | <i>Consumption</i> | | <i>Fitting</i> | <i>Consumption</i> | |
|-----------------|--------------------|---------------|----------------|--------------------|---------------|
| | <i>litre/hr</i> | <i>gal/hr</i> | | <i>litre/hr</i> | <i>gal/hr</i> |
| Basin (private) | 14 | 3 | Sink | 45-90 | 10-20 |
| Basin (public) | 45 | 10 | Bath | 90-180 | 20-40 |
| Shower | 180 | 40 | | | |

Hot water consumption per occupant

| <i>Type of building</i> | <i>Consumption per occupant</i> | | <i>Peak demand per occupant</i> | | <i>Storage per occupant</i> | |
|-------------------------|---------------------------------|----------------|---------------------------------|---------------|-----------------------------|------------|
| | <i>litre/day</i> | <i>gal/day</i> | <i>litre/hr</i> | <i>gal/hr</i> | <i>litre</i> | <i>gal</i> |
| Factories (no process) | 22-45 | 5-10 | 9 | 2 | 5 | 1 |
| Hospitals, general | 160 | 35 | 30 | 7 | 27 | 6 |
| mental | 110 | 25 | 22 | 5 | 27 | 6 |
| Hostels | 120 | 26 | 50 | 11 | 30 | 7 |
| Hotels | 130-230 | 28-50 | 50 | 11 | 30 | 7 |
| Houses and flats | 45-160 | 10-35 | 50 | 11 | 30 | 7 |
| Offices | 22 | 5 | 9 | 2 | 5 | 1 |
| Schools, boarding | 115 | 25 | 30 | 7 | 25 | 5 |
| day | 10 | 2 | 9 | 2 | 5 | 1 |

Contents of fittings

| <i>Fitting</i> | <i>Contents</i> | |
|----------------|-----------------|------------|
| | <i>litre</i> | <i>gal</i> |
| Basin, normal | 4 | 0.8 |
| Basin, full | 9 | 2 |
| Sink, normal | 18 | 4 |
| Sink, full | 30 | 6.5 |
| Bath | 100-135 | 22-30 |

Flow rates

| <i>Fitting</i> | <i>Flow rate</i> | |
|----------------|------------------|----------------|
| | <i>litre/s</i> | <i>gal/min</i> |
| Basin | 0.08 | 1 |
| Sink | 0.15 | 2 |
| Bath | 0.15 | 2 |
| Shower | 0.09-0.12 | 1.2-1.6 |

Maximum dead leg of hot water pipe without circulation

| <i>Pipe size</i> | | | <i>Length</i> |
|------------------|---------------|--|---------------|
| <i>Steel</i> | <i>Copper</i> | | <i>m</i> |
| 15 | 15 | | 12 |
| 20 | 22 | | 8 |
| 25 | 28 | | 3 |

Pipe sizes for domestic cold and hot water service

| <i>Nominal bore of pipe</i> | | | <i>Maximum number of draw offs served</i> | | |
|-----------------------------|----------------------|-----------------------|---|-------------------------------|---------------------|
| | | | <i>Flow pipes</i> | | |
| <i>in</i> | <i>Steel pipe mm</i> | <i>Copper pipe mm</i> | <i>Head up to 20 m (70 ft)</i> | <i>Head over 20 m (70 ft)</i> | <i>Return pipes</i> |
| $\frac{1}{2}$ | 15 | 15 | 1 | 1 to 2 | 1 to 8 |
| $\frac{3}{4}$ | 20 | 22 | 2 to 4 | 3 to 9 | 9 to 29 |
| 1 | 25 | 28 | 5 to 8 | 10 to 19 | 30 to 66 |
| $1\frac{1}{4}$ | 32 | 35 | 9 to 24 | 20 to 49 | 67 to 169 |
| $1\frac{1}{2}$ | 40 | 42 | 25 to 49 | 50 to 79 | 170 to 350 |
| 2 | 50 | 54 | 50 to 99 | 80 to 153 | — |
| $2\frac{1}{2}$ | 65 | 67 | 100 to 200 | 154 to 300 | — |

For the purpose of this table, basins, sinks, showers count as one draw off, baths count as two draw offs.

Cold water storage per occupant

| <i>Type of building</i> | <i>Storage per occupant</i> | | <i>Type of building</i> | <i>Storage per occupant</i> | |
|---------------------------|-----------------------------|------------|-------------------------|-----------------------------|------------|
| | <i>litres</i> | <i>gal</i> | | <i>litres</i> | <i>gal</i> |
| Factories (no process) | 10 | 2 | Offices with canteen | 45 | 10 |
| Hospitals per bed | 150 | 33 | without canteen | 35 | 8 |
| per staff on duty | 45 | 10 | Restaurant, per meal | 7 | 1.5 |
| Hostels | 90 | 20 | Schools | | |
| Hotels | 150 | 33 | boarding | 90 | 20 |
| Houses and flats | 135 | 30 | day | 30 | 7 |

Cold water storage per fitting



| <i>Type of fitting</i> | <i>Storage per unit</i> | | <i>Type of fitting</i> | <i>Storage per unit</i> | |
|------------------------|-------------------------|------------|------------------------|-------------------------|------------|
| | <i>litres</i> | <i>gal</i> | | <i>litres</i> | <i>gal</i> |
| Shower | 450-900 | 100-200 | Sink | 90 | 20 |
| Bath | 900 | 200 | Urinal | 180 | 40 |
| W.C. | 180 | 40 | Garden | | |
| Basin | 90 | 20 | watering tap | 180 | 40 |

Temperature drop in bare pipes


| <i>Flow of water</i> <i>kg/s</i> | <i>Temperature drop K/m for size of pipe</i> | | | | | | | | |
|-------------------------------------|--|--------------|--------------|--------------|--------------|--------------|--------------|--------------|---------------|
| | <i>15 mm</i> | <i>20 mm</i> | <i>25 mm</i> | <i>32 mm</i> | <i>40 mm</i> | <i>50 mm</i> | <i>65 mm</i> | <i>80 mm</i> | <i>100 mm</i> |
| 0.010 | 1.03 | 1.37 | 1.49 | 1.83 | 2.06 | 2.52 | 2.88 | 3.44 | 4.35 |
| 0.012 | 0.86 | 1.14 | 1.24 | 1.54 | 1.72 | 2.10 | 2.40 | 2.87 | 3.63 |
| 0.014 | 0.74 | 0.98 | 1.06 | 1.31 | 1.45 | 1.80 | 2.06 | 2.43 | 3.11 |
| 0.016 | 0.65 | 0.86 | 0.93 | 1.14 | 1.29 | 1.57 | 1.80 | 2.14 | 2.72 |
| 0.018 | 0.57 | 0.76 | 0.83 | 1.02 | 1.14 | 1.40 | 1.60 | 1.91 | 2.42 |
| 0.020 | 0.52 | 0.69 | 0.74 | 0.92 | 1.03 | 1.26 | 1.44 | 1.77 | 2.08 |
| 0.025 | 0.41 | 0.55 | 0.60 | 0.72 | 0.82 | 1.01 | 1.16 | 1.37 | 1.78 |
| 0.030 | 0.34 | 0.45 | 0.50 | 0.61 | 0.69 | 0.84 | 0.96 | 1.15 | 1.45 |
| 0.035 | 0.29 | 0.39 | 0.43 | 0.52 | 0.59 | 0.72 | 0.82 | 0.98 | 1.24 |
| 0.040 | 0.26 | 0.34 | 0.39 | 0.46 | 0.52 | 0.63 | 0.72 | 0.86 | 1.09 |
| 0.045 | 0.23 | 0.30 | 0.33 | 0.41 | 0.46 | 0.56 | 0.64 | 0.76 | 0.97 |
| 0.050 | 0.21 | 0.27 | 0.30 | 0.37 | 0.41 | 0.50 | 0.57 | 0.69 | 0.87 |
| 0.060 | 0.17 | 0.23 | 0.25 | 0.31 | 0.34 | 0.42 | 0.48 | 0.57 | 0.76 |
| 0.070 | 0.15 | 0.20 | 0.21 | 0.26 | 0.29 | 0.36 | 0.41 | 0.49 | 0.62 |
| 0.080 | 0.13 | 0.17 | 0.19 | 0.23 | 0.26 | 0.32 | 0.36 | 0.47 | 0.54 |
| 0.090 | 0.11 | 0.15 | 0.17 | 0.20 | 0.23 | 0.27 | 0.32 | 0.43 | 0.48 |
| 0.100 | 0.10 | 0.14 | 0.15 | 0.18 | 0.21 | 0.25 | 0.29 | 0.34 | 0.44 |

| <i>Flow of water</i> <i>lb/hr</i> | <i>Temperature drop °F/ft for size of pipe</i> | | | | | | | | |
|--------------------------------------|--|------------------|-------|-------------------|-------------------|------|-------------------|------|------|
| | $\frac{1}{2}$ in | $\frac{3}{4}$ in | 1 in | $1\frac{1}{4}$ in | $1\frac{1}{2}$ in | 2 in | $2\frac{1}{2}$ in | 3 in | 4 in |
| 100 | 0.45 | 0.60 | 0.65 | 0.80 | 0.90 | 1.10 | 1.25 | 1.50 | 1.90 |
| 120 | 0.38 | 0.50 | 0.54 | 0.62 | 0.75 | 0.92 | 1.04 | 1.21 | 1.58 |
| 140 | 0.32 | 0.43 | 0.46 | 0.57 | 0.64 | 0.79 | 0.89 | 1.07 | 1.36 |
| 160 | 0.28 | 0.37 | 0.41 | 0.50 | 0.56 | 0.69 | 0.78 | 0.94 | 1.19 |
| 180 | 0.25 | 0.33 | 0.36 | 0.44 | 0.50 | 0.61 | 0.69 | 0.83 | 1.06 |
| 200 | 0.22 | 0.30 | 0.33 | 0.40 | 0.45 | 0.55 | 0.63 | 0.75 | 0.95 |
| 250 | 0.18 | 0.24 | 0.26 | 0.32 | 0.36 | 0.44 | 0.50 | 0.60 | 0.76 |
| 300 | 0.15 | 0.20 | 0.22 | 0.27 | 0.30 | 0.37 | 0.42 | 0.50 | 0.63 |
| 350 | 0.13 | 0.17 | 0.19 | 0.23 | 0.26 | 0.31 | 0.36 | 0.43 | 0.54 |
| 400 | 0.11 | 0.15 | 0.17 | 0.20 | 0.23 | 0.28 | 0.32 | 0.38 | 0.48 |
| 450 | 0.10 | 0.13 | 0.14 | 0.18 | 0.20 | 0.24 | 0.28 | 0.33 | 0.42 |
| 500 | 0.09 | 0.12 | 0.13 | 0.16 | 0.18 | 0.22 | 0.25 | 0.30 | 0.38 |
| 600 | 0.075 | 0.10 | 0.11 | 0.14 | 0.15 | 0.19 | 0.21 | 0.25 | 0.37 |
| 700 | 0.065 | 0.085 | 0.095 | 0.13 | 0.13 | 0.16 | 0.18 | 0.22 | 0.27 |
| 800 | 0.055 | 0.075 | 0.083 | 0.10 | 0.11 | 0.14 | 0.16 | 0.19 | 0.24 |
| 900 | 0.050 | 0.066 | 0.070 | 0.089 | 0.10 | 0.12 | 0.14 | 0.17 | 0.21 |
| 1000 | 0.045 | 0.060 | 0.065 | 0.080 | 0.090 | 0.11 | 0.13 | 0.15 | 0.19 |

Cold water storage systems for tall buildings



Fire service



Typical dry riser provided in tall buildings for fire brigade use

Pipe sizing for fire service

Usual requirement is that 30 gal/min with 30 lb/in² residual pressure should be available at hose reel. Design on assumption that three hose reels are in use at once.


Usual sizes for pipe serving

- | | |
|--------------|-------|
| 1 hose reel | 32 mm |
| 2 hose reels | 40 mm |
| 3 hose reels | 50 mm |

Gas supply. Gas consumption of equipment (natural gas)

| | ft^3/h | m^3/s | litre/s | <i>Heat dissipated kW</i> |
|------------------------|----------|--------------------------------------|--------------|-----------------------------------|
| 10 gal boiling pan | 45 | 350×10^{-6} | 0.35 | 13 |
| 20 gal boiling pan | 60 | 475×10^{-6} | 0.48 | 18 |
| 30 gal boiling pan | 75 | 600×10^{-6} | 0.60 | 22 |
| 40 gal boiling pan | 90 | 700×10^{-6} | 0.70 | 26 |
| 4 ft hot cupboard | 48 | 375×10^{-6} | 0.38 | 14 |
| 6 ft hot cupboard | 54 | 425×10^{-6} | 0.43 | 16 |
| Steaming oven | 40 to 50 | $300 \text{ to } 400 \times 10^{-6}$ | 0.30 to 0.40 | 11 to 15 |
| Double steaming oven | 100 | 800×10^{-6} | 0.80 | 30 |
| 2-tier roasting oven | 50 | 400×10^{-6} | 0.40 | 15 |
| Double oven range | 400 | 3200×10^{-6} | 3.2 | 115 |
| Roasting oven | 30 | 240×10^{-6} | 0.24 | 9 |
| Gas cooker | 75 | 600×10^{-6} | 0.60 | 20 |
| Hot cupboard | 17 | 140×10^{-6} | 0.14 | 5 |
| Drying cupboard | 5 | 40×10^{-6} | 0.04 | 1.5 |
| Gas iron heater | 5 | 40×10^{-6} | 0.04 | 1.5 |
| Washing machine | 20 | 150×10^{-6} | 0.15 | 6 |
| Wash boiler | 30 to 50 | $230 \text{ to } 400 \times 10^{-6}$ | 0.23 to 0.40 | 8 to 15 |
| Bunsen burner | 3 | 20×10^{-6} | 0.02 | 1 |
| Bunsen burner, full on | 10 | 80×10^{-6} | 0.08 | 3 |
| Glue kettle | 10 | 80×10^{-6} | 0.08 | 3 |
| Forge | 15 | 115×10^{-6} | 0.12 | 4 |
| Brazing hearth | 30 | 230×10^{-6} | 0.23 | 9 |

Flow of gas in steel tubes



11 Ventilation

Ventilation

Classification by distribution

Central system. A central plant supplies air to the whole building. There can also be a central extract system.


Unit system. Each room or area of the building has its own ventilating unit.

Classification by function

Split system of heating and ventilating. Heat losses through the fabric of the building are supplied by a radiator heating system and the ventilation delivers air at room temperature.

Combined system. A central ventilation plant supplies air above or below room temperature so that in cooling or heating to room temperature it provides the required heating or cooling as well as ventilation.

Schemes of air distribution



DIAGRAMMATIC VIEWS (IN ELEVATION) SHOWING HOW VARIOUS SYSTEMS OF AIR DISTRIBUTION ARE APPLIED IN BUILDINGS.

- 1 Upward flow system
- 2 Downward flow system
- 3 High-level supply and return system
- 4 Low-level supply and return system
- 5 Ejector system

Design procedure for ventilating system

- 1 Heating or cooling load, including sensible and latent heat.
- 2 Temperature of air leaving grilles, calculated or assumed.
- 3 Mass of air to be circulated.
- 4 Temperature loss in ducts.
- 5 Output of heaters, washers, humidifiers, coolers.
- 6 Boiler or heater size.
- 7 Duct system and duct sizes.

1 Heating and cooling loads

Calculated with data in sections 6 and 7.

2 Supply air temperature

For heating 38°–50°C (100°–120°F).

For cooling, inlets near occupied zones, 6°–8°C below room temperature (10°–15°F).

For cooling, high velocity diffusing jets. 17°C below room temperature (30°F).

3 Air quantity

$$W = \frac{H}{C(t_d - t_r)} \quad V = \frac{H}{C\rho(t_d - t_r)}$$

where

W = mass of air (kg/s)

V = volume of air (m³/s)

H = sensible heat loss or gain (kW)

C = specific heat capacity of air (= 1.01) (kJ/kg K)

ρ = density of air (= 1.21) (kg/m³)

t_d = discharge temperature of air at grilles (°C)

t_r = room temperature (°C)

when moisture content is limiting factor

$$W = \frac{M}{w_2 - w_1}$$

where

W = mass of air (kg/s)

M = moisture to be absorbed (g/s)

w_1 = humidity of supply air (g/kg)

w_2 = humidity of room air (g/kg)

Alternatively, the air quantity is determined by the ventilation requirements of the occupants or process in the various rooms.

It is a disadvantage of the *Combined System* that the air quantity necessary to satisfy the heating or cooling requirement is not always the same as that necessary to satisfy the ventilation requirement and an acceptable compromise is not always easy to find.

4 Temperature drop in ducts

$$WC(t_1 - t_2) = Ak \left(\frac{t_1 + t_2}{2} - t_r \right)$$

where

W = mass of air flowing (kg/s)

C = specific heat capacity of air (= 1.01) (kJ/kg K)

A = area of duct walls (m²)

k = heat loss coefficient of duct walls (kW/m² K)

t_1 = initial temperature in duct (°C)

t_2 = final temperature in duct (°C)

t_r = surrounding room temperature (°C)

$k = 5.68 \times 10^{-3}$ kW/m² K for sheet metal ducts

$= 2.3 \times 10^{-3}$ kW/m² K for insulated ducts.

For large temperature drops the logarithmic mean temperature should be used. The equation then becomes

$$WC(t_2 - t_1) = Ak \frac{(t_1 - t_r) - (t_2 - t_r)}{\log_e(t_1 - t_r)/(t_2 - t_r)}$$

5 Heaters, washers, humidifiers, coolers

Units with required combination of air quantity, heating or cooling capacity, humidifying or dehumidifying capacity to be selected from manufacturers' catalogues.

6 Boiler

$$B = H(1 + X)$$

where

B = boiler rating (kW)

H = total heat load of all heater units in system (kW)

X = margin for heating up and design uncertainties (0.15 to 0.20)

Boiler with correct rating to be selected from manufacturers' catalogues.

7 Duct sizes

$$v = \frac{Q}{A}$$

$$p_t = p_1 + p_2 + p_3$$

$$p_1 = il$$

$$i = \frac{2f\varrho v^2}{d}$$

$$p_2 = \sum \frac{Kv^2\varrho}{2}$$

where

v = air velocity (m/s)

Q = air volume (m³/s)

A = cross section of duct (m²)

p_t = total pressure loss in system (N/m²)

p_1 = pressure loss in ducts due to friction (N/m²)

p_2 = pressure loss in fittings (N/m²)

p_3 = pressure loss in apparatus (filters, heaters, etc.) (N/m²)

i = duct friction resistance per unit length (N/m² per m run)

f = friction factor, which is a function of Reynolds number

K = coefficient of resistance for fitting

ϱ = density of air (kg/m³)

d = diameter of duct (m)

i can be obtained from Chart 4.

For rectangular ducts the equivalent diameter must be used

$$d = 1.26 \sqrt[5]{\frac{(ab)^3}{a+b}}$$

where

d = equivalent diameter (m)

a, b = sides of rectangular duct (m)

For standard air

$$\varrho = 1.21 \text{ kg/m}^3$$

$$p_2 = K \left(\frac{v}{1.29} \right)^2 \text{ N/m}^2 \text{ with } v \text{ in m/s}$$

Ventilation rates, occupancy known

| <i>Type of building</i> | <i>Fresh air supply m³/s per person</i> | <i>Type of building</i> | <i>Fresh air supply m³/s per person</i> |
|-------------------------|--|-------------------------------------|--|
| Assembly halls | 0.014 | Schools | 0.014 |
| Factories | 0.02-0.03 | Shops | 0.02 |
| Hospitals, general | 0.025 | Theatres | 0.014 |
| contagious diseases | 0.05 | Areas where heavy smoking can occur | 0.028 |
| Offices | 0.016 | | |

Ventilation rates, occupancy unknown

| <i>Type of building</i> | <i>Air changes per hour</i> | <i>Type of building</i> | <i>Air changes per hour</i> |
|-------------------------|-----------------------------|-------------------------|-----------------------------|
| Assembly halls | 5-10 | Laundries | 10-15 |
| Baths | 5-8 | Libraries | 3-4 |
| Boiler rooms | 4 | Offices | 3-8 |
| Cinemas | 5-10 | Museums | 3-4 |
| Conference rooms | 6-10 | Restaurants | 7-15 |
| Department stores | 3-8 | Sports halls | 6 |
| Dry stores | 10 | Supermarkets | 3-8 |
| Engine rooms | 4 | Swimming pools | 5-10 |
| Factories | 6 | Theatres | 5-10 |
| Garages | 6 | Toilets | 6-10 |
| Kitchens | 10-60 | | |
| Laboratories | 4-15 | | |

Garage ventilation

Two thirds total extract at high level, one third at low level


Bathroom and W.C. ventilation

Six air changes per hour or 0.018 m³/s per room.

To provide a standby service two fans with an automatic changeover switch are installed.

Proprietary units incorporating two fans with automatic changeover are widely used. Alternatively individual fans can be joined by ducting and the

changeover control supplied separately. Typical schemes for this are



Theoretical velocity of air (due to natural draught)

$$V = 4.43 \sqrt{\frac{h(t_c - t_o)}{273 + t_o}}$$

V = theoretical velocity (m/s)
 h = height of flue (m)
 t_c = temperature of warm air column ($^{\circ}\text{C}$)
 t_o = temperature of outside air ($^{\circ}\text{C}$)

$$V = 8.02 \sqrt{\frac{h(t_c - t_o)}{460 + t_o}}$$

V = in ft/s
 h = in ft
 t_c = in $^{\circ}\text{F}$
 t_o = in $^{\circ}\text{F}$

Air velocities and equivalent pressures

$$p = \frac{V^2 \rho}{2} = 0.6V^2$$

p = velocity pressure N/m^2
 V = velocity m/s
 ρ = density of air = 1.2 kg/m^3

$$h = \frac{V^2 \rho}{2g} \frac{1}{18\,720} = \frac{V^2}{16\,000\,000}$$

h = velocity head in water gauge
 V = velocity ft/min
 ρ = density of air = 0.075 lb/ft^3

Filters

Dust load for filters

| | mg/m ³ |
|------------------------------|-------------------|
| Rural and suburban districts | 0.45-1.00 |
| Metropolitan districts | 1.0-1.8 |
| Industrial districts | 1.8-3.5 |
















Types of filter

- (a) *Washers*
- | | |
|--|---|
| Overall length | about 20 m |
| Air velocity through washer | 2.5 m/s |
| Water quantity required | 0.5 to 0.8 litre per m ³ air |
| Water pressure required for spray nozzles | 140-170 kN/m ² |
| Water pressure required for flooding nozzles | 35-70 kN/m ² |
- (b) *Dry filters*
Felt, cloth, cellulose, glass, silk, etc. without adhesive liquid
- (i) Panel type – disposable
- | | |
|--------------|-------------------------|
| Air velocity | 0.1-1.0 m/s |
| Resistance | 25-250 N/m ² |
- (ii) Continuous roll – self cleaning
- | | |
|--------------|-------------------------|
| Air velocity | 2.5 m/s |
| Resistance | 30-175 N/m ² |
- (c) *Viscous filters*
- (i) Panel type – cloth with viscous fluid coating – washable or disposable
- | | |
|--------------|-------------------------|
| Plates about | 500 mm × 500 mm |
| Air velocity | 1.5-2.5 m/s |
| Resistance | 20-150 N/m ² |
- (ii) Continuous roll – continuously moving, self cleaning
- | | |
|--------------|-------------------------|
| Air velocity | 2.5 m/s |
| Resistance | 30-175 N/m ² |
- (e) *Electrostatic precipitators*
- | | |
|-----------------------|-------------|
| Cleaned automatically | |
| Air velocity | 1.5-2.5 m/s |
| Resistance | negligible |
- (f) *Absolute*
- | | |
|--|--------------------------|
| Dry panel with special coating – disposable or self cleaning | |
| Air velocity | 2.5 m/s |
| Resistance | 250-625 N/m ² |

Resistance of ducts. (Allowance for surface conditions)

| Surface | Chart reading to be multiplied by |
|---------------------|-----------------------------------|
| Asbestos cement | 0.8 |
| Asphalted cast iron | 6.0 |
| Aluminium | 0.8 |
| Brickwork | 4 |
| Concrete | 2 |
| Fibreglass | 0.8 |
| PVC | 0.8 |
| Sheet iron | 1.5 |
| Sheet steel | 1.0 |

Coefficients of resistance (for ductwork fittings)

| FITTING | K | FITTING | K | | | | | | | | | | | | |
|---|--------------------------------------|---|---|-----|---|-----|---|-----|---|-----|----|-----|----|-----|----|
| SHARP 90° BEND  | 1.3 | EXIT TO ROOM  | 1.0 | | | | | | | | | | | | |
| 90° BEND WITH VANES  | 0.7 | ENTRY FROM ROOM  | 0.5 | | | | | | | | | | | | |
| ROUNDED 90° BEND $r/w < 1$  | 0.5 | ABRUPT REDUCTION  | $0.5 - (V_1/V_2)^2$ APPLIED TO V.H. OF V_2 | | | | | | | | | | | | |
| ROUNDED 90° BEND $r/w > 1$  | 0.25 | ABRUPT ENLARGEMENT  | $(1 - V_2/V_1)^2$ APPLIED TO V.H. OF V_1 | | | | | | | | | | | | |
| SHARP 45° BEND  | 0.5 | TAPERED ENLARGEMENT $\alpha \leq 8^\circ$  | $1.5 \times (1 - V_2/V_1)^2$ APPLIED TO V.H. OF V_1 | | | | | | | | | | | | |
| ROUNDED 45° BEND $r/w < 1$  | 0.2 | TAPERED ENLARGEMENT $\alpha > 8^\circ$  | $(1 - V_2/V_1)^2$ APPLIED TO V.H. OF V_1 | | | | | | | | | | | | |
| ROUNDED 45° BEND $r/w > 1$  | 0.05 | TAPERED REDUCTION  | 0 | | | | | | | | | | | | |
| FLOW TO BRANCH  | 0.3 APPLIED TO V.H. IN THE BRANCH | GRILLES RATIO OF FREE AREA TO TOTAL SURFACE | <table border="1"> <tbody> <tr><td>0.7</td><td>3</td></tr> <tr><td>0.6</td><td>4</td></tr> <tr><td>0.5</td><td>6</td></tr> <tr><td>0.4</td><td>10</td></tr> <tr><td>0.3</td><td>20</td></tr> <tr><td>0.2</td><td>50</td></tr> </tbody> </table> | 0.7 | 3 | 0.6 | 4 | 0.5 | 6 | 0.4 | 10 | 0.3 | 20 | 0.2 | 50 |
| 0.7 | 3 | | | | | | | | | | | | | | |
| 0.6 | 4 | | | | | | | | | | | | | | |
| 0.5 | 6 | | | | | | | | | | | | | | |
| 0.4 | 10 | | | | | | | | | | | | | | |
| 0.3 | 20 | | | | | | | | | | | | | | |
| 0.2 | 50 | | | | | | | | | | | | | | |

Pressure drop in apparatus. (Usually given by manufacturers)

| <i>Apparatus</i> | <i>Average pressure drop</i> | |
|------------------|------------------------------|---------------------------------|
| | <i>(N/m²)</i> | <i>(in w.g.)</i> |
| Filters | 50 to 100 | $\frac{3}{16}$ to $\frac{3}{8}$ |
| Air washers | 50 to 100 | $\frac{3}{16}$ to $\frac{3}{8}$ |
| Heater batteries | 30 to 100 | $\frac{1}{8}$ to $\frac{3}{8}$ |

Recommended velocities for ventilating systems

| <i>Service</i> | <i>Velocity</i> | | | |
|------------------------------|-------------------------|---------------|-------------------------|---------------|
| | <i>Public buildings</i> | | <i>Industrial plant</i> | |
| | <i>m/s</i> | <i>ft/min</i> | <i>m/s</i> | <i>ft/min</i> |
| Air intake from outside | 2.5-4.5 | 500-900 | 5-6 | 1000-1200 |
| Heater connection to fan | 3.5-4.5 | 700-900 | 5-7 | 1000-1400 |
| Main supply ducts | 5.0-8.0 | 1000-1500 | 6-12 | 1200-2400 |
| Branch supply ducts | 2.5-3.0 | 500-600 | 4.5-9 | 900-1800 |
| Supply registers and grilles | 1.2-2.3 | 250-450 | 1.5-2.5 | 350-500 |
| Low level supply registers | 0.8-1.2 | 150-250 | — | — |
| Main extract ducts | 4.5-8.0 | 900-1500 | 6-12 | 1200-2400 |
| Branch extract ducts | 2.5-3.0 | 500-600 | 4.5-9 | 900-1800 |

Velocities in natural draught extract systems should be 1-3 m/s (200-600 ft/min).

Thickness of ducts

Rectangular

| <i>Longest Side</i> | | <i>Thickness</i> | |
|---------------------|-----------|----------------------|---------------------------|
| | | <i>Up to 1000 pa</i> | <i>1001 pa to 2000 pa</i> |
| <i>mm</i> | <i>in</i> | <i>mm</i> | <i>mm</i> |
| 400 | 15 | 0.6 | 0.8 |
| 600 | 24 | 0.8 | 0.8 |
| 800 | 32 | 0.8 | 0.8 |
| 1000 | 40 | 0.8 | 0.8 |
| 1250 | 48 | 1.0 | 1.0 |
| 1600 | 63 | 1.0 | 1.0 |
| 2000 | 78 | 1.0 | 1.2 |
| 2500 | 96 | 1.0 | 1.2 |
| 3000 | 118 | 1.2 | — |

| <i>Circular diameter</i> | | <i>Thickness</i> | | |
|--------------------------|-----------|-------------------------------------|------------------------|----------------------|
| | | <i>Spirally wound up to 2000 pa</i> | <i>Straight seamed</i> | |
| <i>mm</i> | <i>in</i> | | <i>mm</i> | <i>up to 1000 pa</i> |
| | | <i>mm</i> | <i>mm</i> | <i>mm</i> |
| 80 | 3 | 0.4 | 0.6 | 0.8 |
| 160 | 6 | 0.5 | 0.6 | 0.8 |
| 200 | 8 | 0.5 | 0.6 | 0.8 |
| 315 | 12 | 0.6 | 0.6 | 0.8 |
| 500 | 20 | 0.6 | 0.8 | 0.8 |
| 800 | 32 | 0.8 | 0.8 | 1.0 |
| 1000 | 40 | 1.0 | 1.0 | 1.2 |
| 1500 | 60 | 1.2 | 1.2 | 1.2 |

Ducts outside buildings exposed to atmosphere should be 0.2 mm thicker.

Beaufort wind scale

| <i>Beaufort No.</i> | <i>Description of wind</i> | <i>Observation</i> | <i>Wind speed</i> | | |
|---------------------|----------------------------|---|-------------------|---------------|------------|
| | | | <i>mph</i> | <i>ft/min</i> | <i>m/s</i> |
| 0 | Calm | Smoke rises vertically | 0-0.3 | 0-25 | 0-0.15 |
| 1 | Light air | Direction of wind shown by smoke drift but not by wind vanes | 0.3-6 | 25-525 | 0.15-2.7 |
| 2 | Light breeze | Wind felt on face; leaves rustle; ordinary vanes moved by wind | 6-8 | 525-700 | 2.7-3.6 |
| 3 | Gentle breeze | Leaves and small twigs in constant motion; wind extends light flag | 8-16 | 700-1400 | 3.6-7.2 |
| 4 | Moderate breeze | Raises dust and loose paper; small branches moved | 16-20 | 1400-1800 | 7.2-8.9 |
| 5 | Fresh breeze | Small trees in leaf begin to sway | 20-28 | 1800-2500 | 8.9-12.5 |
| 6 | Strong breeze | Large branches in motion; whistling heard in telegraph wires | 28-32 | 2500-2800 | 12.5-14.5 |
| 7 | Moderate gale | Whole trees in motion; inconvenience felt when walking into wind | 32-44 | 2800-3900 | 14.5-20 |
| 8 | Gale | Twigs broken off trees; generally impedes progress | 44-50 | 3900-4400 | 20-22 |
| 9 | Strong gale | Slight structural damage, e.g. slates and chimney pots removed from roofs | 50-62 | 4400-5450 | 22-28 |
| 10 | Storm | Trees uprooted; considerable structural damage | 62-70 | 5450-6150 | 28-31 |
| 11 | Violet storm | Widespread damage | 70-82 | 6150-7200 | 31-37 |
| 12 | Hurricane | | > 82 | > 7200 | > 37 |

Chill effect is the cooling effect of air movement. It is defined as the reduction in dry bulb air temperature which would give the same cooling effect in still air.

| <i>Air velocity</i> | | <i>Chill effect</i> | |
|---------------------|---------------|---------------------|-----------|
| <i>m/s</i> | <i>ft/min</i> | <i>°C</i> | <i>°F</i> |
| 0.1 | 20 | 0 | 0 |
| 0.25 | 50 | 0.5 | 2 |
| 1.5 | 300 | 4 | 7 |
| 3 | 600 | 6 | 10.5 |
| 5 | 1000 | 7 | 13 |
| 8 | 1575 | 8 | 15 |
| 10 | 2000 | 9 | 16 |

Natural ventilation

Relies on natural forces of wind and temperature differences to generate flow of air.



Advantages



- Absence of mechanical components.
- No plant room needed.
- Reduction in building energy requirements.

Disadvantages

- Close control not practicable.
- Incoming air cannot be filtered.
- Difficult to exclude external noise.
- Paths for flow of air must form part of architectural building design.
- Cost saving of mechanical plant may be offset by increased cost of special building components.

Typical schemes





Mixed mode ventilation

Mechanical ventilation is used in winter to avoid cold draughts and natural ventilation in summer to save energy.

Design requirements

Inlets and air paths to be arranged to avoid draughts.

Internal heat gains to be kept to a minimum.

Solar heat gain through glazing to be limited.

A higher room temperature is acceptable than with full air conditioning.

Daylighting and natural ventilation are improved by increased floor to ceiling height.

Building shape to ensure adequate wind pressure difference between inlet and outlet opening.

Air leakage through building joints and materials to be kept to a minimum. For controllable nature ventilation air tightness not to exceed $5 \text{ m}^3/\text{hr}$ per m^2 facade.

Openings to be adjustable and well sealed when closed to allow for difference in wind and stack effects between winter and summer.

Fire dampers to be provided at openings in fire walls.

Consideration to be given to sound insulation.

Supply air to interior areas not to pick up contamination from occupants and equipment in external areas.

Design procedure

- 1 Air flow requirements for summer cooling.
- 2 Selection of inlet and outlet ventilation openings.
- 3 Driving pressure due to wind and stack effects.
- 4 Resistance of flow path.
- 5 Size of ventilation openings to give required flow rate.

1 Air flow

Flow required for cooling calculated as for mechanical ventilation.

Computer programs take account of effect of thermal mass of building over 24 hour period.

For natural ventilation room air temperature can be higher than with full air conditioning.

2 Openings

Windows

Trickle ventilators

Louvres

Underfloor ducts

Chimney type stacks

Dampers - manual or automatic control

3 Driving pressure

(a) Wind pressure

Driving pressure due to wind is difference between wind pressures on inlet and outlet sides of building.

$$P_w = 0.5C_p \rho V_w^2$$

where

P_w = Wind pressure (N/m^2)

C_p = Wind coefficient on wall

V_w = Wind speed (m/s)

ρ = Density of air (kg/m^3)

Data on wind coefficients has been published by Air Infiltration and Ventilation Centre, Coventry.

(b) Stack effect

Driving pressure due to stack effect

$$\Delta P_s = \rho_i g h \frac{(T_i - T_o)}{T_o}$$

where

 ΔP_s = stack driving pressure (N/m²) ρ_i = density of internal air (kg/m³) g = acceleration of gravity = 9.81 m/s² h = difference in height of inlet and outlet openings (m) T_i = internal temperature (°K) T_o = outside temperature (°K)**4 Resistance of flow path**

To be calculated as for large ducts with low air velocity.

5 Size of openings

Pressure drop across openings = total driving pressure - pressure drop through building.


$$A = \frac{Q}{C_d} \left[\frac{\rho}{2\Delta P} \right]^{1/2}$$

where

 A = area of opening (m²) Q = air flow (m³/s) C_d = discharge coefficient (can be taken as 0.61) ρ = density of inside air (kg/m³) ΔP = pressure drop across opening (N/m²)**Fume and dust removal****Equipment for industrial exhaust systems**

- A Suction hoods, booths, or canopies for fume and dust collection, or suction nozzles, or feed hoppers for pneumatic conveying.
- B Conveying, ducting or tubing.
- C Fan or exhauster to create the necessary pressure or vacuum for pneumatic conveying.
- D Dust separator, for separating the conveyed material from the conveying air.

Classification of schemes



Pneumatic conveying plants are suitable for conveyance of material in powdered form or in solids up to 50 mm size, dry: not more than 20% moisture, not sticking.


Efficiency of pneumatic conveying plants is low but compensated by easy handling, free of dust.

Suction type – Distance of conveying up to 300 m difference in heights up to 40 m. Required vacuum 200 to 400 mm mercury.

Pressure type – Distance of conveying above 300 m working pressure up to 40 kN/m². Advantage: possibility of conveying material over long distance by connecting more systems in series.

Working pressure above 40 kN/m² not suitable, because of high running cost.

Types of hoods



A flow of air into the hood resists cross draughts which would carry fumes and convected heat from appliances into the room.


Projection of hood beyond range 300 mm. Projection to be beyond open position of oven doors. Underside of hood 2000-2100 mm above floor level. Extract air velocity across face of hood 0.25 to 1.5 m/s. Mechanical supply air 85% of extract, 15% by natural infiltration.

Face velocity of mesh type grease filter 2-5 m/s, for baffle type 5 m/s.

Recommended velocities through top hoods and booth, subject to cross draughts in m/s

| | | | |
|-----------------------------|----------|------------------------|-----------|
| Canopy hood, open | 1.0-1.5 | Canopy hood, double | 5.0 |
| Canopy hood, closed 1 side | 0.9-1.0 | Booths, through 1 side | 0.5-0.75 |
| Canopy hood, closed 2 sides | 0.75-0.9 | Laboratory hoods, | |
| Canopy hood, closed 3 sides | 0.5-0.75 | through doors | 0.25-0.35 |

Coefficients of entry and velocity. Pressure loss of duct extraction hoods



| | | | | |
|------------------------------------|------|------|------|------|
| <i>VELOCITY</i> | | | | |
| <i>PRESSURE LOSS</i> | 0.11 | 0.49 | 0.60 | 1.10 |
| <i>COEFFICIENT "C_e"</i> | 0.95 | 0.82 | 0.79 | 0.61 |

Flow of air into a hood

$Q = 1.3 C_e A_t \sqrt{h_t}$
 $Q =$ Air volume m³/s
 $C_e =$ Entrance coefficient
 $A_t =$ Area of throat, m²
 $h_t =$ Static suction in throat, N/m²

$Q = 4000 C_e A_t \sqrt{h_t}$
 $Q =$ Air volume ft³/min
 $C_e =$ Entrance coefficient
 $A_t =$ Area of throat, ft²
 $h_t =$ Static suction in throat, inches w.g.

Coefficient of entry

Entrance loss into hood

$C_e = \sqrt{\frac{h_v}{h_t}}$ ($h_v =$ velocity pressure) $C_e h_t = \frac{(I - C_e^2)}{C_e^2} h_v$

The transporting velocity for material varies with the size, specific gravity and shape of the material (Dalla Valle)

Vertical lifting velocity

$$V = 10.7 \frac{s}{s+1} \times d^{0.57} \qquad V = 13\,300 \frac{s}{s+1} \times d^{0.57}$$

Horizontal transport velocity

$$V = 8.4 \frac{s}{s+1} \times d^{0.40} \qquad V = 6000 \frac{s}{s+1} \times d^{0.40}$$

V = Velocity m/s
 s = Specific gravity of material
 d = Average dia of largest particle in mm


V = Velocity ft/min
 s = Specific gravity of material
 d = Average dia of largest particle in in.

Friction loss of mixture

$$\frac{F_m}{F_a} = 1 + 0.32 \left(\frac{W_s}{W_a} \right)$$

where



- F_m = Friction loss of mixture
- F_a = Friction loss of air
- W_s = Mass of solid
- W_a = Mass of air



Velocity contours and flow directional lines in radial plane of circular suction pipe.

CHART 4. DUCT SIZING FOR VENTILATION SCHEMES

→ FRICTION IN INCHES OF WATER PER 100 ft.








CHART 4a. DUCT SIZING FOR HIGH AIR VELOCITIES







→ *FRICIONAL RESISTANCE N/m² PER m RUN*

ENTHALPY LINES ARE NOT PARALLEL TO WET BULB LINES.
 TO OBTAIN THE ENTHALPY OF ANY POINT IT IS NECESSARY
 TO ALIGN A STRAIGHT EDGE ACROSS THE CHART AND READ
 THE SCALE SURROUNDING THE CHART

CHART 5. PSYCHROMETRIC CHART FOR AIR



REPRODUCED BY PERMISSION OF



THE CHARTERED INSTITUTION OF BUILDING SERVICES ENGINEERS

Carrying velocities. (For dust extraction and pneumatic conveying)

| <i>Material</i> | <i>m/s</i> | <i>ft/min</i> |
|-----------------------------|------------|---------------|
| Ashes, powdered clinker | 30-43 | 6500-8500 |
| Cement | 30-46 | 6500-9000 |
| Coal, powdered | 20-28 | 4000-5500 |
| Coffee beans | 15-20 | 3000-4000 |
| Cork | 17-28 | 3500-5500 |
| Corn, wheat, Rye | 25-36 | 5500-7000 |
| Cotton | 22-30 | 4500-6500 |
| Flour | 17-30 | 3500-6500 |
| Grain dust | 10-15 | 2000-3000 |
| Grinding and foundry dust | 17-23 | 3500-4500 |
| Jute | 22-30 | 4500-6500 |
| Lead dust | 20-30 | 4500-6500 |
| Leather dust | 8-12 | 1800-2500 |
| Lime | 25-36 | 5500-7500 |
| Limestone dust | 10-15 | 2000-3500 |
| Metal dust | 15-18 | 3500-4000 |
| Oats | 22-30 | 4500-6500 |
| Plastic moulding powder | 15-17 | 3000-3500 |
| Plastic dust | 10-12 | 2000-2500 |
| Pulp chips | 22-36 | 4500-7000 |
| Rags | 22-33 | 4500-6500 |
| Rubber dust | 10-15 | 2000-3000 |
| Sand | 30-46 | 6000-9000 |
| Sandblast | 17-23 | 3500-4500 |
| Sawdust and shavings, light | 10-15 | 2000-3000 |
| Sawdust and shavings, heavy | 17-23 | 3500-4500 |
| Textile dust | 10-15 | 2000-3500 |
| Wood chips | 20-25 | 4500-5500 |
| Wool | 22-30 | 4500-6000 |

Minimum particle size for which various separator types are suitable

| | |
|--------------------------------|-----------------------------------|
| Gravity | 200 microns (1 micron = 0.001 mm) |
| Inertial | 50 to 150 |
| Centrifugal, large dia cyclone | 40 to 60 |
| Centrifugal, small dia cyclone | 20 to 30 |
| Fan type | 15 to 30 |
| Filter | 0.5 |
| Scrubber | 0.5 to 2.0 |
| Electrical | 0.001 to 1.0 |

Size of particles

| | |
|-----------------|-------------|
| Outdoor dust | 0.5 microns |
| Sand blasting | 1.4 |
| Foundry dust | 1.0 to 200 |
| Granite cutting | 1.4 |
| Coal mining | 1.0 |
| Raindrops | 500 to 5000 |
| Mist | 40 to 500 |
| Fog | 1 to 40 |
| Fly ash | 3 to 70 |
| Pulverised coal | 10 to 400 |

Drying

Weight of air to be circulated

$$W = \frac{X}{w_2 - w_1}$$

W = Mass of air to be circulated (kg/s)
 X = Mass of water to be evaporated (kg/s)
 w_1 = Absolute humidity of entering air (kg/kg)
 w_2 = Absolute humidity of leaving air (kg/kg)

The relative humidity of the air leaving the dryer is usually kept below 75%.

Heat amount

- Total heat amount =
- 1 Heat for evaporating moisture
 - 2 Heat for heating of stock
 - 3 Heat-loss due to air change
 - 4 Heat transmission loss of drying chamber

Water content of various materials

| <i>Material</i> | <i>Original per cent</i> | <i>Final per cent</i> | <i>Material</i> | <i>Original per cent</i> | <i>Final per cent</i> |
|--------------------|--------------------------|-----------------------|-------------------|--------------------------|-----------------------|
| Bituminous coal | 40-60 | 8-12 | Hides | 45 | 0 |
| Earth | 45-50 | 0 | Glue | 80-90 | 0 |
| Earth, sandy | 20-25 | 0 | Glue, air dried | 15 | 0 |
| Grain | 17-23 | 10-12 | Macaroni | 35 | 0 |
| Rubber goods | 30-50 | 0 | Soap | 27-35 | 25-26 |
| Green hardwood | 50 | 10-15 | Starch | 38-45 | 12-14 |
| Green softwood | 30-50 | | Starch, air dried | 16-20 | 12-14 |
| Air dried hardwood | 17-20 | | Peat | 85-90 | 30-35 |
| Air dried softwood | 10-15 | | Yarn, washing | 40-50 | 0 |
| Cork | 40-45 | | 10-15 | | |

Drying temperatures and time for various materials

| <i>Material</i> | <i>Temperature</i> | | <i>Time hr</i> | <i>Material</i> | <i>Temperature</i> | | <i>Time hr</i> |
|-------------------|--------------------|-----------|----------------|-----------------|--------------------|-----------|----------------|
| | <i>°C</i> | <i>°F</i> | | | <i>°C</i> | <i>°F</i> | |
| Bedding | 66-88 | 150-190 | | Hides, thin | 32 | 90 | 2-4 |
| Cereals | 43-66 | 110-150 | | Ink, printing | 21-150 | 70-300 | |
| Coconut | 63-68 | 145-155 | 4-6 | Knitted fabrics | 60-82 | 140-180 | |
| Coffee | 71-82 | 160-180 | 24 | Leather, | | | |
| Cores, oil sand | 150 | 300 | 0.5 | thick sole | 32 | 90 | 4-6 |
| Films, photo | 32 | 90 | | Lumber: | | | |
| Fruits, vegetable | 60 | 140 | 2-6 | Green, | | | |
| Furs | 43 | 110 | | hardwood | 38-82 | 100-180 | 3-180 |
| Glue | 21-32 | 70-90 | 2-4 | Green, | | | |
| Glue size on | | | | softwood | 71-105 | 160-220 | 24-350 |
| furniture | 54 | 130 | 4 | Macaroni | 32-43 | 90-110 | |
| Gut | 66 | 150 | | Matches | 60-82 | 140-180 | |
| Gypsum wall | | | | Milk | 120-150 | 250-300 | |
| board | | | | Paper glued | 54-150 | 130-300 | |
| Start wet | 175 | 350 | | Paper treated | 60-93 | 140-200 | |
| Finish | 88 | 190 | | Rubber | 27-32 | 80-80 | 6-12 |
| Gypsum blocks | 175-88 | 350-180 | 8-16 | Soap | 52 | 125 | 12 |
| Hair goods | 66-88 | 150-190 | | Sugar | 66-93 | 150-200 | 0.3-0.5 |
| Hats, felt | 60-82 | 140-180 | | Tannin | 120-150 | 250-300 | |
| Hops | 49-82 | 120-187 | | Terra cotta | 66-93 | 150-200 | 12-96 |

Defogging plants

The defogging of rooms is carried out by blowing in dry, hot air and exhausting humidified air.

Mass of water evaporated from open vats

$$\frac{W}{A} = (0.037 + 0.032 \nu) \times 10^{-3} (p_s - p_w)$$

where

W = mass of water evaporated, kg/s

A = surface area, m²

ν = velocity of air over surface, m/s

p_s = pressure of saturated vapour at temperature of water, kPa

p_w = actual pressure of water vapour in the air, kPa

Mass of air to be circulated

$$G = \frac{W}{(w_2 - w_1)}$$

where

G = Mass of air, kg/s

W = Mass of water vapour to be removed, kg/s

w_1 = Original absolute humidity of air, kg/kg

w_2 = Final absolute humidity of air, kg/kg

Amount of heat

$$H = Gc (t_i - t_o)$$

where

H = Amount of heat, without fabric loss of room or other losses, W

G = Mass of air (see above), kg/s

t_i = Inside air temperature, °C

t_o = Outside air temperature, °C

c = Specific heat capacity of air = 1.012×10^3 J/Kg °C

12 Air conditioning

Design procedure for air conditioning

- 1 Cooling load calculation
 - (a) Sensible heat load due to
 - (i) heat gain through walls, etc.
 - (ii) solar radiation.
 - (iii) heat emission of occupants.
 - (iv) infiltration of outside air.
 - (v) heat emission of lights and machinery.
 - (b) Latent heat load due to
 - (i) moisture given off by occupants.
 - (ii) infiltration of outside air.
 - (iii) moisture from process machinery.
- 2 Selection of air treatment process. For processes and psychrometric chart see pages 80, 81 and Chart 5.
- 3 Determination of air quantities.
- 4 Layout and sizing of ducts.
- 5 Determination of capacities of air treating units, allowing for heat gains in ducts.
- 6 Determination of refrigerator and boiler duties.
- 7 Determination of pump and fan duties.

Methods of cooling air

- 1 Spray type washer.
- 2 Surface type cooler
 - (i) Indirect. By heat exchange with water which has been cooled by a refrigerant.
 - (ii) Direct. By heat exchange in evaporator of a refrigerator system.


Methods of refrigeration

1 Compression system


Hot compressed vapour leaves a compressor and is liquified in a condenser by heat exchange with cooling water or air. The liquid refrigerant then passes through an expansion valve and the low pressure liquid enters the evaporator. It absorbs heat from the medium to be cooled and is vaporised. The vapour enters the compressor and is raised to a higher pressure.

2 Absorption system


A solution of water in a solvent is raised to a high pressure and heated which causes the dissolved water to vaporise. The vapour is liquified in a condenser and then passes through an expansion valve. Now at low pressure the water enters the evaporator, absorbs heat from the medium to be cooled and vaporises. The vapour returns to be absorbed in the solvent.



FLOW DIAGRAM




PRESSURE - ENTHALPY DIAGRAM




TEMPERATURE - ENTROPY DIAGRAM

VAPOUR COMPRESSION CYCLE



BASIC ABSORPTION CYCLE



ABSORPTION CYCLE WITH SOLUTION HEAT EXCHANGER


Types of system

- 1 Cooling only (comfort cooling).
- 2 Cooling or heating.
- 3 Cooling or heating with control of humidity (full air conditioning).


In all systems heat is removed from the conditioned space and rejected to atmosphere outside the building.

Types of compressor

1. **RECIPROCATING** Pistons driven in cylinders by crankshaft. Suction and discharge valves are thin plates which open and close easily. Most widely used type. Step control by unloading cylinders.
2. **CENTRIFUGAL** Similar in construction to centrifugal pump. Vaned impeller rotates inside a casing and gas pressure is increased by centrifugal action. Suitable for very large capacities. Infinitely variable control by:
 - a) Variable speed drive
 - b) Suction throttle valve
 - c) Variable inlet guide vanes
3. **SCREW** Two meshing helically shaped screws rotate and compress gas as the volume between them decreases towards the discharge side. Reliable, efficient and comparatively cheap. Used for larger duties. Infinitely variable control by bypassing partly compressed gas back to suction inlet.
4. **ROTARY** Rotor with blades sliding radially is eccentric to casing. As it turns gas is swept into a smaller volume. Has few parts and can be relatively quiet and vibration free. Used for small duties such as wall or window units.



ROTARY COMPRESSOR




SCROLL COMPRESSOR

5. **SCROLL** Two helically shaped scrolls are interleaved in such a way that as they rotate the space between them decreases from the suction to the discharge openings and thus compresses the gas. Suitable for medium to large commercial applications.

Free cooling

At low ambient air temperatures chilled water to air conditioning systems can be cooled directly by cold water from the cooling tower and the refrigeration plant can be switched off.



*DOTTED LINES SHOW CIRCUIT AT LOW AMBIENT TEMPERATURES
THREE WAY VALVES ARE CONTROLLED BY AMBIENT AIR WET BULB TEMPERATURE*

Units

Cooling is expressed in the same units as heating, namely kW or Btu/hr.

Another unit much used formerly was the Ton of Refrigeration. This was the cooling produced when one American ton of ice melted at 32°F in 24 hours. Since the latent heat of melting ice at 32°F is 144 Btu/lb

$$\begin{aligned}
 1 \text{ ton of refrigeration} &= 2000 \text{ lb} \times 144 \text{ Btu/lb in 24 hours} \\
 &= 288\,000 \text{ Btu in 24 hours} \\
 &= 12\,000 \text{ Btu/hr} \\
 &= 3.517 \text{ kW}
 \end{aligned}$$

Air washer

Air washers are sheet metal, or sometimes brick or concrete chambers, in which air is drawn through a mist caused by spray nozzles and then through eliminators to remove particles of water not evaporated into the air. The water for the spray nozzles is recirculated by a pump and can be heated or cooled. A tempering heater is installed before, and a reheating battery after the air washer.

General data

| | |
|-----------------------------|---|
| Cleaning efficiency | 70% on fine dust 98% on coarse dirt |
| Air velocity through washer | 2-3 m/s 450-550 ft/min |
| Resistance | 50-140 N/m ² 0.2-0.5 in water gauge |
| Water pressure for sprays | 100-170 kN/m ² 15-25 lb/in ² |
| Water quantity | 0.45-0.55 l/m ³ air 3-3.5 gal per 1000 ft ³ air |

Humidifying efficiency

$$E = \frac{t_1 - t_2}{t_1 - t_w} \times 100\%$$

where

- t_1 = initial dry bulb temperature
- t_2 = final dry bulb temperature
- t_w = initial wet bulb temperature.

Typical efficiencies obtained are

- 60-70% with one bank of nozzles downstream
- 65-75% with one bank of nozzles upstream
- 85-100% with two banks of nozzles.

Shell and tube cooler

Shell and tube coolers consist of plain or finned tubes in an outer shell. Air flows through the shell and a liquid coolant (water, brine or refrigerant) flows through the tubes. The air can be dehumidified as well as cooled by being cooled below its dew point so that part of the moisture is condensed.

Surface area of cooler

$$A = \frac{H}{U(t_a - t_m)}$$

where

- A = area of cooling surface (m²)
- H = cooling rate (kW)
- U = heat transfer coefficient (kW/m² K)
- $t_a - t_m$ = log mean temperature difference between air and coolant (K)

Direct dehumidification

Classification

- 1 Adsorption type.
- 2 Absorption type.

Adsorption type

In adsorption systems the humidity is reduced by adsorption of moisture by an adsorbent material such as silica gel or activated alumina. Adsorption is a physical process in which moisture is condensed and held on the surface of the material without any change in the physical or chemical structure of the material. The adsorbent material can be reactivated by being heated, the water being driven off and evaporated.

The adsorption system is particularly suitable for dehumidification at room temperature and where gas or high pressure steam or hot water is available for reactivation.

| | |
|--------------------------------|---|
| Temperature for reactivation | 160–175°C 325–350°F |
| Heat required for reactivation | 4800–5800 kJ/kg water removed 2100–2500 Btu/lb water removed |

Silica gel SiO_2 , is a hard, adsorbent, crystalline substance; size of a pea; very porous.

Voids are about 50% by volume.

Adsorbs water up to 40% of its own mass

Bulk density 480–720 kg/m^3

Specific heat capacity 1.13 kJ/kg K

Activated alumina is about 90% aluminium oxide, Al_2O_3 ; very porous

Voids about 50–70% by volume

Adsorbs water up to 60% of its own mass

Bulk density 800–870 kg/m^3

Specific heat capacity 1.0 kJ/kg K

Absorption type

In absorption systems the humidity is reduced by absorption of moisture by an absorbent material such as calcium chloride solution. Absorption involves a change in the physical or chemical structure of the material and it is not generally practicable to reactivate the material.


Humidification

Classification

- 1 Sprayed coil.
- 2 Spinning disc.
- 3 Steam humidifier.


Sprayed coil

Water is discharged into the air stream flowing onto a finned cooling coil. The discharge is through banks of high-pressure nozzles which produce a finely divided spray of water droplets. The fins of the cooling coil provide additional surface on which the water evaporates into the air. Eliminator plates at the exit from the humidifier prevent carry over of unevaporated water droplets. Excess water is collected at the base of the unit and recirculated to the nozzles by a pump. Air velocity through unit 2.0–3.5 m/s.



Spinning disc

Water flows as a fine film over the surface of a rapidly revolving vertical disc. It is thrown off the disc by centrifugal action onto a toothed ring and broken up into fine particles.



Steam humidifier

Electrode-type steam generator delivers low pressure steam to a perforated distributor pipe in the air stream. Because the water is boiled this method reduces the risk of transferring water-borne bacteria to the air.

Precautions against legionellosis

Humidifiers creating a spray should be supplied with treated and disinfected water which is not allowed to stand in equipment or tanks. Cooling towers to be positioned away from air inlets and populated areas, to have high efficiency drift eliminators and have the section above the pond enclosed to reduce wind pick up. Water to be treated to reduce scale, sediments and bacteria.

Duct work to be designed so that water cannot accumulate in air stream. Drains to have air break.

Air conditioning systems

1 Self-contained wall or window unit

Unit mounted in wall or window with evaporator inside room and condenser outside room.

Advantages

- Low cost.
- Flexible.
- Simple.

Disadvantages


- Short life.
- Noise.
- Poor control.
- Poor filtration and air distribution.
- Lack of fresh air supply.
- Unsightly.

Applications

- Small buildings, individual rooms.

2 Split direct expansion (DX) unit

Air cooled condenser is separate and remote from indoor unit. Compressor can be in either part but is usually in the outdoor unit.



Advantages

- Indoor unit need not be on outside wall.
- Indoor unit can be ceiling mounted.
- Silencers can be incorporated for indoor unit.
- Multiple refrigerant circuits give improved control.
- Relatively simple.

Disadvantages

- Restriction on length of refrigerant piping between indoor and outdoor units.
- Restriction on difference in level between indoor and outdoor units.
- Limited fresh air supply.

Applications

- Small shops, computer rooms, individual rooms or areas.

3 Split system reversible heat pump

Split system direct expansion with changeover valves enabling functions of condensing and evaporating coils to be reversed.

Advantages


- Similar to split cooling only system.
- Provides winter heating as well as summer cooling.

Disadvantages

- Similar to split cooling only system.
- Heating and cooling capacities not independent of each other.


Applications

Small shops, individual rooms or areas.



- VALVES IN POSITION SHOWN IN FULL LINES
- INDOOR UNIT EVAPORATES } ROOM IS
 - OUTDOOR UNIT CONDENSES } COOLED
- VALVES IN POSITION SHOWN DOTTED
- INDOOR UNIT CONDENSES } ROOM IS
 - OUTDOOR UNIT EVAPORATES } HEATED

For small duties the units are simplified by the use of a capillary which can operate in either direction instead of expansion valves.



4 Water cooled unit

Self-contained indoor unit consisting of evaporator, compressor and water cooled condenser with separate outdoor cooling tower.

Advantages

- Quieter than air cooled unit.
- Flexibility in location of outdoor and indoor units.
- Better control than air cooled units.

Disadvantages

- Cooling water treatment advisable.
- Maintenance of cooling water circuit.

Applications

- Computer rooms.

5 Glycol cooled unit

Self-contained indoor unit consisting of evaporator, compressor and glycol cooled condenser with remote forced draught glycol/air heat exchanger.

Advantages

- No water treatment problems.
- Protection against freezing.

Disadvantages

- Need to ensure glycol is retained in system.


Applications

- Computer rooms.


6 Fan coil units

Chilled water or hot water is circulated from central plant to individual units in which room air is cooled or heated.

- (a) *Two-pipe system.* One pair of pipes used for chilled water in summer and for hot water in winter. Suitable for continental climate with sharp difference between summer and winter. Not suitable for temperate climate as in the United Kingdom.



- (b) *Four-pipe system.* Separate pairs of pipes for chilled water and hot water. More expensive but more flexible control for use in temperate climates. Some rooms can be cooled while others are heated.



Advantages


- Flexible.
- Straightforward design.
- Good control.

Disadvantages

- Additional provision needed for fresh air supply.
- Condense drain from each unit and/or separate provision for dehumidification.

Applications

- Offices, hotel bedrooms, luxury housing, schools.





CENTRAL PLANT FOR FAN COIL SYSTEM

Design parameters

| | |
|---|----------|
| Chilled water flow to fan coils | 5°C–10°C |
| Chilled water temperature rise in fan coils | 5 K–6 K |
| Hot water flow to fan coils | 80°C |
| Hot water temperature drop in fan coils | 10 K |

7 Heat recovery units (Versatemp system from Temperature Ltd.)

Self-contained refrigeration/heat pump room units reject heat to water circulating throughout building when cooling or take heat from the water when heating. Heat rejected by units acting as coolers is supplied to units acting as heaters. Central plant to provide cooling and heating is needed to balance the cooling/heating loads.



CENTRAL PLANT FOR HEAT RECOVERY SYSTEM

Advantages

Energy conservation, particularly in temperate climates.

Disadvantages

Units are larger than fan coil units.

Applications

Offices.

Design parameters

Water flow to units controlled at 27°C .

Return from individual unit

when heating 19°C

when cooling 38°C .

To achieve 27°C in summer conditions the circulating water must be cooled in a cooling tower.

Temperature Ltd offer an extended range of room units which operate with a water flow temperature of 37°C . This allows the circulating water to be cooled in a dry air blast cooler.

For water flow to units at 37°C return from individual unit


when heating 32°C

when cooling 44°C .


Disadvantage of operating at higher temperature is that room units are bigger for same duty.

8 Induction system

A central air plant delivers conditioned air through high-velocity ducting to induction units in the rooms. Water from a central plant is also supplied to the induction units. The conditioned, or primary, air supplied to the units induces room, or secondary, air through the unit. This induced secondary air passes over the water coil and is thus heated or cooled.



- Two-pipe changeover system.* One pair of pipes used for chilled water in summer and for hot water in winter. Not suitable for temperate climate.
- Two-pipe non-changeover system.* One pair of pipes for chilled water only, with heating by primary air only.
- Four-pipe system.* Separate pairs of pipes for chilled water and hot water. Lower running cost and better control than two-pipe non-changeover system.



Advantages

- Space saving through use of high velocity and small diameter ducts.
- Low running costs.
- Individual room control.
- Very suitable for modular building layouts.
- Central air plant need handle only part of the air treated.
- Particularly applicable to perimeter zones of large buildings.
- Suitable for large heat loads with small air volumes.

Disadvantages

- High capital cost.
- Design, installation and operation are all more complex than with fan coil system.
- Individual units cannot be turned off.


Applications

Offices.

Design parameters

| | |
|--|---|
| Fresh air quantity | 0.012 m ³ /s per person or as needed for ventilation |
| Air velocity in primary ducts | 15-20 ms |
| Induction unit ratio secondary air/primary air | 3 : 1 |
| Pressure of primary air at units | 200 N/m ² |
| Hot water flow to units | 80°C |
| temperature drop in units | 10 K or as specified by manufacturer |
| Chilled water flow to units | 5-10°C but taking into account dew point of room air |
| temperature rise in units | 5-6 K or as specified by manufacturer |


Water and air quantities and temperatures to be checked for compatibility and required outputs at both summer and winter conditions.



SCHEME OF CENTRAL PLANT FOR INDUCTION SYSTEM

9 All air constant volume reheat system

Central or local plant with cooler sized for latent heat cooling load and reheater to balance for sensible heat load and for winter heating. Reheater can be remote from cooler; several reheaters can be used with one cooler to give a degree of local control. Can incorporate humidifier with preheater to give complete control of discharge air temperature and humidity.



Advantages

Simple.

Free cooling available at low outdoor temperatures.

Several reheat zones can be used to improve control.

Good air distribution possible because diffusers handle constant volume.

Independent control of temperature and humidity.

Disadvantages

Wastes energy by reheat.

Expensive in both capital and running cost.

Space occupied by air ducts.

Large volume of air to be treated in central plant.

Recirculating system necessary.

Applications


Industrial, small commercial, internal areas of large buildings, houses, apartments, shopping malls, supermarkets, large stores, restaurants, theatres, cinemas, concert halls, museums, libraries, swimming pools, sports centres, clean rooms, operating theatres, large computer installations.

Design parameters

| | |
|-------------------------------------|--|
| Fresh air quantity: | 0.012 m ³ /s per person or as needed for ventilation |
| Air velocity: | as for ventilation systems, see Chapter 11 |
| Supply air temperature for heating: | 38°C–50°C |
| for cooling: | 6–8 K below room temperature |
| Recirculating air quantity: | as required to carry heat load at specified temperature difference between room and supply air |

10 Dual duct system

A central plant delivers two streams of air through two sets of ducting to mixing boxes in the various rooms. The two streams are at different temperatures.

**Advantages**

- Cooling and heating available simultaneously.
- Free cooling available at low outdoor temperatures.
- Individual room control – zoning not necessary.
- Flexible in operation.

Disadvantages

- Two sets of supply air ducting are needed, using more space.
- More air has to be treated in central plant.
- Recirculation system necessary.
- Expensive in both capital and running costs.

Applications

- Hospitals, public rooms of hotels.

11 Multizone units

Similar to dual duct system but mixing of air streams takes place at central plant for several building zones.

Advantages

- Only one supply duct needed to each zone.
- Free cooling available at low outdoor temperatures.

Disadvantages


- Suitable only for limited number of zones.
- Poor control if duties of zones differ greatly.
- Recirculating system necessary.

Applications

Small buildings, groups of rooms in public buildings, swimming pools, leisure centres, libraries.

12 High-velocity air systems

Similar to all air systems but operate with high air velocities in supply ducts. Outlet boxes incorporate sound attenuators. Recirculation is usually at low velocity.


(a) Single duct**Advantages**

- Space saving through use of high velocity small diameter ducts.
- Simple.
- Zone control can be used.

Disadvantages

- Large volume of air to be treated in central plant.
- Individual room control not possible.
- Recirculating system necessary – usually at low velocity.
- Outlet attenuator boxes needed to overcome noise generated by high velocity ducting.
- Higher fan pressure and fan power; increased running costs.

- (b) *Dual duct*. Similar to low-velocity dual duct but with sound attenuation incorporated in outlet boxes.



Advantages

- Space saving through use of high-velocity small diameter ducts.
- Individual room control – zoning not necessary.
- Flexible in operation.
- Can handle larger air volumes than single duct.

Disadvantages

- Two sets of supply air ducting are needed, using more space.
- More air has to be treated in central plant.
- Recirculating system necessary – usually at low velocity.
- Outlet boxes must include attenuators to overcome noise generated in high-velocity ducting.
- Higher fan pressure and fan power increase running costs.

Applications

- Offices, public rooms of hotels, internal areas of large buildings.

Design parameters for single and dual duct high-velocity systems

- | | |
|-------------------------------------|------------------------------|
| Air velocities in ducts: | 15–20 m/s |
| Pressure at inlet to furthest unit: | 100–250 N/m ² |
| Typical pressure at fan: | 1250–1500 N/m ² |
| Air quantities and temperatures: | as for low-velocity systems. |

13 Variable air volume system

An all air system in which local control is obtained by varying volume discharged at each diffuser or group of diffusers in response to the dictates of a local thermostat. Capacity of supply and extract fans is reduced as total

system volume requirement falls at part load. Fans controlled by:

- (a) Variable speed.
- (b) Variable blade pitch.
- (c) Variable inlet guide vanes.
- (d) Disc throttle on fan outlet.

Satisfactory operation is critically dependent on the design and performance of the terminal diffuser units. Manufacturer's data must be adhered to.

Advantages

- Efficient part load operation.
- Individual room or area control.
- Unoccupied areas can be closed off with dampers.

Disadvantages

- Special provision needed for heating.
- Extra controls needed to maintain minimum fresh air supply to terminals operating at low load.
- Complexity of controls.
- Cannot provide full control of humidity.

Methods of providing heating

- (a) *Perimeter heating with VAV cooling only to core of building*
 - Simple.
 - Running cost uneconomic.
 - Controls may cause perimeter heating to add unnecessarily to cooling load.
- (b) *Dual-duct system*
 - Expensive in capital cost.
 - Complicated and difficult to control.
 - Two sets of supply air ducting, using more space.
- (c) *Reheater in each terminal unit*
 - Simple and effective.
 - Reheating cooled air reduces the economic operation which is chief attraction of variable air volume.

Applications

Offices, hospitals, libraries, large stores, schools.

Design parameters

| | |
|------------------------------------|---|
| Air velocities in ducts | 10–15ms |
| Supply air temperature for cooling | 9–11 K below room temperature |
| for heating | max 35°C |
| Throw and spacing of units | in accordance with manufacturer's recommendations |
| Turn down ratio | as advised by manufacturer 30%–20% can be achieved. |

14 Displacement ventilation

Cooled air is introduced at low level at low outlet velocity. It spreads across the room at floor level and is drawn in to feed plumes of warmed air rising from occupants and equipment heat sources. It is extracted at high level. Low level inlets may be on walls or columns or grilles in a false floor.

Advantages

- Removal of contaminants at source by rising plumes gives better room air quality.
- Higher supply air temperature requires less refrigeration.
- Simple plant and ductwork layout.

Disadvantages

- Separate provision needed for heating, usually perimeter heating.
- Possibility of draughts at ankle level near outlets.
- Repositioning of outlets if partitioning or furniture layout is changed.

Applications

Industrial, commercial, offices, theatres, cinemas.

Design parameters

- Supply temperature: 2–3 K below room temperature
- Discharge velocity: 0.1–0.3 m/s
- Outlets to be selected in accordance with manufacturer's data.

15 Chilled ceiling

Cool water is circulated through panels in the ceiling or through beams which may be exposed or recessed. Panels in the ceiling cool occupants by radiation from occupants to cool surface. Chilled beams have a radiant effect but also cool rising warm air and produce a convective downflow of cool air. This enables beams to have a greater cooling effect than ceiling panels.

Advantages

- Cooled rather than chilled water requires less refrigeration.
- Ventilation needed only for fresh air supply, therefore smaller volume.
- Takes up no floor space.
- Cooling by radiation permits higher room air temperature.
- Low maintenance.

Disadvantages

- Risk of condensation at cold surface requires control of room humidity.
- Insulation needed on top of ceiling panels and beams.
- Other provision needed for heating, usually perimeter heating.

Applications

Offices, public buildings.

Design parameters

| | |
|--|-----------------------------------|
| Water flow temperature: | 14–15°C |
| Water temperature rise: | 2–3 K |
| Cooling effect: | 30–80 W/m ² floor area |
| Temperature difference, room to ceiling surface: | 4–8 K |
| Temperature difference, water to ceiling surface: | 2–3 K |
| Actual data to be agreed with ceiling or beam manufacturer according to application. | |

16 Variable refrigerant volume

Similar to split direct expansion system but several indoor units are connected by a common system of refrigerant piping to one outdoor unit. Local control is obtained by varying the flow of refrigerant at each indoor unit. Compressor output is reduced as total system requirement falls at part load. A heat recovery version is possible in which hot refrigerant from units which are cooling is passed to units which are heating.

Design in accordance with manufacturer's data

Advantages

- Efficient part load operation.
- Individual room or area control.

Disadvantages

- Separate provision may be needed for heating.
- Restriction imposed by design of refrigerant piping.
- Limited fresh air supply.

Applications

- Offices

Ice storage

Ice is made when electric power for refrigeration is available at a low off-peak rate. Stored ice is used to chill water for air conditioning during peak times. The store can be used for whole or part of load. A store used for part load only reduces peak demand for refrigeration and allows smaller chillers to be used, running for longer at their full load and optimum efficiency.

Direct system

Direct heat exchange between refrigerant and ice/water.
Water alone used in secondary circuit.

Freezing and melting circuits separate.

Advantage: easier to maintain low chilled water temperature.

Disadvantage: refrigerant evaporator within ice store limits distance between store and chiller.

Indirect system

Intermediate circuit between refrigerant and ice/water.

Same circuit used for both freezing and melting. Intermediate circuit must contain anti-freeze.

Advantage: no restriction on distance between ice store and chiller.

Disadvantages: changeover valves needed.

Concentration of anti-freeze must be maintained.

Ice stores

Ice builder – refrigerant evaporator within tank of water. Ice builds on evaporator coils. Store discharged by water circulated through tank.

Ice bank – glycol mixture circulated through coil below 0°C for freezing and above 0°C for melting. No circulation through tank itself.

Equipment

To be selected from manufacturers' data.

Refrigerant evaporator must operate at lower temperature than for normal air conditioning.

Capacity

$$S = \frac{p \sum h}{\eta}$$

$$R = H - \frac{S}{n_1}$$

$$\text{or } \frac{S}{n_2}$$

where

S = stored energy (kWhr)

p = proportion of cooling demand over cycle to be stored (= 1 for full storage)

h = load during an hour of cycle (kWhr)

η = efficiency of store (normally about 0.94)

R = chiller capacity (kW)


H = peak cooling load (kW)

n_1 = time during which cooling is required (hr)

n_2 = charging period (hr)

Controls

Output regulated by variation of flow of chilled water through store. Detection of quantity of ice in store can be used to vary timing of cycle.



Properties of refrigerants

Under European legislation the use of chlorofluorocarbons is banned from 31st December 2000. The use of hydrochlorofluorocarbons is being phased out and will be banned from 1st January 2010.

The following table gives the characteristics of new and replacement refrigerants.

| <i>Refrigerant</i> | <i>Formula</i> | <i>Boiling temp. °C</i> | <i>Critical temp. °C</i> | <i>Properties</i> | <i>Applications</i> |
|--------------------|---|-------------------------|--------------------------|---|---|
| Ammonia | NH ₃ | -33 | 133 | Penetrating odour, soluble in water, harmless in concentrations up to 0.33%, non-flammable, explosive, zero ozone depletion Low global warming potential | Large industrial plants |
| Lithium Bromide | LiBr | - | - | Soluble in alcohol and ether Soluble in water Zero ozone depletion Low global warming potential | Solvent for water in absorption systems |
| R134a | CF ₃ CH ₂ F | -26 | 101 | Zero ozone depletion | Air conditioning Industrial refrigeration Domestic refrigeration Replacement for R12 |
| R404A | CF ₃ CHF ₂ (44%) CF ₃ CH ₃ (52%) CF ₃ CH ₂ F (4%) | -46 | 72 | Zero ozone depletion Non flammable Low toxicity | Cold stores and refrigerated display cabinets Replacement for R502 |
| R407A | CH ₂ F ₂ (20%) CHF ₂ CF ₃ (40%) CF ₃ CH ₂ F (40%) | -42 | 83 | Zero ozone depletion Non flammable Low toxicity | Low temperature applications Replacement for R502 |

Properties of refrigerants (continued)

| Refrigerant | Formula | Boiling Critical | | Properties | Applications |
|-------------------------------------|--|------------------|-------------|---|--|
| | | temp. °C | temp. °C | | |
| R407C | CH ₂ F ₂ (23%) CHF ₂ CF ₃ (25%) CF ₃ CH ₂ F (52%) | -43 | 87 | Zero ozone depletion Non flammable Low toxicity | Air conditioning Heat pumps Replacement for R22 |
| R410A | CH ₂ F ₂ (50%) CF ₃ CHF ₂ (50%) | -52 | 72 | Zero ozone depletion Non flammable Low toxicity Non corrosive | Air conditioning units Heat pumps Cold stores Industrial and commercial refrigeration |
| R507 | CF ₃ CHF ₂ (50%) CF ₃ CH ₃ (50%) | -47 | 71 | Zero ozone depletion Low toxicity Non corrosive | Low and medium temperature applications Refrigerated display cases Replacement for R502 |
| CARE 40 (R290) Propane | CH ₃ CH ₂ CH ₃ | -42 | 97 | Zero ozone depletion Low global warming potential Flammable Non toxic | Commercial and industrial refrigeration Air conditioning Heat pumps Alternative to R22 and R502 |
| CARE 50 (R170) | CH ₃ CH ₂ CH ₃ CH ₃ CH ₃ | -49 | 79 | Zero ozone depletion Low global warming potential Flammable Non toxic | Commercial and process refrigeration Air conditioning Heat pumps Alternative to R22 and R502 |
| CARE 10 (R600a) Isobutane | CH(CH ₃) ₃ | -12 | 135 | Zero ozone depletion Low global warming potential Flammable Non toxic | Small charge hermetic applications Domestic refrigeration |
| CARE 30 | CH(CH ₃) ₃ CH ₃ CH ₂ CH ₃ | -32 | 106 | Zero ozone depletion Low global warming potential Flammable Non toxic | Chilled food display cabinets Drinking water dispensers Alternative to R12 |

CARE is a trademark of Calor Gas Ltd

Former refrigerants

For reference and comparison the properties of previously common refrigerants which are now either obsolete or obsolescent are listed below.

| <i>Refrigerant</i> | <i>Formula</i> | <i>Boiling temp.</i> °C | <i>Critical temp.</i> °C | <i>Properties</i> | <i>Applications</i> |
|--------------------|---|----------------------------|-----------------------------|---|--|
| R12 | CCl ₂ F ₂ | -30 | 112 | Non flammable Non corrosive Stable | Small plants with reciprocating compressors |
| R11 | CCl ₃ F | 9 | 198 | Non flammable Non corrosive Stable | Commercial plants with centrifugal compressors |
| R22 | CHClF ₂ | -41 | 96 | Non flammable Non toxic Non corrosive Stable | Packaged air conditioning units |
| R500 | CCl ₂ F ₂ (74%) CH ₃ CHF ₂ (25%) | -33 | | Non flammable Non corrosive Stable | Approximately 20% more refrigeration capacity than R12. Useful when machine designed for 60 Hz had to operate on 50 Hz |
| R502 | CHClF ₂ (50%) CClF ₂ CF ₃ | -46 | 90 | Non flammable Non toxic Non corrosive | Low temperature applications |

Friction loss through fittings

The following table takes into account static regain. EL = Equivalent length of pipe.

| Fitting | | 4 in | 6 in | 8 in | 10 in | 12 in | 14 in | 16 in | 18 in | 20 in |
|---------|--|-----------|--------|--------|--------|--------|--------|--------|--------|--------|
| | | 100 mm | 150 mm | 200 mm | 250 mm | 300 mm | 350 mm | 400 mm | 450 mm | 500 mm |
| | | EL ft -9 | -15 | | | | | | | |
| | | EL m -3 | -5 | | | | | | | |
| | | EL ft 12 | 21 | | | | | | | |
| | | EL m 4 | 7 | | | | | | | |
| | | EL ft 3 | 4 | 7 | 10 | 12 | 15 | 18 | 21 | 24 |
| | | EL m 1 | 1.2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 |
| | | EL ft 1 | 2 | 4 | 5 | 6 | 8 | 9 | 10 | 12 |
| | | EL m 0.3 | 0.6 | 1.2 | 1.5 | 1.8 | 2.4 | 3 | 3 | 4 |
| | | EL ft 1 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 |
| | | EL m 0.3 | 0.3 | 0.6 | 1 | 1.2 | 1.5 | 1.8 | 2 | 2.4 |
| | | EL ft -5 | -9 | -13 | -17 | -22 | -26 | -31 | -36 | -42 |
| | | EL m -1.5 | -3 | -4 | -5 | -7 | -8 | -10 | -11 | -13 |
| | | EL ft 12 | 21 | 30 | 40 | 52 | 63 | 75 | 87 | 100 |
| | | EL m 4 | 6 | 10 | 12 | 16 | 19 | 22 | 25 | 30 |
| | | EL ft -13 | -22 | -32 | -42 | -54 | -66 | -78 | -91 | -105 |
| | | EL m -4 | -7 | -10 | -13 | -16 | -20 | -24 | -28 | -32 |
| | | EL ft 13 | 22 | 32 | 42 | 54 | 66 | 78 | 91 | 105 |
| | | EL m 4 | 7 | 10 | 13 | 16 | 20 | 24 | 28 | 32 |
| | | EL ft -8 | -10 | -11 | -13 | -17 | -20 | -24 | -28 | -32 |
| | | EL m -2.4 | -3 | -3.3 | -4 | -5 | -6 | -7 | -9 | -10 |
| | | EL ft | | | | -9 | -9 | -10 | -10 | -10 |
| | | EL m | | -3 | -3 | -3 | -3 | -3 | -3 | -3 |
| | | EL ft 13 | 22 | 32 | 42 | 54 | 56 | 78 | 91 | 105 |
| | | EL m 4 | 7 | 10 | 13 | 16 | 20 | 24 | 28 | 32 |
| | | EL ft | -21 | -30 | -40 | -52 | -63 | -75 | -87 | -100 |
| | | EL m | -6 | -10 | -12 | -16 | -19 | -22 | -25 | -30 |
| | | EL ft 13 | 22 | 32 | 42 | 54 | 66 | 78 | 91 | 105 |
| | | EL m 4 | 7 | 10 | 13 | 16 | 20 | 24 | 28 | 32 |
| | | EL ft 14 | 23 | 37 | 49 | 62 | 76 | 90 | 106 | 121 |
| | | EL m 4 | 7 | 11 | 15 | 19 | 23 | 27 | 32 | |

Design temperatures and humidities for industrial processes

| <i>Industry</i> | <i>Process</i> | <i>Temperature °C</i> | <i>Relative humidity %</i> | |
|-----------------|---|---------------------------|--------------------------------|-------|
| Textile | Cotton | carding | 24-27 | 50 |
| | | spinning | 15-27 | 60-70 |
| | | weaving | 20-24 | 70-80 |
| | Rayon | spinning | 21 | 85 |
| | | twisting | 21 | 65 |
| | Silk | spinning | 24-27 | 65-70 |
| | | weaving | 24-27 | 60-70 |
| | Wool | carding | 24-27 | 65-70 |
| | | spinning | 24-27 | 55-60 |
| weaving | | 24-27 | 50-55 | |
| Tobacco | Cigar and cigarette making | 21-24 | 55-65 | |
| | Softening | 32 | 85 | |
| | Stemming and strigging | 24-30 | 70 | |
| Paint | Drying oil paints | 15-32 | 25-50 | |
| | Brush and spray painting | 15-27 | 25-50 | |
| Paper | Binding, cutting, drying, folding, gluing | 15-27 | 25-50 | |
| | Storage of paper | 15-27 | 34-45 | |
| | Storage of books | 18-21 | 38-50 | |
| Printing | Binding | 21 | 45 | |
| | Folding | 25 | 65 | |
| | Pressing, general | 24 | 60-78 | |
| Photographic | Development of film | 21-24 | 60 | |
| | Drying | 24-27 | 50 | |
| | Printing | 21 | 70 | |
| | Cutting | 22 | 65 | |
| Fur | Storage | -2 to +4 | 25-40 | |
| | Drying | 43 | — | |

Air curtains

Heated air is blown across a door opening to prevent or reduce ingress of cold atmospheric air.

Applications

Door-less shop fronts.

Workshop entrances.

Doors of public buildings which are frequently opened.

Temperatures

Discharge Temperature: for small installation 35–50°C

for large installation 25–35°C

Suction Temperature 5–15°C

Air velocity

Flow from above 5–15 m/s

below 2–4 m/s

side 10–15 m/s

Air quantity:

Quantity required depends on too many variable factors for exact calculation to be possible. The quantity should be made as large as possible consistent with practicable heat requirements. Suggested values: 2000–5000 m³/m² hr of door opening. In very exposed situations or other difficult cases this can be increased to 10 000 m³/m² hr.

Let V_o = quantity of air entering in absence of curtain

V = quantity blown by curtain

For one-sided curtain $V = 0.45 V_o$

For two-sided curtain $V = 0.9 V_o$

Example: Width of door 4 m. Height of door 2 m. Speed of outdoor air 2 m/s.

$$\therefore V_o = 4 \times 2 \times 2 = 16 \text{ m}^3/\text{s}$$

$$\therefore V = 0.45 \times 16 = 7.2 \text{ m}^3/\text{s}$$

Discharge velocity, say 10 m/s.

$$\therefore \text{Grille area} = \frac{7.2}{10} = 0.72 \text{ m}^2$$

Height of grille = height of door = 2 m.

$$\therefore \text{Width of grille} = \frac{0.72}{2} = 0.36 \text{ m}$$

13 Pumps and fans

Flow in pipes

Bernoulli's Equation can be applied between points in a pipe through which fluid is flowing, with the addition of a term to allow for energy lost from the fluid in overcoming friction.

$$\frac{p_1}{\rho g} + \frac{U_1^2}{2g} + z_1 = \frac{p_2}{\rho g} + \frac{U_2^2}{2g} + z_2 + h_f$$
$$h_f = \frac{p_f}{\rho g}$$

where

Subscript 1 refers to values at point 1.

Subscript 2 refers to values at point 2.

p = pressure (N/m^2)

ρ = density (kg/m^3)

g = weight per unit mass


= acceleration due to gravity (m/s^2)

U = velocity (m/s)

z = height above arbitrary datum (m)

h_f = friction head from point 1 to point 2 (m)

p_f = pressure necessary to overcome friction between points 1 and 2 (N/m^2)



Fluid statics

For a liquid in equilibrium

$$p + \rho g z = \text{const.}$$

If the datum from which z is measured is taken as the free surface of the liquid

$$z = -h$$

and

$$p = \rho g h$$

$$\frac{p}{\rho g} = h \text{ and is termed } \textit{pressure head}$$

$$\frac{p}{\rho g} + z = \text{const. and is termed } \textit{piezometric head}$$

where

p = pressure of liquid (N/m^2)

ρ = density (kg/m^3)

g = weight per unit mass

= acceleration due to gravity (m/s^2)

z = height above arbitrary datum (m)

h = depth below free surface (m)

Fluid motion

The total energy per unit weight of a liquid in steady flow remains constant. This is expressed in *Bernoulli's Equation*:

$$\frac{p}{\rho} + \frac{U^2}{2} + g z = \text{const.}$$

or

$$\frac{p}{\rho g} + \frac{U^2}{2g} + z = \text{const.}$$

$p/\rho g$ is the pressure head per unit weight of fluid.

$U^2/2g$ is the velocity head per unit weight of fluid.

z is the gravitational head above datum per unit weight of fluid.

where


U = velocity of fluid (m/s).

Other symbols as above.

Venturimeter

A venturimeter is inserted in a pipe to measure the quantity of water flowing through it.

$$Q = \frac{C_d A_2}{\sqrt{1 - (A_2/A_1)^2}} \sqrt{2 \left(\frac{p_1 - p_2}{\rho} \right)}$$



where

Q = quantity of water flowing (m^3/s)

C_d = coefficient of discharge
= 0.96 to 0.99

A = area (m^2)

p = pressure (N/m^2)

ρ = density (kg/m^3)

Subscripts 1 and 2 refer to values of sections 1 and 2 respectively.


Discharge of water through small orifice

$$Q = v a_o$$

$$v = C_v \sqrt{2gh}$$

$$a_o = C_c a_1$$

$$Q = C_v C_c a_1 \sqrt{2gh}$$



where

Q = quantity of water discharged (m^3/s)

v = velocity at section of minimum area of jet (m/s)

a_o = area at section of minimum area of jet (m^2)

a_1 = area of orifice (m^2)

h = height of free surface above orifice (m)

g = weight per unit mass

= acceleration due to gravity (m/s^2)

C_v = coefficient of velocity

$$= \frac{\text{actual velocity}}{\text{theoretical velocity}} = 0.96 \text{ to } 0.99$$

C_c = coefficient of contraction

$$= a_o/a_1 = 0.6 \text{ to } 0.7$$

Velocity heads and theoretical velocities of water

$$h = \frac{v^2}{2g}$$

h = Head in m
 v = Velocity in m/s
 g = Gravity of earth = 9.81 m/s²

| v m/s | h m | v m/s | h m | v m/s | h m | v m/s | h m |
|------------|-----------|------------|----------|------------|----------|------------|----------|
| 0.01 | 0.0000051 | 0.80 | 0.0326 | 1.60 | 0.130 | 2.40 | 0.293 |
| 0.05 | 0.000127 | 0.85 | 0.0368 | 1.65 | 0.139 | 2.45 | 0.306 |
| 0.10 | 0.00051 | 0.90 | 0.0413 | 1.70 | 0.147 | 2.50 | 0.318 |
| 0.15 | 0.00115 | 0.95 | 0.046 | 1.75 | 0.156 | 2.55 | 0.331 |
| 0.20 | 0.00204 | 1.0 | 0.0510 | 1.80 | 0.165 | 2.60 | 0.344 |
| 0.25 | 0.00319 | 1.05 | 0.0561 | 1.85 | 0.174 | 2.65 | 0.358 |
| 0.30 | 0.00459 | 1.10 | 0.0617 | 1.90 | 0.184 | 2.70 | 0.371 |
| 0.35 | 0.00624 | 1.15 | 0.0674 | 1.95 | 0.194 | 2.75 | 0.385 |
| 0.40 | 0.00815 | 1.20 | 0.0734 | 2.0 | 0.204 | 2.80 | 0.400 |
| 0.45 | 0.0103 | 1.25 | 0.0797 | 2.05 | 0.214 | 2.85 | 0.414 |
| 0.50 | 0.0127 | 1.30 | 0.0862 | 2.10 | 0.225 | 2.90 | 0.429 |
| 0.55 | 0.0154 | 1.35 | 0.0930 | 2.15 | 0.236 | 2.95 | 0.444 |
| 0.60 | 0.0183 | 1.40 | 0.100 | 2.20 | 0.246 | 3.0 | 0.459 |
| 0.65 | 0.0215 | 1.45 | 0.107 | 2.25 | 0.258 | | |
| 0.70 | 0.0250 | 1.50 | 0.115 | 2.30 | 0.269 | | |
| 0.75 | 0.0287 | 1.55 | 0.122 | 2.35 | 0.281 | | |


$$h = \frac{v^2}{2g}$$

h = Head in ft
 v = Velocity in ft/s
 g = Gravity of earth = 32.2 ft/s²

| v ft/s | h ft | v ft/s | h ft | v ft/s | h ft | v ft/s | h ft |
|-------------|-----------|-------------|-----------|-------------|-----------|-------------|-----------|
| 0.1 | 0.0002 | 2.1 | 0.068 | 4.1 | 0.261 | 6.1 | 0.578 |
| 0.2 | 0.0006 | 2.2 | 0.075 | 4.2 | 0.274 | 6.2 | 0.597 |
| 0.3 | 0.0014 | 2.3 | 0.082 | 4.3 | 0.289 | 6.3 | 0.616 |
| 0.4 | 0.0025 | 2.4 | 0.089 | 4.4 | 0.301 | 6.4 | 0.636 |
| 0.5 | 0.0039 | 2.5 | 0.097 | 4.5 | 0.314 | 6.5 | 0.656 |
| 0.6 | 0.0056 | 2.6 | 0.105 | 4.6 | 0.329 | 6.6 | 0.676 |
| 0.7 | 0.0076 | 2.7 | 0.113 | 4.7 | 0.343 | 6.7 | 0.697 |
| 0.8 | 0.0099 | 2.8 | 0.122 | 4.8 | 0.358 | 6.8 | 0.718 |
| 0.9 | 0.0126 | 2.9 | 0.131 | 4.9 | 0.373 | 6.9 | 0.739 |
| 1.0 | 0.0155 | 3.0 | 0.140 | 5.0 | 0.388 | 7.0 | 0.761 |
| 1.1 | 0.019 | 3.1 | 0.149 | 5.1 | 0.404 | 7.1 | 0.783 |
| 1.2 | 0.022 | 3.2 | 0.159 | 5.2 | 0.420 | 7.2 | 0.805 |
| 1.3 | 0.026 | 3.3 | 0.169 | 5.3 | 0.436 | 7.3 | 0.827 |
| 1.4 | 0.030 | 3.4 | 0.179 | 5.4 | 0.453 | 7.4 | 0.850 |
| 1.5 | 0.035 | 3.5 | 0.190 | 5.5 | 0.470 | 7.5 | 0.874 |
| 1.6 | 0.040 | 3.6 | 0.201 | 5.6 | 0.487 | 7.6 | 0.897 |
| 1.7 | 0.045 | 3.7 | 0.212 | 5.7 | 0.505 | 7.7 | 0.921 |
| 1.8 | 0.050 | 3.8 | 0.224 | 5.8 | 0.522 | 7.8 | 0.945 |
| 1.9 | 0.056 | 3.9 | 0.236 | 5.9 | 0.541 | 7.9 | 0.969 |
| 2.0 | 0.062 | 4.0 | 0.248 | 6.0 | 0.559 | 8.0 | 0.994 |

Centrifugal pumps

The action of pumps is most conveniently expressed in terms of head. The rotor gives the liquid a head.



Notation

- v_1 = absolute velocity of water at inlet (m/s)
- v_2 = absolute velocity of water at outlet (m/s)
- U_1 = tangential velocity of blade at inlet (m/s)
- U_2 = tangential velocity of blade at outlet (m/s)
- V_{w1} = tangential velocity of water at inlet (m/s)
- V_{w2} = tangential velocity of water at outlet (m/s)
- R_1 = velocity of water relative to blade at inlet (m/s)
- R_2 = velocity of water relative to blade at outlet (m/s)
- g = weight per unit mass = 9.81 (m/s²)
- ρ = density (kg/m³)
- p_1 = pressure of water at inlet (N/m²)
- p_2 = pressure of water at outlet (N/m²)
- H_i = ideal head developed by pump (m)
- H_a = manometric head
= actual head developed by pump (m)
- η_m = manometric efficiency (%)
- η_o = overall efficiency (%)

Normally for a pump $V_{w1} = 0$

Then

$$H_i = \text{work done on water per unit weight} = \frac{U_2 V_{w2}}{g}$$

When the output of a pump is expressed as head of working liquid it is independent of the density of the liquid.

$$H_m = \frac{p_2 - p_1}{\rho g} + \frac{v_2^2}{2g}$$

Actual head is less than ideal because of friction losses within pump.

$$\eta_m = \frac{H_m}{H_i} \times 100$$

Overall efficiency is lower again because of mechanical losses in bearings, etc.

$$\eta_o = \frac{H_m Q \rho g}{S} \times 100$$

where

Q = quantity of water flowing (m^3/s)

S = power input at shaft (Nm/s)

The specific speed of a centrifugal pump is the speed at which the pump would deliver $1 \text{ m}^3/\text{s}$ of water at a head of 1 m.

$$N_s = \frac{nQ^{1/2}}{H^{3/4}}$$

where

N_s = specific speed

n = speed (rev/min)

Q = volume delivered (m^3/s)

H = total head developed (m)

Pump laws

- 1 Volume delivered varies directly as speed

$$\frac{Q_1}{Q_2} = \frac{N_1}{N_2}$$




- 2 Head developed varies as the square of speed

$$\frac{H_1}{H_2} = \left(\frac{N_1}{N_2}\right)^2$$

- 3 Power absorbed varies as the cube of speed

$$\frac{S_1}{S_2} = \left(\frac{N_1}{N_2}\right)^3$$

Characteristic curves of pumps



Q = QUANTITY FLOWING (m^3/s)
 H = HEAD DEVELOPED (m)
 S = POWER ABSORBED (W)
 η = EFFICIENCY (%)

A centrifugal pump takes the least power when the flow is zero. It should therefore be started with the delivery valve shut.

An axial flow pump takes the least power when the flow is greatest. It should therefore be started with the delivery valve open.


Fans

1 Propeller fans and axial flow fans

Pressure for single stage up to about 300 N/m².


Suitable for large volumes at comparatively low pressures.

Characteristic curve for axial flow fan



2 Centrifugal fans


Types of blade




STRAIGHT
STEEL PLATE
PADDLE WHEEL



FORWARD
MULTIVANE
MULTIBLADE



BACKWARD
TURBOVANE



Notation

Suffix 1 refers to inlet.

Suffix 2 refers to outlet.

v = absolute velocity of air (m/s)

u = tangential velocity of blade (m/s)

v_w = tangential velocity of air (m/s)

R = velocity of air relative to blade (m/s)

g = weight per unit mass

= 9.81 (m/s²)

ρ = density of air (kg/m³)

p_t = total pressure (N/m²)

p_s = static pressure (N/m²)

p_i = theoretical total pressure developed by fan (N/m²)

p_a = actual total pressure developed by fan (N/m²)

Q = volume of air (m³/s)

S = power input to fan (W)

η = efficiency (%)

Normally


$$p_i = U_2 v_{w2} \rho \quad v_{w1} = 0$$

$$p_t = p_s + \frac{v^2 \rho}{2}$$

$$p_a = p_{t2} - p_{t1} = p_{s2} - p_{s1} + \frac{(v_2^2 - v_1^2) \rho}{2}$$


$$\eta = \frac{P_a Q}{S} \times 100$$

Characteristic curve for centrifugal fan




3 Mixed flow fans

Within an axial casing the impeller hub and casing inlet form a conical passage in which the impeller blades combine axial and centrifugal actions. Downstream guide vanes turn the radial component of air velocity into axial velocity without loss of pressure. This enables a fan with an axial-type casing fitted in a straight run of ducting to develop higher pressures than a normal axial flow fan.



CHARACTERISTIC CURVE FOR MIXED FLOW FAN



Typical efficiencies

| | |
|-------------|------|
| Small fans | 0.40 |
| Medium fans | 0.60 |
| Large fans | 0.80 |

Fan laws

- 1 Volume varies directly as speed

$$\frac{Q_1}{Q_2} = \frac{N_1}{N_2}$$

- 2 Total pressure varies as the square of speed

$$\frac{P_{t1}}{P_{t2}} = \left(\frac{N_1}{N_2}\right)^2$$

- 3 Power absorbed varies as the cube of speed

$$\frac{S_1}{S_2} = \left(\frac{N_1}{N_2}\right)^3$$

Selection of fans

- 1 Air volume to be moved.
- 2 Static pressure or resistance.
- 3 Noise level permissible.
- 4 Electric supply available.

Pressures commonly used for typical systems

| | |
|--|--------------------------|
| Public buildings, ventilation only | 90–150 N/m ² |
| Public buildings, combined heating and ventilation | 150–250 N/m ² |
| Public buildings, combined heating and ventilation with air cleaning plant | 170–300 N/m ² |
| Factories, heating only | 170–400 N/m ² |
| Factories, combined heating and ventilation | 300–500 N/m ² |

Fan discharge velocities for quiet operation

| | <i>Supply systems</i> m/s | <i>Extract systems</i> m/s |
|-------------------------------------|------------------------------|-------------------------------|
| Sound studios, churches, libraries | 4–5 | 5–7 |
| Cinemas, theatres, ballrooms | 5–7.5 | 6–8 |
| Restaurants, offices, hotels, shops | 6–8 | 7–9 |

14 Sound

Sound. (Energy travelling as a pressure wave)

One decibel is equal to ten times the logarithm to base 10 of the ratio of two quantities.

$$I = \frac{W}{A} = \frac{p^2}{\rho c}$$

Sound power level

$$PWL = 10 \log_{10} \frac{W}{W_0}$$

Sound intensity

$$IL = 10 \log_{10} \frac{I}{I_0}$$

Sound pressure level

$$\begin{aligned} SPL &= 10 \log_{10} \frac{p^2}{p_0^2} \\ &= 20 \log_{10} \frac{p}{p_0} \end{aligned}$$

where

- I = intensity of sound (W/m^2)
- I_0 = reference intensity (W/m^2)
- W = power (W)
- W_0 = reference power (W)
- A = area (m^2)
- p = root mean square pressure (N/m^2)
- p_0 = reference pressure (N/m^2)
- ρ = density (kg/m^3)
- c = velocity of sound (m/s)


The usual reference levels are

$$\begin{aligned} W_0 &= 10^{-12} \text{ watts} \\ I_0 &= 10^{-12} \text{ W}/\text{m}^2 \\ p_0 &= 0.0002 \text{ } \mu\text{bar} = 20 \times 10^{-6} \text{ N}/\text{m}^2 \end{aligned}$$

At room temperature and at sea level $SPL = IL + 0.2$ decibels

Measurement of noise

Method of adding levels expressed in decibels



Noise rating Graphs are plotted of Sound Pressure Level (SPL) v frequency, to show how the acceptable sound level varies with frequency. What is acceptable depends on the use to which the room will be put, and so a different curve is obtained for each type of use. Each such curve is designated by an NR number.

| <i>NR No.</i> | <i>Application</i> |
|---------------|---|
| NR 25 | Concert halls, broadcasting and recording studios, churches |
| NR 30 | Private dwellings, hospitals, theatres, cinemas, conference rooms |
| NR 35 | Libraries, museums, court rooms, schools, hospital operating theatres and wards, flats, hotels, executive offices |
| NR 40 | Halls, corridors, cloakrooms, restaurants, night clubs, offices, shops |
| NR 45 | Department stores, supermarkets, canteens, general offices |
| NR 50 | Typing pools, offices with business machines |
| NR 60 | Light engineering works |
| NR 70 | Foundries, heavy engineering works |

NR levels (SPL. dB re 0.00002 N/m²)

| Noise rating | Octave band mid-frequency, HZ | | | | | | | |
|--------------|-------------------------------|-----|-----|-----|------|------|------|------|
| | 62.5 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 |
| NR10 | 42 | 32 | 23 | 15 | 10 | 7 | 3 | 2 |
| NR20 | 51 | 39 | 31 | 24 | 20 | 17 | 14 | 13 |
| NR30 | 59 | 48 | 40 | 34 | 30 | 27 | 25 | 23 |
| NR35 | 63 | 52 | 45 | 39 | 35 | 32 | 30 | 28 |
| NR40 | 67 | 57 | 49 | 44 | 40 | 37 | 35 | 33 |
| NR45 | 71 | 61 | 54 | 48 | 45 | 42 | 40 | 38 |
| NR50 | 75 | 65 | 59 | 53 | 50 | 47 | 45 | 43 |
| NR55 | 79 | 70 | 63 | 58 | 55 | 52 | 50 | 49 |
| NR60 | 83 | 74 | 68 | 63 | 60 | 57 | 55 | 54 |
| NR65 | 87 | 78 | 72 | 68 | 65 | 62 | 61 | 59 |
| NR70 | 91 | 83 | 77 | 73 | 70 | 68 | 66 | 64 |
| NR75 | 95 | 87 | 82 | 78 | 75 | 73 | 71 | 69 |
| NR80 | 99 | 91 | 86 | 82 | 80 | 78 | 76 | 74 |

Sound obeys the Inverse Square Law

$$p^2 = K \frac{W}{r^2}$$

where

p = root mean square pressure

K = constant

W = power

r = distance from source

or

$$\text{SPL} = \text{PWL} - 20 \log_{10} r + K'$$

$$K' = \log_{10} K = \text{constant.}$$

In air with source near ground, $K' = -8$.

For a continuing source in a room, the sound level is the sum of the direct and the reverberant sound and is given by

$$\text{SPL} = \text{PWL} + 10 \log_{10} \left[\frac{Q}{4\pi r^2} + \frac{4}{R} \right] \text{dB}$$

where

$$Q = \frac{\text{SPL at distance } r \text{ from actual source}}{\text{SPL at distance } r \text{ from uniform source of same power}}$$

$$R = \text{Room constant} = \frac{S\alpha}{1 - \alpha} \text{ m}^2$$

S = Total surface area of room m²

α = Absorption coefficient of walls

r in m

Coefficient of absorption α

For range of frequencies usual in ventilation applications

| | | | |
|-----------------------------|-----------|-------------------------------|---------|
| Plaster walls | 0.01-0.03 | 25 mm wood wool cement | |
| Unpainted brickwork | 0.02-0.05 | on battens | 0.6-0.7 |
| Painted brickwork | 0.01-0.02 | 50 mm slag wool or glass silk | 0.8-0.9 |
| 3-plywood panel | 0.01-0.02 | 12 mm acoustic belt | 0.5-0.6 |
| 6 mm cork sheet | 0.1-0.2 | Hardwood | 0.3 |
| 6 mm porous rubber sheet | 0.1-0.2 | 25 mm sprayed asbestos | 0.6-0.7 |
| 12 mm fibreboard on battens | 0.3-0.4 | Persons, each | 2.0-5.0 |
| | | Acoustic tiles | 0.4-0.8 |

Sound insulation of walls

$$\text{Transmission coefficient } \tau = \frac{\text{transmitted energy}}{\text{incident energy}}$$

Sound reduction index


$$\text{SRI} = 10 \log_{10} \left(\frac{1}{\tau} \right) \text{ dB}$$

Empirical formula is

$$\text{SRI} = 15 \log(\sigma f) - 17$$

where

- σ = mass per unit area of wall (kg/m^2)
- f = frequency (Hz)



SOUND INSULATION OF SOLID WALLS ACCORDING TO MASS

Transmission through walls

$$(SPL)_1 - (SPL)_2 = SRI - 10 \log_{10} \left(\frac{S_p}{S_2 \alpha_2} \right) \text{dB}$$

where

- $(SPL)_1$ = sound pressure in sending room
- $(SPL)_2$ = sound pressure in receiving room
- SRI = sound reduction index
- $S_2 \alpha_2$ = equivalent absorption in receiving room
- S_p = area of partition wall

Sound insulation of windows

| <i>Single/ double window</i> | <i>Type of window</i> | <i>Type of glass</i> | <i>Sound reduction in dB</i> |
|--------------------------------------|---|--|--------------------------------------|
| Single | Opening type (closed) | Any glass | 18-20 |
| Single | Fixed or opening type with air-tight weather strips | 24/32 oz sheet glass | 23-25 |
| | | 6 mm polished plate glass | 27 |
| | | 9 mm polished plate glass | 30 |
| Double | Opening type (closed) plus absorbent material on sides of air space | 24/32 oz sheet glass 100 mm space | 28 |
| | | 24/32 oz sheet glass 200 mm space | 31 |
| | | 6 mm polished plate glass 100 mm space | 30 |
| | | 6 mm polished plate glass 200 mm space | 33 |
| Double | Fixed or opening type with air-tight weather strips | 24/32 oz sheet glass 100 mm space | 34 |
| | | 24/32 oz sheet glass 200 mm space | 40 |
| | | 6 mm polished plate glass 100 mm space | 38 |
| | | 6 mm polished plate glass 200 mm space | 44 |

Attenuation by building structure

| <i>Structure</i> | <i>Attenuation dB</i> | <i>Structure</i> | <i>Attenuation dB</i> |
|------------------------------|---------------------------|-------------------------------|---------------------------|
| 9 in brick wall | 50 | Double window 50 mm spacing | 30 |
| 6 in (150 mm) concrete wall | 42 | 12 mm T & G boarded partition | 26 |
| Wood joist floor and ceiling | 40 | 2.5 mm glass window | 23 |
| Lath and plaster partition | 38 | | |

Transmission through ducts

$$\begin{aligned}\frac{\text{Attenuation}}{\text{Duct length}} &= 1.07\alpha^{1.4}\frac{P}{A}\text{ dB per ft} \\ &= 1.07\alpha^{1.4}\frac{P}{A}\text{ dB per m}\end{aligned}$$

where

α = coefficient of absorption

P = perimeter of duct

A = cross sectional area of duct


Approximate attenuation of round bends or square bends with turning vanes in dB

| <i>Frequency</i> <i>Hz</i> | <i>20-</i> <i>75</i> | <i>75-</i> <i>150</i> | <i>150-</i> <i>300</i> | <i>300-</i> <i>600</i> | <i>600-</i> <i>1200</i> | <i>1200-</i> <i>2400</i> | <i>2400-</i> <i>4800</i> | <i>4800-</i> <i>10 000</i> |
|-------------------------------|-------------------------|--------------------------|---------------------------|---------------------------|----------------------------|-----------------------------|-----------------------------|-------------------------------|
| <i>Diameter</i> | | | | | | | | |
| 5 to 10 in | | | | | | | | |
| 125 to 250 mm | 0 | 0 | 0 | 0 | 1 | 2 | 3 | 3 |
| 11 to 20 in | | | | | | | | |
| 251 to 500 mm | 0 | 0 | 0 | 1 | 2 | 3 | 3 | 3 |
| 21 to 40 in | | | | | | | | |
| 501 to 1000 mm | 0 | 0 | 1 | 2 | 3 | 3 | 3 | 3 |
| 41 to 80 in | | | | | | | | |
| 1001 to 2000 mm | 0 | 1 | 2 | 3 | 3 | 3 | 3 | 3 |

Attenuation due to changes in area in dB

| <i>Ratio of</i> <i>Area S_2/S_1</i> | <i>Attenuation</i> <i>dB</i> | <i>Ratio of</i> <i>Area S_2/S_1</i> | <i>Attenuation</i> <i>dB</i> |
|---|---------------------------------|---|---------------------------------|
| 1 | 0.0 | 3 | 1.3 |
| 2 | 0.5 | 4 | 1.9 |
| 2.5 | 0.9 | 5 | 2.6 |

Attenuation at entry to room (end reflection loss)



END REFLECTION LOSS
 FOR RECTANGULAR OPENING LENGTH = $\sqrt{L_1 \times L_2}$
 FOR CIRCULAR OPENING LENGTH = 0.9 DIA.
 LENGTHS IN mm.

Sound power level (PWL) of fans

Exact data for any particular fan is to be obtained from the manufacturer. In the absence of this the following approximate expressions may be used.

$$PWL = 90 + 10 \log_{10} s + 10 \log_{10} h$$

$$PWL = 55 + 10 \log_{10} q + 20 \log_{10} h$$

$$PWL = 125 + 20 \log_{10} s - 10 \log_{10} q$$

where

s = rated motor power (hp)
 h = fan static head (in water gauge)
 q = volume discharged (ft³/min)

$$PWL = 67 + 10 \log_{10} S + 10 \log_{10} p$$


$$PWL = 40 + 10 \log_{10} Q + 20 \log_{10} p$$

$$PWL = 94 + 20 \log_{10} S - 10 \log_{10} Q$$

where


S = rated motor power (kW)
 p = fan static pressure (N/m²)
 Q = volume discharged (m³/s)

Typical curves of fan frequency distribution



SOUND POWER LEVEL SPECTRA OF FANS

Sound absorption



- (a) Sound absorption by increase of duct area.
- (b) Ceiling air outlet with sound-absorbing plate.
- (c) Sound absorption in branch duct with splitter.
- (d) Arrangement of splitters in main duct.

15 Labour rates

The following schedules give basic times for installation and erection of heating and ventilating equipment.

Included. Haulage of all parts into position, erection on site, surveying of builder's work, testing.

Not included. Delivery to site, travelling time, addition for overtime working.

Additions to basic time

The basic time given should be increased

| | |
|---|--------|
| For jobs under 1 week | by 40% |
| For jobs under 2 weeks | 20% |
| For jobs under 3 weeks | 8% |
| For work in existing buildings, unoccupied | 5% |
| For work in existing buildings, occupied | 15% |
| For work in existing building, with concealed pipes | 20% |

| <i>Plant</i> | <i>Time in man hrs</i> |
|--|------------------------|
| Boilers. Including all fittings | |
| <i>Cast iron sectional</i> | |
| up to 36 kW | 20 |
| 37-75 kW | 25 |
| 76-150 kW | 35 |
| 151-220 kW | 50 |
| 221-300 kW | 60 |
| 301-450 kW | 70 |
| 451-580 kW | 75 |
| 581-750 kW | 80 |
| <i>Unit construction steel boilers</i> | |
| up to 110 kW | 6 |
| 111-300 kW | 12 |
| 301-600 kW | 20 |

| <i>Plant</i> | <i>Time in man hrs</i> |
|---|------------------------|
| Oil burners, Pressure jet gas burners | |
| up to 75 kW | 8 |
| 76-150 kW | 12 |
| 151-300 kW | 20 |
| 301-500 kW | 25 |
| Combination boiler – Calorifier sets. Including all fittings | |
| Boiler rating | |
| up to 110 kW | 20 |
| 111-300 kW | 25 |
| 301-600 kW | 35 |
| Calorifiers, Indirect cylinders, Direct cylinders | |
| Storage capacity | |
| up to 250 litres | 9 |
| 251-550 litres | 12 |
| 551-900 litres | 20 |
| 901-1300 litres | 30 |
| 1301-2250 litres | 35 |
| 2251-3500 litres | 40 |
| 3501-5000 litres | 45 |
| Electric water heaters | |
| up to 3 kW | 4 |
| F and E tanks, Cold water tanks | |
| Capacity | |
| up to 90 litres | 6 |
| 91-225 litres | 9 |
| 226-450 litres | 12 |
| 451-900 litres | 15 |
| 901-2000 litres | 20 |
| 2001-4000 litres | 30 |

| <i>Plant</i> | <i>Time in man hrs</i> | |
|--|------------------------|-----|
| Pumps. Complete with motor | | |
| <i>Direct coupled or belt driven, with supports</i> | | |
| Flow | Nominal size | |
| up to 1.5 litre/s | up to 32 | 10 |
| 1.6-2.5 litre/s | 40-50 | 14 |
| 2.6-25 litre/s | 65-100 | 18 |
| over 25 litre/s | over 100 | 24 |
| <i>In-line pipeline pumps</i> | | |
| Flow | Nominal size | |
| up to 0.7 litre/s | up to 32 | 6 |
| 0.8-1.5 litre/s | 40-80 | 10 |
| over 1.5 litre/s | over 80 | 14 |
| Flue pipes. Steel or Asbestos | | |
| <i>Pipes</i> | | |
| 150 dia | (per m) | 1 |
| 300 dia | (per m) | 2 |
| over 300 dia | (per m) | 3 |
| <i>Elbows</i> | | |
| 150 dia | | 0.3 |
| 300 dia | | 0.6 |
| over 300 dia | | 1.0 |
| Valves, Taps, Cocks | | |
| Nominal bore | | |
| 15-32 | | 0.5 |
| 40-50 | | 1.0 |
| 65-100 | | 2 |
| over 100 | | 3 |
| Mixing Valves, Diverting Valves, Two-way Valves. With | | |
| Actuators | | |
| Nominal bore | | |
| up to 32 | | 8 |
| 40-50 | | 10 |
| 65-100 | | 12 |
| over 100 | | 15 |

| <i>Plant</i> | <i>Time in man hrs</i> |
|---|------------------------|
| Electric Starters | |
| All ratings | 2 |
| Three-way Cocks. For venting | |
| Nominal bore | |
| up to 50 | 2 |
| 65-100 | 3 |
| over 100 | 4 |
| Pressure Gauge. With Cock | |
| Thermometer | 1 |
| Thermostat | 2 |
| Safety Valves | |
| Nominal bore | |
| up to 32 | 1 |
| 40-50 | 2 |
| over 50 | 4 |
| Radiators. Complete with 2 valves | |
| Heating surface | |
| up to 2.5 m ² | 4 |
| 2.6-4.5 m ² | 6 |
| 4.6-10 m ² | 8 |
| Remove and refix one radiator (for painting and decorating) | 1.5 |
| Natural Draught Convectors | |
| Length | |
| up to 1 m | 6 |
| 1.1-1.5 m | 7 |
| over 1.5 m | 8 |
| Fan Convectors | |
| Floor standing 700 mm high | 5 |
| recessed 700 mm high | 7 |
| recessed 1800 mm high | 10 |

| <i>Plant</i> | <i>Time in man hrs</i> |
|---|------------------------|
| Industrial Type Unit Heaters | |
| up to 6 kW | 10 |
| 7-15 kW | 15 |
| 16-30 kW | 20 |
| Gas Fired Room Heaters | |
| up to 2 kW | 5 |
| 2.1-10 kW | 7 |
| 11-18 kW | 12 |
| over 18 kW | 15 |
| Centrifugal Fans | |
| Complete with motor, direct coupled or belt driven, with supports | |
| Impeller diameter | |
| up to 300 mm | 15 |
| 301-600 mm | 20 |
| 601-1000 mm | 28 |
| 1001-1200 mm | 45 |
| 1201-1525 mm | 50 |
| Axial Flow Fans. Complete with casing and motor | |
| Diameter | |
| up to 300 mm | 5 |
| 301-600 mm | 8 |
| 601-1500 mm | 10 |
| 1501-2400 mm | 20 |
| Cooling Towers. For air conditioning | |
| Plan area | |
| up to 2 m ² | 15 |
| 2.1-3.5 m ² | 20 |
| 3.6-6.0 m ² | 45 |
| 6.1-8.0 m ² | 60 |
| 8.1-15 m ² | 100 |
| 15.1-20 m ² | 140 |
| 20.1-25 m ² | 160 |

| <i>Plant</i> | <i>Time in man hrs</i> |
|--|------------------------|
| Dry or Throw-away Filters | |
| Capacity | |
| up to 0.7 m ³ /s | 1 |
| 0.71-2.0 m ³ /s | 2 |
| Self-cleaning Viscous Filters | |
| Capacity | |
| up to 1 m ³ /s | 5 |
| 1.1-1.8 m ³ /s | 7 |
| 1.9-6 m ³ /s | 15 |
| 6.1-12 m ³ /s | 20 |
| 12.1-22 m ³ /s | 30 |
| 22.1-30 m ³ /s | 40 |
| Grease Filters | |
| Capacity | |
| up to 0.5 m ³ /s | 1 |
| 0.6-1.0 m ³ /s | 2 |
| 1.1-1.3 m ³ /s | 3.5 |
| 1.4-3.0 m ³ /s | 5 |
| Package Air Handling Units. Consisting of filter, preheater, cooler, humidifier, reheater, fan and silencer | |
| Capacity | |
| up to 0.15 m ³ /s | 6 |
| 0.16-0.3 m ³ /s | 10 |
| 0.4-0.5 m ³ /s | 15 |
| 0.6-0.8 m ³ /s | 20 |
| 0.9-2 m ³ /s | 30 |
| 2.1-3 m ³ /s | 43 |
| 3.1-4.5 m ³ /s | 70 |
| 4.6-6 m ³ /s | 110 |
| 6.1-8 m ³ /s | 150 |

| <i>Plant</i> | <i>Time in man hrs</i> |
|---|-------------------------------------|
| Grilles and Registers | |
| Long side | |
| up to 100 mm | 1 |
| 101-450 mm | 2 |
| over 450 mm | 3 |
| Air Dampers. In ventilation ducting | |
| Diameter (or equivalent diameter for rectangular dampers) | |
| up to 100 mm | 1 |
| 101-200 mm | 2 |
| 201-500 mm | 3 |
| 501-1000 mm | 5 |
| 1001-1700 mm | 8 |
| 1701-2000 mm | 10 |
| Actuator or Motor for Motorised Dampers | |
| All ratings | 7.5 |
| | <i>Time in man hr/m</i> |
| Pipes. Including brackets and fittings | |
| Nominal bore | |
| up to 20 mm | 0.5 |
| 25-32 mm | 0.75 |
| 40-100 mm | 1 |
| 150 mm | 1.8 |
| 200 mm | 2.5 |
| 250 mm | 3 |
| Pipe Lagging. Rigid or flexible sectional | |
| Nominal bore of pipe | |
| up to 150 mm | 0.5 |
| over 150 mm | 0.75 |
| | <i>Time in man hr/m²</i> |
| Equipment Lagging | |
| Flat | 0.5 |

| | <i>Time in man hrs/m</i> |
|--|--------------------------------|
| Steel Ducts for ventilation systems, including supports and brackets and all fittings | |
| Diameter (or equivalent diameter for rectangular ducts) | |
| up to 200 mm | 3 |
| 201-300 mm | 6 |
| 301-500 mm | 10 |
| 501-750 mm | 18 |
| 751-1000 mm | 25 |
| 1001-1200 mm | 40 |
| 1201-1700 mm | 50 |
| 1701-2000 mm | 70 |
| | <i>Time in man hours/tonne</i> |
| Ventilation and Air Conditioning Equipment | |
| Not separately detailed, or as alternative to times given above | 90 |

16

Bibliography

The following list is intended as a guide for readers who require more theoretical treatment of the topics on which data is presented in this book. It is a selection of books which are both useful and generally accessible, but does not claim to be exhaustive. Some of the books mentioned are out of print; they are included because they are available in libraries and contain material which is still useful.

Handbooks

- CIBSE Guides. Chartered Institution of Building Services Engineers, London
Handbook of Air Conditioning Design. Carrier Air Conditioning, Biggin Hill, Kent
Kempe's Engineering Yearbook, Morgan-Grampian, London
Machinery's Handbook, The Industrial Press, New York
Mark's Standard Handbook for Mechanical Engineers, McGraw-Hill, New York
Newnes Mechanical Engineers Pocket Book, 2nd ed. (1997)
Powell, M.J.V., *House Builder's Reference Book*, Butterworth-Heinemann, Oxford (1979)

Heating, ventilating, air conditioning

- Allard, F., (ed.), *Natural Ventilation in Buildings*, James & James (1998)
Awbi, H. W., *Ventilation of Buildings*, E. & F. N. Spon (1991)
Barton, J.J., *Small Bore Heating and Hot Water Supply for Small Dwellings*, 2nd ed., Butterworth-Heinemann, Oxford (1970)
Barton, J.J., *Electric Floor Warming*, Butterworth-Heinemann, Oxford (1967)
Bedford, Thomas, *Bedford's Basic Principles of Ventilation and Heating*, ed. F.A. Chrenka, 3rd ed., H.K. Lewis, London (1974)
Chadderton, D., *Air Conditioning: A Practical Introduction*, 2nd ed., E. & F. N. Spon (1997)
Chadderton, D., *Building Services Engineering*, 3rd ed., E. & F. N. Spon (2000)
Clifford, G.E., *Modern Heating & Ventilating System Design*, Prentice Hall (1993)
Cooper, W.B., Lee, R.E. and Quinlan, R.A., *Warm Air Heating for Climate Control*, 2nd ed., Prentice Hall (1991)
Croome-Gale, D.J. and Roberts, T.M., *Air Conditioning and Ventilation of Buildings*, 2nd ed. (1981)
Clements-Croome, D., *Naturally Ventilated Buildings*, E. & F. N. Spon (1997)
Faber and Kell's *Heating and Air Conditioning of Buildings*, 8th ed., Martin, P.L., and Oughton, D.R., Architectural Press (1995)
Jones, W.P., *Air Conditioning Engineering*, 4th ed., Arnold, London (1994)
Jones, W.P., *Air Conditioning Applications and Design*, 2nd ed., Arnold, London (1997)
Kreider, J.F. and Rabb, A., *Heating and Cooling of Buildings*, McGraw-Hill (1994)
Kut, D., *Heating and Hot Water Services in Buildings*, Pergamon Press, Oxford (1968)

- Kut, D., *Warm Air Heating*, Pergamon Press, Oxford (1970)
- Kut, D. and Hare, G., *Applied Solar Energy*, Butterworth-Heinemann, Oxford (1983)
- Mackenzie-Kenney, C., *District Heating*, Pergamon Press, Oxford (1979)
- McQuiston, F.C. and Parker, J.D., *Heating, Ventilating and Air Conditioning*, 4th ed., Wiley, New York
- Moss, K., *Heating and Water Services Design in Buildings*, E. & F. N. Spon (1996)
- Santamouris, M. and Asimakopoulos, *Passive Cooling of Buildings*, James & James (1996)
- Sherratt, A.F.C., *Air Conditioning System Design for Buildings*
- Wang, S.K., *Handbook of Air Conditioning and Refrigeration*, McGraw-Hill (1993)

Heat pumps

- Heap, R.D., *Heat Pumps*, 2nd ed., E. & F. N. Spon, London (1983)
- McMullan, T. and Morgan, R., *Heat Pump*, Hilger, Bristol (1981)
- Miles, L., *Heat Pumps, Theory and Service*, Delmar Publishers (1994)
- Reay, D.A. and MacMichael, D.B.A., *Heat Pumps: Design and Application* (1979)
- Sherratt, A.F.C. (ed.), *Heat Pumps for Buildings*, Hutchinson, London (1984)
- Von Cube, H.W. and Steimle, F., *Heat Pump Technology*, Butterworth-Heinemann, Oxford (1981)

Heat, heat transfer and thermodynamics

- Dunn, P.D. and Reay, D.A., *Heat Pipes*, 3rd ed. (1982)
- Eastop and McConkey, *Applied Thermodynamics for Engineering Technologies*, 5th ed., Longman (1993)
- Fishenden, M. and Saunders, O.A., *An Introduction to Heat Transfer*, Oxford University Press (1950)
- Joel, R., *Basic Engineering Thermodynamics*, 5th ed., Longman (1997)
- Long, C.A., *Essential Heat Transfer*, Longman (1999)
- Moss, K., *Heat and Mass Transfer in Building Services Design*, E. & F. N. Spon (1998)
- Rogers, G.F.C. and Mayhew, Y.R., *Engineering Thermodynamics*, 4th ed., Longman, London (1992)
- Sherwin, K., *Introduction to Thermodynamics*, Chapman & Hall (1993)

Refrigeration

- Dossat, R.J., *Principles of Refrigeration*, 4th ed., Prentice Hall (1997)
- Langley, B.C., *Refrigeration and Air Conditioning*, 2nd ed., Reston Publishing (1982)
- Stoecker, W.F., *Industrial Refrigeration Handbook*, McGraw-Hill (1998)

Hydraulics

- Evvett, J.B. and Liu, C., *Fundamentals of Fluid Mechanics*, McGraw-Hill (1987)
- Fox, R.W. and McDonald, A.T., *Introduction of Fluid Mechanics*, 5th ed., Wiley (1998)

- Massey, B., revised by Ward-Smith, J., *Mechanics of Fluids*, 7th ed., Stanley Thornes (1998)
- Sherwin, J. and Horsley, M., *Thermofluids*, Chapman & Hall (1996)

Combustion

- Brame and King, *Fuels, Solid, Liquid and Gaseous*, Edward Arnold, London (1967)
- Gilchrist, J.D., *Fuels, Furnaces and Refractories*, Pergamon Press, Oxford (1977)

Fans

- Bleier, F.B., *Fan Handbook*, McGraw-Hill (1998)
- Eck, I.B., *Fans*, translated from German, Pergamon Press, Oxford (1973)
- Osborne, W.C., *Fans*, 2nd ed., Pergamon Press, Oxford (1977)
- Wallis, R.A., *Axial Flow Fans and Ducts*, Wiley, New York (1983)
- Wood's, *Practical Guide to Fan Engineering*, 3rd ed., Wood's of Colchester (1978)

Pumps

- Anderson, H.H., *Centrifugal Pumps*, 3rd ed., Trade & Technical Press, Morden, Surrey (1980)
- British Pump Manufacturers' Association, *Pump User's Handbook*, Trade & Technical Press, Morden, Surrey (1978)
- De Kovats, A. and Desmur, G., *Pumps, Fans and Compressors*, translated from French by R.S. Eaton (1958)
- Karassik, I.J., *Pump Handbook*, McGraw-Hill, New York (1986)
- Lobanoff, V.S. and Ross, R.R., *Centrifugal Pumps, Design & Application*, 2nd ed., Gulf Publishing (1982)
- Pumping Manual*, 8th ed., Trade & Technical Press, Morden, Surrey (1988)
- Warring, R.J., *Pumps: Selection, Systems and Applications*, 2nd ed., Trade & Technical Press, Morden (1984)

Sound

- Croome, D.J., *Noise, Buildings & People* (1977)
- Everest, F.A., *The Master Handbook of Acoustics*, 3rd ed., TAB Books (McGraw Hill) (1994)
- Ghering, W.L., *Reference Data for Acoustic Noise Control* (1978)
- Iqbal, M.A., *The Control of Noise in Ventilation Systems* (1977)
- Porges, G., *Applied Acoustics*, Edward Arnold, London (1977)
- Sharland, I., *Wood's Practical Guide to Noise Control*, Wood's of Colchester (1972)
- Smith, B.J., Peters, R.J. and Owen, J., *Acoustics and Noise Control*, 2nd ed., Longman (1996)

Piping

- M.W. Kellogg Co., *Design of Piping Systems*, Wiley, New York (1965)
- Kentish, D.N.W., *Industrial Pipework*, McGraw-Hill, London (1982)

Pearson, G.H., *Application of Valves and Fittings*, Applied Science Publishers, London (1981)

Piping Handbook, 7th ed., McGraw-Hill (2000)

Smith, P.R. and van Laan, T.J., *Piping and Pipe Support Systems*, McGraw-Hill, New York (1987)

Welding

American Welding Society, *Welding Handbook*, 7th ed., Macmillan, London (1970-78)

Cary, H.B., *Modern Welding Technology*, Prentice Hall, Englewood Cliffs (1989)

Davies, A.C., *The Science of and Practice of Welding*, 9th ed., Cambridge University Press (1989)

Gibson, S. and Smith, A., *Basic Welding*, Macmillan

Gibson, S., *Practical Welding*, Macmillan

Gibson, S.W., *Advanced Welding*, Macmillan (1997)

Gourd, L.M., *Principles of Welding Technology* (1980)

Manko, H.H., *Solders and Soldering*, 2nd ed. (1979)

Automatic control

Coffin, M.J., *Direct Digital Control for Building HVAC Systems*, 2nd ed., Kluwer Academic Publishers (1998)

Fisk, D.J., *Thermal Control of Buildings*, Applied Science Publishers, London (1981)

Levenhagen, J.J., *HVAC Control System Design Diagrams*, McGraw-Hill (1999)

Underwood, C.P., *HVAC Control Systems*, E. & F. N. Spon (1999)

17 Standards

British Standards

The following list of British Standards relevant to heating ventilating and air conditioning is based on information available in March 2000. For the latest details reference should be made to the current BSI Catalogue which is published annually.

10: 1962 Flanges and bolting for pipes, valves and fittings
(obsolescent)

Flanges in grey cast iron, copper alloy and cast or wrought steel for -328°F (-200°C) to 975°F (524°C) and up to 2800 lb/in^2 . Materials and dimensions of flanges, bolts and nuts. Ten tables cover plain, boss, integrally cast or forged, and welding neck types.

21: 1985 Pipe threads for tubes and fittings where pressure-tight joints are made on the threads (metric dimensions)

Range of threads from 1/16 to 6, together with thread forms, dimensions, tolerances, and designations. Requirements for jointing threads for taper external threads, for assembly with either taper or parallel internal threads and for lonscrews specified in BS 1387.

41: 1973 (1998) Cast iron spigot and socket flue or smoke pipes and fittings

Material, dimensions and tolerances of pipes, bends and offsets up to 300 mm nominal bore and nominal weight of pipes.

143 & 1256: 1986 Malleable cast iron and cast copper alloy threaded pipe fittings

Requirements for design and performance of pipe fittings for design to BS 143 having taper external and internal threads and BS 1256 having taper external and parallel internal threads.

417: -- Galvanised low carbon steel cisterns, cistern lids, tanks and cylinders

417: Part 1: 1964 Imperial units (obsolescent)

Cold and hot water storage vessels for domestic purposes.

Cisterns: 20 sizes from 4 to 740 gallons capacity, in two grades.

Tanks: 5 sizes from 31 to 34 gallons capacity, in two grades.

Cylinders: 10 sizes from 16 to 97 gallons capacity, in two grades.

417: Part 2: 1987 Metric units

Capacities from 18 l to 3364 l for cisterns, 95 to 115 l for tanks, 73 to 441 l for cylinders.

499: -- Welding terms and symbols

499: Part 1: 1991 Glossary for welding, brazing and thermal cutting

Gives terms common to more than one process, terms relating to welding with pressure, fusion welding, brazing, testing, weld imperfections and thermal cutting.

499: Part 1: 1992 Supplement

Definitions for electric welding equipment.

499: Part 2c: 1980 Welding symbols

Provides, in chart form, the type, position and method of representation of welding symbols and examples of their use.

567: 1973 (1989) Asbestos - cement flue pipes and fittings, light quality

Diameters 50 to 150 mm, for use with gas-fired appliances up to 45 kW.

599: 1966 Methods of testing pumps

Testing performance and efficiency of pumps for fluids which behave as homogeneous liquids.

699: 1984 (1990) Copper direct cylinders for domestic purposes

Requirements for copper direct cylinders, with capacities between 74 and 450 litres, for storage of hot water. Covers 4 grades and 16 sizes and also factory-applied insulation and protector rods.

715: 1993 Metal flue pipes, fittings, terminals and accessories for gas-fired appliances with a rated input not exceeding 60 kW

749: 1969 Underfeed stokers

Stokers rated up to 550 kg of coal per hour for all furnaces except metallurgical or other high temperature; requirements, installation, maintenance.

759: -- Valves, gauges and other safety fittings for application to boilers and to piping installations for and in connection with boilers

759: Part 1: 1984 Valves, mountings and fittings for boilers

Requirements for safety fittings excluding safety valves for boiler installations where steam pressure exceeds 1 bar gauge or, in the case of hot water boilers, the rating is 44 kW and above.

779: 1989 Cast iron boilers for central heating and indirect water supply (rated output 44 kW and above)

Design and construction including materials, workmanship, inspection, testing and marking of boilers for use with solid, gaseous and liquid fuels.

799: -- Oil burning equipment**799: Part 2: 1991 Vaporising burners**

Requirements for oil vaporising burners and associated equipment for boilers, heaters, furnaces, ovens and similar static flued plant such as free standing space-heating appliances, for single family dwellings.

799: Part 3: 1981 Automatic and semi-automatic atomising burners up to 36 litres per hour

Requirements for materials for all component parts and such parts of component design and plant layout as are fundamental to the proper functioning of such equipment.

799: Part 4: 1991 Atomising burners (other than monobloc type) together with associated equipment for single burner and multi-burner installations

For land and marine purposes. Suitable for liquid fuels to BS 2869 and BS 1469.

799: Part 5: 1989 Oil storage tanks

Requirements for carbon steel tanks for the storage of liquid fuel used in conjunction with oil-burning equipment. Includes integral tanks which form part of a complete oil-fired unit, service tanks, and storage tanks with a maximum height of 10 m and capacities up to 150 000 l.

799: Part 7: 1988 Dimensions of atomising oil-burner pumps with rotating shaft and external drive

Fixes the dimensions for connectors and certain dimensional characteristics of pumps.

799: Part 8: 1988 Connecting dimensions between atomising oil burners and heat generators

Applicable to atomising oil burners up to 150 kW capacity.

835: 1973 (1989) Asbestos cement flue pipes and fittings, heavy quality

Diameters from 75 to 600 mm for use with solid fuel and oil-burning appliances of output rating not exceeding 45 kW, for gas-fired appliances and for incinerators not exceeding 0.09 m³ capacity.

845: -- Methods of assessing thermal performance of boilers for steam hot water and high temperature heat transfer fluids**845: Part 1: 1987 Concise procedure**

A concise but complete test method, at minimum cost, for assessing the thermal performance of boilers, generally at output greater than 44 kW, which are thermodynamically simple and fired by solid, liquid or gaseous fuels.

845: Part 2: 1987 Comprehensive procedure

A comprehensive test method for assessing the thermal performance of any boiler, generally of output greater than 44 kW, including those

with multiple thermal flows to and from the boiler, and fired by solid, liquid or gaseous fuels.

848: -- Fans for special purposes

848: Part 1: 1997 Performance testing using standardised airways

848: Part 2: 1985 Methods of noise testing

Determination of the acoustic performance of fans operating against differences of pressure. Four methods are described: in-duct, reverberant field, free field and semi-reverberant.

848: Part 4: 1997 Dimensions

848: Part 5: 1986 Guide for mechanical and electrical safety

Fans connected to single-phase a.c., three-phase a.c. and d.c. supplies up to 660 V. Identifies the circumstances in which safety measures should be taken and gives information on how safety hazards can be reduced or eliminated.

848: Part 6: 1989 Method measurement of fan vibration

853: -- Vessels for use in heating systems

853: Part 1: 1996 Calorifiers and storage vessels for central heating and hot water supply

Strength and method of construction.

853: Part 2: 1996 Tubular heat exchangers and storage vessels for building and industrial services

855: 1976 Welded steel boilers for central heating and indirect hot water supply (rated output 44 kW to 3 MW)

Requirements for design and construction of boilers for use with solid, gaseous and liquid fuels.

1010: -- Draw off valves and stop valves for water services (screw-down pattern)

1010: Part 2: 1973 Draw off taps and above ground stop valves

Dimensions and test requirements for screwdown pattern draw off taps and above ground stop valves 1/4 in to 2 in nominal sizes. Material, design, dimensions of components and union ends.

1181: 1989 Clay flue linings and flue terminals

For use with certain domestic appliances, including gas-burning installations, and for ventilation. Dimensions, performance characteristics, sampling, testing, inspection and marking.

1212: -- Float operated valves (including floats)

1212: Part 1: 1990 Piston type

Seven sizes from 3/8 in to 2 in. Materials, quality, workmanship, dimensions and performance requirements.

1212: Part 2: 1990 Diaphragm type (copper alloy body)

Workmanship, dimensions and performance requirements for nominal sizes 3/8 and 1/2.

1212: Part 3: 1990 Diaphragm type (plastics body) for cold water services

Operational requirements.

1339: 1965 (1981) Definitions, formulae and constants relating to the humidity of air

Includes tables of saturation vapour pressure and bibliography.

1387: 1985 (1990) Screwed and socketed steel tubes and tubulars and plain end steel tubes suitable for welding or for screwing to BS 21 pipe threads

Applicable to tubes of nominal sizes DN 8 to DN 150 in light, medium and heavy thicknesses.

1394: -- Stationary circulation pumps for heating and hot water service systems**1394: Part 2: 1987 Physical and performance requirements**

Physical and performance requirements for pumps with a rated input not exceeding 300 W.

1415: -- Mixing valves**1415: Part 1: 1976 Non-thermostatic, non-compensatory mixing valves**

Performance requirements, materials and methods of specification of 1/2 and 3/4 nominal size valves.

1415: Part 2: 1986 Thermostatic mixing valves

Materials, designs, construction and performance requirements, with method of specifying size, for thermostatic mixing valves suitable for use with inlet supply pressures up to 6 bar and inlet water temperature between 10°C and 72°C.

1564: 1975 (1983) Pressed steel sectional rectangular tanks

Working under a pressure not exceeding the static head corresponding to the depth of the tank, built up from pressed steel plates 1220 mm square. The sectional dimensions are interchangeable with the imperial dimensions of the previous standard.

1565: -- Galvanised mild steel indirect cylinders**1565: Part 1: 1949 Imperial units (obsolescent)****1565: Part 2: 1973 Metric units (obsolescent)**

1566: -- Copper indirect cylinders for domestic purposes

1566: Part 1: 1984 (1990) Double feed indirect cylinders

Requirements for cylinders with capacities between 72 and 440 l for hot water storage. Covers 4 grades and 16 sizes and also includes factory-applied insulation and protector rods.

1566 : Part 2: 1984 Single-feed indirect cylinders

Requirement for 3 grades for cylinders with capacities from 86 to 196 l. Covers 3 grades and 7 sizes. The cylinders are of the type in which the bottom is domed inwards.

1586: 1982 Methods of performance testing and presentation of performance data for refrigerant condensing units

Applies to air and water-cooled condensing units employing single-stage refrigerant compressors including hermetic, semi-hermetic and open types. Describes the method for presentation of performance data for these units including correction factors and part load characteristic where applicable.

1608: 1990 Electrically-driven refrigerant condensing units

Design, construction and testing of units up to a power input of approximately 25 kW.

1710: 1984 (1991) Identification of pipelines and services

Colours for identifying pipes conveying fluids in liquid or gaseous form in land and marine installations.

1740: -- Wrought steel pipe fittings

1740: Part 1: 1971 (1990) Metric units

Welded and seamless fittings 6 mm to 150 mm for use with steel tubes to BS 1387, screwed BSP thread to BS 21.

1756: -- Methods for sampling and analysis of flue gases

1756: Part 1: 1971 Methods of sampling

1756: Part 2: 1971 Analysis by the Orsat apparatus

Apparatus, reagents, method, sample analysis, calculations, reporting of results.

1756: Part 3: 1971 Analysis by the Haldane apparatus

Apparatus, reagents, method, sample analysis, calculation, reporting of results.

1756: Part 4: 1977 Miscellaneous analyses

Determination of moisture content, sulphuric acid dew point, carbon monoxide, oxides of sulphur and oxides of nitrogen.

1756: Part 5: 1971 Semi-routine analyses

Carbon dioxide, carbon monoxide and total oxides of sulphur. Mainly for combustion performance of domestic gas appliances.

1894: 1992 Design and manufacture of electric boilers of welded construction

Materials, workmanship, inspection, testing, documentation and marking of boilers utilising electrodes or immersion elements to provide hot water or steam. Boilers are cylindrical constructed from carbon or carbon manganese steel by fusion welding.

2051: -- Tube and pipe fittings for engineering purposes**2501: Part 1: 1973 (obsolescent) Copper and copper alloys capillary and compression tube fittings for engineering purposes**

Applies to capillary and compression fittings, in sizes from 4 mm to 42 mm. These fittings are intended primarily for use with tubes of the outside diameters given in BS 2871: Part 2.

2740: 1969 (1991) Single smoke alarms and alarm metering devices

Requirements for the construction and operation of instruments designed to give an alarm when smoke emission from a chimney exceeds a chosen Ringelmann shade.

2742: 1969 (1991) Notes on the use of the Ringelmann and miniature smoke charts

Explains the purpose and method of use of these charts for the visual assessment of the darkness of smoke emitted from chimneys.

2742C: 1957 (1991) Ringelmann chart**2742M: 1960 (1991) Miniature smoke chart**

A chart, printed in shades of grey matt lacquer, which when held at about 5 ft from the observer gives readings of the density values of smoke from chimneys.

2767: 1991 Manually operated copper alloy valves for radiators

Designation, pressure and temperature ratings, materials, design, construction and testing of manual valves. Includes handwheel torque strength test, connections for metric copper tubes, compression type tailpiece connections, plating and drainage facility.

2811: 1969 (1991) Smoke density indicators and recorders

Requirements of construction and operation of instruments designed to measure the optical density of, or percentage obscuration caused by, smoke emitted from chimneys.

2869: 1998 Fuel oils for agricultural, domestic and industrial engines and boilers**2879: 1980 (1988) Draining taps (screw down pattern)**

Specifies 1/2 and 3/4 nominal size copper alloy bodied taps for draining down hot and cold water installations and heating systems.

3048: 1958 Code for the continuous sampling and automatic analysis of flue gases, indicators and recorders

Automatic instruments for direct indication or record of composition of flue gases from industrial plant. Thermal conductivity instruments,

instruments depending on chemical absorption and chemical reaction, viscosity and density instruments, oxygen meters, infra-red absorption instruments. Determination of dew point.

3198: 1981 Copper hot water storage combination units for domestic purposes

Requirements for direct, double-feed indirect and single-feed indirect types of units having hot water storage capacities between 65 and 180 litres.

3250: -- Methods for the thermal testing of domestic solid fuel burning appliances

3250: Part 1: (1993) Flue loss method

3250: Part 2: 1961 (1988) Hood method

Describes a method in which the convection warm air from the appliance is collected by means of a hood and measured directly.

3300: 1974 Kerosine (paraffin) unflued space heaters, cooking and boiling appliances for domestic use

Construction, safety, performance, marking and methods of test.

3377: 1985 Boilers for use with domestic solid mineral fuel appliances

Materials, construction and pressure testing of boilers of normal and high output for use with domestic solid mineral fuel appliances.

3416: 1991 Bitumen-based coatings for cold applications, suitable for use in contact with potable water

Two types each with three classes of coatings, all of which give films that comply with the national requirements for contact with potable water.

3505: 1986 Unplasticised polyvinyl chloride (PVC-U) pressure pipes for cold potable water

Pipes up to and including nominal size 24 for use at pressures up to 15 bar and 20°C, such that pipes which conform to the standard will be acceptable to UK water undertakings.

3974: -- Pipe supports

3974: Part 1: 1974 Pipe hangers, slider and roller type supports

Requirements for the design and manufacture of components for the hanger, slide and roller type supports for uninsulated and insulated steel and cast iron pipes of nominal sizes 15 mm to 160 mm within the temperature range -20°C + 470°C.

3974: Part 2: 1978 Pipe clamps, cages, cantilevers and attachments to beams

Applies to pipes of nominal sizes 100 mm to 600 mm.

4127: 1993 Light gauge stainless steel tubes, primarily for water applications

4213: 1991 Cold water storage and combined feed and expansion cistern (polyolefin or olefin copolymer) up to 500 L capacity used for domestic purposes

Requirements for materials and physical properties for cisterns for use in the storage of water.

4256: -- Oil burning air heaters

4256: Part 2: 1972 (1980) Fixed, flued, fan-assisted heaters

Construction, operation, performance and safety requirements for heaters, designed for use with distillate coals such as kerosene, gas oil and domestic fuel oil.

4433: -- Domestic solid mineral fuel fired boilers with rated outputs up to 45 kW

4433: Part 1: 1994 Boilers with undergrate ash removal

4433: Part 2: 1994 Gravity feed boilers designed to burn small anthracite

4485: -- Water cooling towers

4485: Part 2: 1988 Methods of performance testing

Determination of the performance of industrial mechanical draught and natural draught towers.

4504: -- Circular flanges for pipes, valves and fittings

4504: Section 3.1: 1989 Steel flanges

Types of circular steel flanges from PN 2.5 to PN 40 and in sizes up to DN 4000. Facings, dimensions, tolerances, threading, bolt sizes, marking and materials for bolting and flange materials with associated pressure/temperature ratings.

4504: Section 3.2: 1989 Cast iron flanges

Flanges in grey, malleable and ductile cast iron from PN 2.5 to PN 40 and in sizes up to DN 4000. Facings, dimensions, tolerances, threading, bolt sizes, marking and materials for bolting and flange materials with associated pressure/temperature ratings.

4504: Section 3.3: 1989 Copper alloy and composite flanges

Types of flanges from PN 6 to PN 40 and in sizes up to DN 1800. Facings, dimensions, tolerances, bolt sizes, marking and materials for bolting and flange materials with associated pressure/temperature ratings.

4508: -- Thermally insulated underground pipe lines

4508: Part 1: 1986 Steel-cased systems with air gap

Requirements of design, materials, construction, installation, testing and fault monitoring for steel-cased systems for temperatures exceeding 50°C.

4508: Part 4: 1977 Specific testing and inspection requirements for cased systems without air gap

Testing, inspection and certification of pipe-in-pipe distribution systems with an insulated service or product pipe enclosed in a pressure tight casing.

4543: -- Factory-made insulated chimneys

4543: Part 1: 1990 Methods of test

Methods of test for circular cross sectional metal chimneys supplied in component form needing no site fabrication. Intended for internal use.

4543: Part 2: 1990 Chimneys with flue linings for use with solid fuel fixed appliances

Circular cross sectional chimneys needing no site fabrication for internal use.

4543: part 3: 1990 Chimneys with stainless steel flue lining for use with oil fired appliances

Requirements for chimneys with stainless steel internal and metal external surfaces intended for use with oil fired appliances.

4814: 1990 Expansion vessels using an internal diaphragm for sealed hot water heating system

Requirements for manufacture and testing of carbon steel vessels up to 1000 L: capacity, up to 1000 mm diameter and for use in systems operating up to 6 bar.

4856: -- Methods for testing and rating fan coil units, unit heaters and unit coolers

4856: Part 1: 1972 (1983) Thermal and volumetric performance for heating duties, without additional ductwork

Methods of carrying out thermal and volumetric tests on forced convection units containing fluid to air heat exchangers and incorporating their own fans. The units are for heating applications and the tests are to be carried out on units in essentially clean conditions.

4856: Part 2: 1975 (1983) Thermal and volumetric performance for cooling duties, without additional ductwork

Coolers as used for cooling and dehumidifying under frost-free conditions, the medium used being water or other heat transfer fluid (excluding volatile refrigerants).

4856: Part 3: 1975 (1983) Thermal and volumetric performance for heating and cooling duties, with additional ductwork

Units for use with additional ducting containing fluid to air heat exchangers and incorporating their own electrically-powered fan system. For heating and cooling application, the latter with or without dehumidification under frost-free conditions.

- 4856: Part 4: 1997 Determination of sound power levels for fan coil units, unit heaters and unit coolers using reverberating rooms**
- 4857: -- Methods for testing and rating terminal reheat units for air distribution systems**
- 4857: Part 1: 1972 (1983) Thermal and aerodynamic performance**
Terminal reheat units with or without flow rate controllers.
- 4857: Part 2: 1978 (1985) Acoustic testing and rating**
Methods of testing and rating for static terminal attenuation, sound generation, upstream and downstream of the unit, radiation of sound from the casing.
- 4876: 1984 Performance requirements for domestic flued oil burning appliances**
Performance requirements and methods of testing for flued oil burning appliances (e.g. boilers and air heaters) up to and including 44 kW capacity, used for hot water supply and space heating.
- 4954: -- Methods for testing and rating induction units for air distribution systems**
- 4954: Part 1: 1973 (1987) Thermal and aerodynamic performance**
Methods of test for induction units with water coils for heating and/or sensible cooling duties.
- 4954: Part 2: 1978 (1987) Acoustic testing and rating**
Methods of acoustic testing and rating of induction units for sound power emission and terminal attenuation.
- 4979: 1986 Methods for aerodynamic testing of constant and variable dual or single duct boxes, single duct units and induction boxes for air distribution systems**
Methods of test for casing leakage, valve and damper leakage, flow rate control, temperature mixing, induction flow rate and pressure requirements.
- 5041: -- Fire hydrant systems equipment**
- 5041: Part 1: 1987 Landing valves for wet risers**
Material, design and performance requirements for copper alloy globe and diaphragm valves for wet rising mains. Covers high and low pressure types.
- 5041: Part 2: 1987 Landing valves for dry risers**
Material and design requirements for copper alloy gate valves for dry rising mains.
- 5041: Part 3: 1975 (1987) Inlet breechings for dry riser inlets**
Requirements for 2 and 4-way inlet breechings on a dry rising water main for fire fighters.

5041: Part 4: 1975 (1987) Boxes for landing valves

Dimensions to provide clearances and ensure that valves are easily accessible. Constructional details, requirements for hingeing, glazing, marking, locking of doors.

5041: Part 5: 1974 (1987) Boxes for foam inlets and dry riser inlets

Standard sizes according to the number of inlets for foam or to the size of the riser. Choice and thickness of material. Dimensions of glass in the door frame and marking thereon. May also be used for other purposes, e.g. fuel oil inlets and drencher systems.

5114: 1975 (1981) Performance requirements for joints and compression fittings for use with polyethylene pipes

Resistance to hydraulic pressure, external pressure and pull-out of assembled joints and effect on water and opacity.

5141: -- Air heating and cooling coils**5141: Part 1: 1975 (1983) Method of testing for rating cooling coils**

Duct-mounted cooling coil rating test with chilled water as the cooling medium within specified ranges of variables for inlet air and water temperatures and for water flow and air velocity.

5141: Part 2: 1977 (1983) Method of testing for rating heating coils

Rating test for duct-mounted air heating coils with hot water or dry saturated steam as the heating medium.

5258: -- Safety of domestic gas appliances**5258: Part 1: 1986 Central heating boilers and circulators**

Safety requirements and associated test methods for natural draught and fan-powered boilers of rated heat input up to 60 kW and for circulators of rated heat input not exceeding 8 kW for circulators.

5258: Part 5: 1989 Gas fires

Safety requirements and associated test methods for open-flued radiant and radiant convector gas fires.

5258: Part 7: 1977 Storage water heaters

Safety requirements and associated test methods for domestic appliances having an input rating not exceeding 20 kW.

5258: Part 9: 1989 Combined appliances: fanned circulation ducted air heaters/circulators

Safety requirements and associated methods of test for heaters either combined with, or designed to be fitted with, circulators. For rated heat inputs not exceeding 60 kW and 8 kW for circulators.

5258: Part 13: 1986 Convector heaters

Requirements and associated test methods for flued natural draught and fan-powered heaters of input rating not exceeding 25 kW.

5410: -- Code of practice for oil firing

5410: Part 1: 1977 Installations up to 44 kW output for space heating and hot water supply

5410: Part 2: 1978 Installation of 44 kW and above output for space heating, hot water and steam supply

Deals with provision of oil-burning systems for boiler and warm air heater plants and associated oil tanks.

5422: 1990 Thermal insulating material on pipes, ductwork and equipment (in the temperature range -40°C to $+700^{\circ}\text{C}$)

Insulation of surfaces of process plant, vessels, tanks, ducts, pipelines, boilers, ancillary plant. Domestic, commercial and industrial applications for heating fluids, steam and refrigeration and air conditioning.

5433: 1976 Underground stop valves for water services

Copper alloy screwdown stop valves, nominal sizes 1/2 to 2.

5440: -- Installation of flues and ventilation for gas appliances of rated input not exceeding 60 kW.

5440: Part 1: 1990 Installation of flues

Complete flue equipment from the appliance connection to the discharge to outside air.

5440: Part 2: 1989 Installation of ventilation for gas appliances

Air supply requirements for domestic and commercial gas appliances installed in rooms and other internal spaces and in purpose designed compartments.

5449: 1990 Forced circulation hot water central heating systems for domestic premises

General planning, design considerations, materials, appliances and components, installation and commissioning. Includes small bore and microbore systems, open and sealed systems.

5588: -- Fire precautions in the design and construction of buildings

5588: Part 9: 1989 Code of practice for ventilation and air conditioning duct work

Recommendations to limit the potential for the spread of fire and its by products.

5615: 1985 Insulating jackets for domestic hot water storage cylinders

Performance in respect of maximum permitted heat loss, materials, design and marking of jackets for cylinders to BS 699 and BS 1566.

5720: 1979 Code of practice for mechanical ventilation and air conditioning in buildings

General design, planning, installation, testing and maintenance of mechanical ventilating and air conditioning systems. Covers general

matters, fundamental requirements, design considerations, types and selection of equipment, installation, inspection, commissioning and testing, operation and maintenance, overseas projects.

5864: 1989 Installation in domestic premises of gas-fired ducted-air heaters of rated input not exceeding 60 kW

Selection, installation, inspection and commissioning. Includes commentary and recommendations.

5885: -- Automatic gas burners

5885: Part 1: 1988 Burners with input rating 60 kW and above

Safety aspects for burners employing forced or mechanically-induced draught, packaged or non-packaged types. Covers single burners and dual fuel burners when operating only on gas.

5885: Part 2: 1987 Packaged burners with input rating 7.5 kW up to 60 kW

Requirements for small packaged burners employing forced and induced draught. Covers single burners and dual fuel burners when operating only on gas.

5978: -- Safety and performance of gas-fired hot water boilers (60 kW to 2 MW input)

5978: Part 1: 1989 General requirements

Performance, safety and methods of test for burners operating at internal pressures up to 4.5 bar.

5978: Part 2: 1989 Additional requirements for boilers with atmospheric burners

5978: Part 3: 1989 Additional requirements for boilers with forced or induced draught burners

5990: 1989 Direct gas fired forced convection air heaters with rated inputs up to 2 MW for industrial and commercial space heating

Safety and performance requirements.

5991: 1989 Indirect gas fired forced convection air heaters with rated input up to 2 MW for industrial and commercial space heating

Safety and performance requirements and methods of test for permanently installed open flued space heating appliances for industrial and commercial applications.

6144: 1990 Expansion vessels using an internal diaphragm for unvented hot water supply systems

Requirements for manufacture and testing of steel vessels for use in systems operating with maximum pressure up to 10 bar.

6230: 1991 Installation of gas-fired forced convection air heaters for commercial and industrial space heating of rated input exceeding 60 kW

Requirements for the selection and installation of direct and indirect fired air heaters with or without ducting and with or without recirculation of heated air.

6283: -- Safety and control devices for use in hot water systems

6283: Part 1: 1991 Expansion valves for pressures up to and including 10 bar

Design, construction and testing of expansion valves of the automatic reseating type, specifically intended for preventing overpressurisation due to expansion of water in storage water heaters of the unvented type.

6283: Part 2: 1991 Temperature relief valves for pressures from 1 bar to 10 bar

Design, construction and testing of temperature relief valves of the automatic reseating type, specifically intended for use with and protection of storage water heaters of the unvented type.

6283: Part 3: 1991 Combined temperature and pressure relief valves for pressures from 1 bar to 10 bar

Design, construction and testing of combined temperature and pressure relief valves of the automatic reseating type, specifically intended for use with and protection of storage water heaters of the unvented type.

6283: Part 4: 1991 Drop tight pressure reducing valves of nominal sizes up to and including DN50 for pressures up to and including 12 bar

Design, construction and testing of drop tight pressure reducing valves, sometimes known as pressure limiting valves.

6332: -- Thermal performance of domestic gas appliances

6332: Part 1: 1988 Thermal performance of domestic heating boilers and circulators

Thermal efficiency and associated methods of test for boilers and circulators of rated heat input up to and including 60 kW and 8 kW respectively.

6332: Part 4: 1983 Thermal performance of independent convector heaters

Requirements and associated methods of test for heaters operating under natural draught.

6332: Part 6: 1990 Thermal performance of combined appliances: fanned circulation ducted air heater/circulator

Thermal efficiency requirements and associated methods of test for appliances of rated heat input not exceeding 60 kW with circulators not exceeding 8 kW.

6583: 1985 Methods for volumetric testing for rating of fan sections in central station air-handling units

Definitions of test unit and test installations, methods of test, presentation of data, extrapolation of data for geometrically similar sections and for those which are geometrically similar except for the fans, guide to the rating of air-handling units.

6644: 1991 Installation of gas fired hot water boilers of rated inputs between 60 kW and 2 MW

Requirements for the installation of single and groups of boilers, selection and siting, open vented and sealed systems, controls and safety, air supply and ventilation, flues and commissioning.

6675: 1986 Servicing valves (copper alloy) for water services

Three patterns of servicing valves for isolation of water supplies to individual sanitary appliances so that those appliances can be maintained or serviced.

6700: 1987 Design, installation, testing and maintenance of services supplying water for domestic use within buildings

System of pipes, fittings and connected appliances installed to supply any building with hot and cold water for general purposes.

6759: -- Safety valves

6759: Part 1: 1984 Safety valves for steam and hot water

Requirements for safety valves for boilers and associated pipework for steam pressures exceeding 1 bar and hot water boilers of rating 44 kW and above.

6798: 1987 Installation of gas-fired hot water boilers, of rated input not exceeding 60 kW

Selection, installation, inspection and commissioning of gas-fired central heating installations for domestic or commercial premises by circulation of heated water.

6880: -- Code of practice for low temperature hot water heating systems of output greater than 45 kW

6880: Part 1: 1988 Fundamental design considerations

Requirements which need to be taken into account in the design of open vented or sealed systems.

6880: Part 2: 1988 Selection of equipment

Types of low temperature hot water heating equipment in common use and the selection of such equipment.

6880: Part 3: 1988 Installation, commissioning and maintenance

Recommendations for installation, commissioning, operation and maintenance of open vented or sealed systems.

6896: 1991 Installation of gas-fired overhead radiant heaters for industrial and commercial heating

Installation, inspection and commissioning of heaters for other than domestic premises.

- 7074: -- Application, selection and installation of expansion vessels and ancillary equipment for sealed water systems**
- 7074: Part 1: 1989 Code of practice for domestic heating and hot water supply**
- 7074: Part 2: 1989 Code of practice for low and medium temperature hot water heating systems**
Vessels and systems for heating larger premises, commercial and industrial.
- 7074: Part 3: 1989 Code of practice for chilled and condenser systems**
Vessels and systems for air conditioning of commercial and industrial premises.
- 7186: 1989 Non domestic gas fired overhead radiant tube heaters**
Safety and construction and associated methods of test.
- 7206: 1990 Unvented hot water storage units and packages**
Requirements for units and packages heated directly or indirectly. Cylinders with capacities from 15 L to 500 L having minimum opening pressure of 1 bar and minimum operating pressure of 3 or 6 bar, fitted with safety devices to prevent water temperature from exceeding 100°C.
- 7291: -- Thermoplastic pipes and associated fittings for hot and cold water for domestic purposes and heating installations in buildings**
- 7291: Part 1: 1990 General requirements**
General requirements and application classes for pipes up to 67 mm in alternative metric sizes for plastics or copper. Performance requirements for associated fittings.
- 7291: Part 2: 1990 Polybutylene (PB) pipes and associated fittings**
Pipes 10 mm to 53 mm outside diameter.
- 7291: Part 3: 1990 Crosslinked polyethylene (PE-X) pipes and associated fittings and solvent cement**
Pipes 12 mm to 35 mm outside diameter. Includes cemented joints.
- 7291: Part 4: 1990 Chlorinated polyvinylchloride (PVC) pipes and associated fittings and solvent cement**
Pipes 12 mm to 63 mm outside diameter. Includes cemented joints.
- 7350: 1990 Double regulating globe valves and flow measurement devices for heating and chilled water**
Pressure and temperature rating, materials, performance requirements, testing, marking, installation and operating instructions.
- 7478: 1991 Guide to selection and use of thermostatic radiator valves**
Guidance on selection, application and use of thermostatic radiator valves.

7491: -- Glass reinforced plastics cisterns for cold water storage

7491: Part 1: 1991 One piece cisterns of capacity up to 500 L

7491: Part 2: 1992 One piece cistern of nominal capacity from 600 L to 25 000 L

7491: Part 3: 1994 Sectional tanks

7556: 1992 Thermoplastic radiator valves. Specification for dimensions and details on connection

7593: 1992 Code of practice for treatment of water in domestic hot water central heating systems

Guidance for the preparation of wet central heating systems prior to use, and for application of inhibitors.

8313: 1989 Code of practice for accommodation of building services in ducts

Recommendation for design, construction, installation and maintenance.

European Standards

BS EN 215: -- Thermostatic radiator valves

BS EN 215-1: 1991 Requirements and test methods

Definitions, mechanical properties, operating characteristics and test methods.

BS EN 253: -- Preinsulated bonded pipe systems for underground hot water networks. Pipe assembly of steel service pipes, polyurethane thermal insulation and outer casing of high density polyethylene.

Requirements and test methods for straight lengths of prefabricated thermally insulated pipe-in-pipe assemblies.

BS EN 297: 1994 Gas fired central heating boilers fitted with atmospheric burners of nominal heat input not exceeding 70 kW

BS EN 303: -- Heating boilers. Heating boilers with forced draught burners

BS EN 303-1: 1992 Terminology, general requirements, testing and marking

BS EN 303-2: 1992 Special requirements for boilers with atomising oil burners

BS EN 304: 1992 Heating boilers, Test code for heating boilers for atomising oil burners

BS EN 378: -- Refrigerating systems and heat pumps. Safety and environmental requirements

BS EN 378-1: 1995 Basic requirements

BS EN 442: -- Radiators and convectors**BS EN 442-1: 1996 Technical specifications and requirements****BS EN 442-1: 1997 Test methods and rating****BS EN 442-3: 1997 Evaluation of conformity****BS EN 448: 1995 Preinsulated bonded pipe systems for underground hot water networks. Fittings assemblies of steel service pipes, polyurethane thermal insulation and outer casing of polyethylene****BS EN 488: 1995 Preinsulated bonded pipe systems for underground hot water networks. Steel valve assembly of steel service pipes, polyurethane thermal insulation and outer casing of polyethylene****BS EN 489: 1995 Preinsulated bonded pipe systems for underground hot water networks. Joint assembly for steel service pipes, polyurethane thermal insulation and outer casing of polyethylene****BS EN 525: 1998 Non domestic direct gas fired convection air heaters for space heating not exceeding a net heat input of 300 kW****BS EN 621: 1998 Non domestic gas fired forced convection air heaters for space heating not exceeding a net heat input of 300 kW, without a fan to assist transportation of combustion air and/or combustion products****BS EN 625: 1996 Gas fired central heating boilers. Specific requirements for the domestic hot water operation of combination boilers of nominal heat input not exceeding 70 kW****BS EN 677: 1998 Gas fired central heating boilers. Specific requirements for condensing boilers with a nominal heat input not exceeding 70 kW****BS EN 778: 1998 Domestic gas fired forced convection air heaters for space heating not exceeding a net heat input of 70 kW, without a fan to assist transportation of combustion air and/or combustion products****BS EN 779: 1983 Particulate air filters for general ventilation. Requirements, testing, marking****BS EN 1020: 1998 Non domestic gas fired forced convection air heaters for space heating not exceeding a net heat input of 300 kW, incorporating a fan to assist transportation of combustion air and/or combustion products****BS EN 1057: 1996 Copper and copper alloys. Seamless round copper tubes for water and gas in sanitary and heating applications****BS EN 1196: 1998 Domestic and non-domestic gas fired air heaters. Supplementary requirements for condensing air heaters****BS EN 1254: -- Copper and copper alloys. Plumbing fittings****BS EN 1254-1: 1998 Fittings with ends for capillary soldering or capillary brazing to copper tubes**

BS EN 1254-2: 1998 Fittings with compression ends for use with copper tubes

BS EN 1254-3: 1998 Fittings with compression ends for use with plastics pipes

BS EN 1254-4: 1998 Fittings combining other end connections with capillary or compression ends

BS EN 1254-5: 1998 Fittings with short ends for capillary brazing to copper tubes

BS EN 1264: -- Floor heating. Systems and components

BS EN 1264-1: 1998 Definitions and symbols

BS EN 1264-2: 1998 Determination of the thermal output

BS EN 1264-3: 1998 Dimensioning

BS EN 1886: 1998 Ventilation for buildings. Air handling units. Mechanical performance

International Standards

BS ISO 4065: 1996 Thermoplastics pipes. Universal wall thickness table

BS EN ISO 5167: -- Measurement of fluid flow by means of pressure differential devices

BS EN ISO 5167-1: 1997 Orifice plates, nozzles and Venturi tubes inserted in circular cross section tubes running full

BS ISO 6243: 1997 Climatic data for building design. Proposed systems of symbols

BS EN ISO 6708: 1996 Pipework components. Definition and selection of DN (nominal size)

BS EN ISO 6946: 1997 Building components and building elements. Thermal resistance and thermal transmittance. Calculation method

BS EN ISO 9251: 1996 Thermal insulation. Heat transfer. Conditions and properties of materials. Vocabulary

BS EN ISO 9288: 1996 Thermal insulation. Heat transfer by radiation. Physical quantities and definitions

BS EN ISO 9300: 1995 Measurement of gas flow by means of critical flow Venturi nozzles

BS EN ISO 10211: -- Thermal bridges in building construction. Heat flows and surface temperatures

BS EN ISO 10211-1: 1996 General calculation methods

BS ISO 11922: -- Thermoplastics pipes for the conveyance of fluids. Dimensions and tolerances

BS ISO 11922-1: 1997 Metric series

BS ISO 11922-2: 1997 Inch-based series

BS EN ISO 13370: 1998 Thermal performance of buildings. Heat transfer via the ground. Calculation methods

BS ISO TR 15377: 1998 Measurement of fluid flow by means of pressure differential devices. Guidelines for specification of nozzles and orifice plates beyond the scope of ISO 5167-1

Describes the geometry and methods of use of various types of orifice plates and nozzles outside the scope of ISO 5167-1.

This Page Intentionally Left Blank

Index

- Abbreviations, 1, 2
- Absolute humidity, 79
- Absorption:
 - coefficient, 116, 237
 - dehumidification, 196
 - refrigeration, 190, 192
 - solar radiation, 116
 - sound, 237, 242
 - systems, 190, 196
- Accelerating effect of gravity, 7
- Activated alumina, 196
- Adsorption systems, 196
- Air:
 - altitude density table, 89
 - atmospheric, 78, 89
 - changes, 94, 165
 - combustion, for, 32, 37
 - comfort conditions, 114, 115
 - composition of, 89
 - conditioners, room
 - unit, 198, 201
 - conditioning, 113-118, 190-216, 220, 221, 222, 267
 - coolers, 190
 - cooling coils, 266
 - critical temperature and pressure, 48
 - curtains, 222
 - density, 78, 89
 - dewpoint, 79
 - dry:
 - density of, 84, 85, 86
 - enthalpy of, 80
 - weight of, 84, 85, 86
 - drying, for, 187
 - entering temperature, 91, 162
 - excess of, 32
 - exhaled, 87
 - expansion by heat of, 80
 - filters, 167, 273
 - general gas law, 78
 - handling units, 248, 268, 274
 - heat required for, ventilation, 94
 - heaters, 264, 266, 268, 273
 - heating coils, 266
 - humidity, 78, 80, 259
 - indoor conditions, 114, 115
 - man and, 87
 - mixing of, 81
 - mixture of with water, 78, 81, 84, 85, 86
 - movement, 91
 - pressure and velocity, 166
 - primary, 205
 - properties, 78
 - psychrometric chart, 80, 184, 185
 - Air (*cont*):
 - quantity:
 - for air curtain, 222
 - for combustion, 32
 - for drying, 187
 - for ventilation, 162
 - relative humidity, 79
 - respiration, 87
 - saturated, 78
 - space, conductance, 109
 - specific heat capacity, 80
 - humidity, 79
 - volume, 84, 85, 86
 - standard, 89
 - temperature, 88, 91, 92, 93, 114, 115, 162, 222
 - thermal expansion, 80
 - total heat, 84, 85, 86
 - velocity, 166, 167, 178, 179, 222
 - viscosity, 80
 - washers, 190, 194, 195
 - water vapour mixture, 78, 80, 81-85, 89
 - weight of, 78, 84, 85, 86, 89
 - Altitude-density table for air, 89
 - Alumina, activated, 196
 - Ammonia, 217
 - Anthracite, 30, 31, 32, 38
 - Apparatus, pressure drop in, 169
 - Areas:
 - conversions, 5
 - Asbestos pipes, 256, 257
 - Atmospheric:
 - air, 78, 89
 - pressure, 89
 - Atomic weights, 30
 - Attenuation of noise, 237-240
 - Axial flow fans, 230, 247

 - Barometric pressure, 89
 - Bathroom ventilation, 165, 166
 - Beaufort wind scale, 171
 - Bernoulli's equation, 223, 224
 - Bitumen coatings, 262
 - Bituminous coal, 30, 31, 32, 38
 - Black body, 50, 51
 - Boilers:
 - cast iron, 256
 - domestic, 262, 263
 - efficiency, 33
 - electrode, 130, 261
 - erection times, 243, 244
 - feed pumps, 139
 - gas fired, 268, 270, 272, 273
 - heat losses, 33

- Boilers: (*cont*)
rating, 119, 130, 152, 163
safety valves, 123, 124, 138
solid fuel, 262, 263
standards, 256, 257, 261, 262, 263
steel, 258
thermal performance, 257
- Boiling temperatures, 48, 64
- Boltzmann–Stefan formula, 50
- Building materials:
conductivities, 96–99
radiation constant, 51
- Burners:
oil, 257
solid fuel, 256
- Calorific value, 31
- Calorifier, 13, 151, 244, 258
- Capacities of:
calorifiers, 13
chimneys, 36
condensate pipes, 138
cylinders, 13
tanks, 11, 12, 14
- Carbon, 30
dioxide, 30, 33, 34, 35, 61, 62
monoxide, 30, 33, 61, 62
- Cast iron:
boilers, 256
fittings, 255
- Ceiling, chilled, 213, 214
- Central air conditioning plant, 203, 207
- Centrifugal:
fans, 230, 231, 232
pumps, 227, 228, 229
- Characteristic curves, 229, 230, 232
- Charcoal, 31, 32
- Chemicals, combustion of, 30
- Chilled:
ceiling, 213, 214
beams, 213
- Chill effect, 171
- Chimneys, 36, 264
- Circular equivalents of rectangular ducts,
164, 172
- Circulating pressure, 126
- Cisterns, 11, 12, 14, 255, 263, 271
- Classes of fuel, 39, 40
- Closed hot water system, 120, 122
- Coal:
anthracite, 30, 31, 32, 38
bituminous, 30, 31, 32, 38
calorific value, 31
classification, 40
constituents, 31
ignition temperature, 30
- Coal: (*cont*)
names of, 40
volume, 38
- Coefficients:
absorption, 116, 237
discharge, 225
entry, 178
expansion, 65
heat transmittance, 56, 100–108
resistance, 168
velocity, 178
- Coke, 30, 31
- Cold water, service, 155, 157
cisterns, 11, 12, 14
- Colours:
identification of pipes, 260
of temperatures, 49
- Combustion:
air, 32, 37
incomplete, 33
heat of, 30
temperature of, 30
- Comfort, 114, 115
- Composition:
of air, 89
of fuels, 31
- Compression refrigeration system, 190, 191
- Compressors, refrigeration, 193
- Computer rooms, 199, 201, 208
- Condensate pipes, 138
- Condensation on glass windows, 110
- Condensers, 52
- Conditions:
for comfort, 114, 115
for industrial purposes, 221
- Conduction, 49, 51, 113
- Conductivity:
definition, 49
of materials, 96–99
- Constant volume system, 208
- Consumption:
fuel, 111
gas, 159
hot water, 154
- Contents:
cylinders, 13
expansion tanks, 11, 12
sanitary fittings, 154
tanks, 12, 14
- Contract temperatures, equivalents, 95
- Convection, 49, 50, 113
- Convectors, 272
- Conventional signs, 3, 4
- Conversions, 5, 6, 7
- Conveying:
plants, 177
velocities, 186

- Coolers, 163, 190, 195, 264, 266
- Cooling:
 - curves, 53, 54, 81
 - free, 194
 - load, 113
 - methods, 190
 - Newton's law, 52
 - towers, 203, 247, 263
- Copper:
 - combination units, 262
 - direct cylinders, 256
 - fittings, 273, 274
 - indirect cylinders, 13, 260
 - tubes, 28, 59, 273, 274
- Counterflow, 52
- Critical:
 - pressure, 48, 68, 71
 - temperature, 48, 68, 71
- Curtain, air, 222
- Cylinders:
 - combination, 262
 - contents, 13
 - copper, 256, 260
 - dimensions, 13, 255
 - direct, 13, 256
 - erection times, 244
 - indirect, 13, 259, 260
 - steel, 255, 259
- Dampers, 249
- Decibel, 234, 235
- Defogging, 189
- Degree days, 111, 112
- Dehumidification, 196
- Density:
 - air, 84, 85, 86, 89
 - air-water vapour, 84, 85, 86
 - dry air, 78
 - fuel, 38
 - gases, 62
 - liquids, 60
 - metals, 60
 - oil, 38
 - smoke, 32
 - substances, 60
 - steam, 73, 74, 76, 77
 - water, 66, 67, 68
 - water vapour, 84, 85, 86
- Design:
 - air conditioning systems, 190
 - air curtains, 222
 - hot water heating systems, 119, 121
 - supply schemes, 151
 - ventilation systems, 162
- Desirable temperatures and humidity, 114, 115
- Dew point temperature, 79, 80, 81
- Diameter, equivalent for rectangular ducts, 164, 172
- Dimensions:
 - cylinders, 13, 255
 - fittings, 29
 - flanges, 20-25, 255, 263
 - tanks, 12
- Direct expansion, 199
- Direct hot water system, 151, 153
- Discharge:
 - coefficient, 225
 - orifices, through, 225
 - velocity, fans, 233
- Displacement ventilation, 213
- Domestic:
 - heating, 270, 272
 - hot water supply, 151-156
- Draught:
 - stabilisers, 36
 - velocity due to, 166
- Drawings:
 - sheet sizes, 2
 - standards, 2-4
- Dry air, 78, 84, 85, 86, 89
- Dry bulb temperature, 78, 81, 82, 83, 114, 115
- Dry riser, 158, 265
- Dry saturated vapours, 69
- Drying, 187, 188
- Dryness fraction of vapours, 69
- Dual duct:
 - boxes, 211, 265
 - system, 209
- Ducts:
 - altered surface conditions, 168
 - attenuation of noise in, 239
 - circular equivalents, 164, 172
 - friction in, 168
 - sizing, 164, 180-183
 - sound transmission, 239
 - temperature drop in, 163
 - thickness, 170
- Dust:
 - load for filters, 167
 - removal, 176, 177, 178
 - sizes, 187
- DX cooling, 199
- Effective temperature:
 - chart, 115
 - definition, 88
- Efficiency:
 - boilers, 33
 - fans, 230, 231, 232
 - pumps, 227, 228, 229

- Electrode boilers, 130, 261
- Entering air temperature, 91, 162, 209, 212, 213, 222
- Enthalpy:
 - air water mixture, 80, 84, 85, 86,
 - steam, 72-77
 - water, 66, 67
- Entropy:
 - definition, 69
 - of steam, 72-77
 - of water, 66, 67
- Entry loss, 178, 240
- Environmental temperature, 88
- Equipment:
 - air conditioning, 194-215
 - dust removal, 177, 178
 - pressure drop in, 169
- Equivalent:
 - duct sizes, 164, 172
 - length of fittings, 122, 125, 150, 220
 - temperature, 88, 95
- Evaporation:
 - entropy, 70
 - latent heat, 64
 - man, and, 87
 - water, 64, 68
- Evaporators, 52
- Excess air, combustion, 32
- Exhaust velocities, 169, 178
- Expansion:
 - air, 80
 - coefficient of, 65
 - gases, 45, 46, 47
 - heat, 45
 - tanks, 14, 122, 123
 - valve, 133, 190, 269
 - vessels, 123, 153, 264, 268, 270
 - water, 68
- Explosion doors, 36
- External:
 - latent heat, 69
 - resistance, 109
- Fan coil:
 - units, 202, 264
 - systems, 203
- Fan laws, 233
- Fans, 230-233
 - sound power level, 240, 241
 - testing, 258, 268
- Feed cisterns, 11, 12, 14
 - tanks, 12
- Feed pumps, boiler, 139
- Filters, 167, 248, 273
- Fire:
 - hydrants, 265
 - (*cont*)
 - precautions, 267
 - service, 158
- Fittings:
 - contents of, 154
 - equivalent length, 122, 125, 150, 220
 - high velocity systems, 220
 - malleable iron, 29
 - resistance, 124, 125, 149, 150, 168, 220
 - signs for pipe, 4, 5
 - standards, 255, 260, 261, 273, 274
 - water consumption, 154
 - wrought, 29
- Flanges, 20-25
- Flash point, 39
- Flash steam, 139, 148
- Floors:
 - construction for heating, 129, 274
 - thermal transmittance, 108
- Flow:
 - air, 164, 166, 169, 178
 - air into hoods, 177, 178, 179
 - fluids, 223, 224, 225
 - gas in pipes, 160
 - laminar, 41
 - measurement, 274, 275
 - oil, 41
 - temperature, 39, 124, 127
- Flue:
 - pipes, 245, 255, 256, 257, 258, 264
 - terminals, 256, 258
- Flue dilution, 37
- Flue gas:
 - analysis, 260, 261
 - heat loss in, 33, 34, 35
 - standards, 260
 - volume produced, 32
- Flues, 267
- Free cooling, 194
- Four pipe system, 202, 203, 205
- Free moisture in fuel, heat loss by 33,
- Freezing points, 64
- Friction:
 - air ducts, 164, 168
 - fittings, 125, 220
 - mixtures, of, 179
 - oil pipes, 41
- Fuel:
 - air, for combustion of, 32
 - bulk, of, 38
 - calorific value, 31
 - classification, 31, 40
 - coal, 31, 32, 40
 - combustion heat, 31
 - products, 32
 - composition, 31
 - consumption, 111

Fuel: (cont)

- density of, 38
- free moisture, 33
- gaseous, 31, 32, 34, 38
- ignition temperatures, 30
- oil, 31, 32, 35, 36, 38, 39, 41, 261
- solid, 31, 32, 38, 262, 263
- volume, stored, 38

Fume and dust removal, 176, 177, 178

Garage ventilation, 165

Gas:

- appliances, 159, 266, 268
- boilers, 270, 272
- burners, 268
- constant, 46, 61
- consumption by equipment, 159
- density, 62
- expansion, 45, 46, 47
- fuel, 31, 32, 34
- flow in pipes, 160, 274
- flue, 32, 33, 34, 35, 267
- heaters, 268, 270, 271, 273
- heating, of, 45, 46, 47
- laws, 45-48
- mixtures, 48
- natural, 31, 32, 34
- perfect, 48
- pipes, 160
- specific heat capacity, 61
- town, 31, 32, 34

Gauges, sheet and wire, 15, 16, 17

Glass:

- condensation, 110
- heat gain through, 117
- loss through, 104, 107, 110

Globe temperature, 88

Glycol cooled air conditioner, 201

Gravity:

- acceleration due to, 7
- heating, 120, 126

Grilles:

- erection times, 249
- velocity at, 169

Hangers, pipe, 262

Head:

- actual, 228
- of pumps, 227, 228, 229
- piezometric, 224
- pressure, 166, 224
- velocity, 166, 226

Heat:

- amount of in water, 66, 67, 73, 74, 76, 77
- combustion, 30

Heat: (cont)

- conduction, 49, 50, 51, 113
- convection, 49, 50, 113
- conversion, 5, 6
- drying, for, 187
- emission:
 - of appliances, 114, 159
 - at high temperature, 58, 131, 132
 - of occupants, 87, 113, 118
 - of pipes, 42, 57, 58, 59
- enthalpy, 69, 72-77
- entropy chart, 71
- equilibrium, 87
- evaporation, 64
- expansion, by, 45, 46
- flue gases, in, 33, 34, 35
- gain, 113, 114, 116, 117, 118
- humans, 87, 118
- input to storage, 130
- introduction by infiltration, 113, 114
 - by ventilation, 162
- latent, 64, 65, 69, 73, 74, 76, 77, 87, 118
- liquid, 66, 67, 69, 73, 74, 76, 77
- losses:
 - air changes, by, 94
 - appliances, 114
 - ash, in, 33
 - aspect, for, 91
 - boiler furnace, 33
 - calculation, 90, 91, 95
 - coefficients, 100-108
 - correction factors, 91
 - degree days, 111, 112
 - exposure, by, 91
 - flue gas, in, 33, 34, 35
 - free moisture, by, 33
 - height for, 88, 91
 - high buildings, 88, 94
 - humans, of, 87, 118
 - incomplete combustion, by, 33
 - infiltration, 88, 91
 - intermittent heating, 91
 - lagging, through, 59
 - moisture in fuels, 33
 - pipes of, 42, 57, 58, 59
 - radiation, 33
 - tanks, from, 42
 - transfer, coefficient, 100-108
 - transmittance coefficient, 56
 - unaccounted, 33
 - unburnt carbon in ash, by, 33
 - unsteady state, in, 52, 53, 54
 - warming up allowance, 54, 97
- pump, 133, 134, 199, 200, 272
- radiation, 50, 51, 113, 116, 117
- recovery, 204
- sensible, 33, 34, 35, 45, 87, 118

Heat: (*cont*)

- specific capacity, 45, 61, 63
- storage, 130
- terminology of, 49, 50
- thermal resistance, 50
- total:
 - of air, 84–85
 - of steam, 72–77
 - of vapours, 69, 70
 - of water, 66, 67
- transfer:
 - coefficient, 56, 100–108
 - condensers, 52
 - conduction, by, 49
 - convection, by, 49
 - counterflow, 52
 - evaporation, 52
 - metals, through, 56
 - mixed flow, 52
 - parallel flow, 51
 - partitions, through, 51, 52
 - pipes, through, 42, 57
 - radiation, by, 49
 - Stefan-Boltzmann formula, 50
 - thermal conductivity, 49
 - unsteady state, in, 52, 53, 54
 - transmission, coefficients for, 56, 100–108
 - ventilation, for, 163

Heaters:

- air, 163, 266, 268
- convection, 266, 269
- gas fired, 268, 270
- gases, of, 47
- gravity, 120
- high temperature hot water, 131, 132
- hot water, 119–124
- off peak, 130
- oil burning, 262
- pipe sizing, 122
- radiant, 270, 271
- room, 121
- steam, 135, 136
- storage, 130
- surface, 152
- unit, 264
- up allowance, 92
 - curves, 53, 54
- vacuum, steam, 137
- ventilation, combined with, 162

High buildings:

- heat losses, 88, 94
- water service, 157

High pressure:

- hot water, 119, 131, 132
- steam pipes, 150

High temperature hot water, 131, 132

High velocity air conditioning, 210, 211

Hoods, dust and fume extraction, 177, 178

Horizontal transport velocity, 179

Hot water:

- boiler, 119, 123, 152
- closed systems, 120, 122
- consumption, 154
- cylinders, dimensions, 13
 - standards, 256, 259, 260
- direct service, 151, 153
- flow temperatures, 124
- heating, 119, 120, 267, 272
- high pressure system, 119
- indirect system, 151, 153
- low pressure system, 119, 120
- medium pressure system, 119
- open system, 120, 122
- pipes, 152, 154, 155
- standards, 268, 271
- supply, 151, 152, 153
- system design, 151, 268
- unvented systems, 153, 271

Humans:

- comfort of, 114, 115
- heat given off by, 87, 113, 118

Humidification, 81, 194, 195, 197, 198

Humidity:

- chart for dry air, 81
- definition, 78, 259
- desirable, 114, 115, 221
- effect on comfort, 114, 115
- relative, 78, 81, 82, 83
- specific, 78
- standards, 259

Ice:

- specific heat capacity of, 68
- storage, 214, 215, 216

Identification of pipes, 260

Ignition temperatures, 30

Incandescent bodies, temperatures of, 49

Indirect:

- cylinders, 13, 259
- hot water system, 151, 153

Indoor air temperature, 93, 114, 115, 221

Induction:

- boxes, 265
- system, 205, 206, 207
- unit, 205, 264

Industrial:

- exhaust systems, 169, 176–179
- processes, temperatures and humidities for, 221

Infiltration:

- heat gain by, 113, 114
- loss by, 90, 91, 94

- Infiltration: (*cont*)
of air, 94
Inside temperature, 93, 114, 115, 221
Insulated pipes, 59, 272, 273
Insulation against sound:
walls, 237
windows, 238
Insulation, thermal, 59
Internal:
latent heat, 69
resistance, 109
Inverse square law, 236
Iron, malleable, fittings, 29
pipes, 255
- Kerosine, 31, 38, 39, 262
Kilogram molecule, 46
- Lagging, heat loss through, 59
Latent heat:
definition, 69
load, 113, 118
loss, of human body, 87, 118
melting, 64, 65
substances, 64, 65
vaporisation, 64, 73, 74, 76, 77
water, 64, 65, 68
Laws:
perfect gases, of, 45–47
thermodynamics, 45–47
Legionellosis, 152, 198
Lengths, equivalent, 122, 125, 150, 220
Lift, suction, of pumps, 139
Linear expansion by heat, 45, 65
Liquid fuel, 30, 31, 32, 35, 36, 38, 39
Liquids, densities, 60
Lithium bromide, 217
Logarithmic mean temperature differences,
51, 55
Low pressure:
hot water heating, 119
steam heating, 135
- Malleable iron fittings, 29
Manometric efficiency, 227, 228
Mechanical ventilation, 267
Melting:
latent heat, 64, 65
point, 64
Metals:
densities, 60
heat transmission coefficients, 56
specific heat capacities, 63
thermal conductivities, 96–99
weight of sheets, 18, 19
- Methane, 30
Micron, 187
Mixed flow, 52
Mixed flow fans, 232
Mixed mode ventilation, 174
Mixed gases, 48
Mixing unit, 209, 211
Mixtures:
friction loss, 179
of gases, 48
Moisture in air, 78–86
Mollier chart for steam, 71
Multiples, 2
 $n^{1.3}$ table of, 56
- Natural ventilation, 173–174
Newton's Law of cooling, 52
Noise, 234–242
Normal temperature and pressure, 89
NR rating, 235, 236
- Off peak storage heating, 130
Oil:
burners, 256, 264, 272
firing, 267
flow, 41
fuel, 31, 32, 35, 36, 38, 39, 41
pipes:
heat loss from, 42
storage tanks, 43, 44
heat loss from, 42
Olefin copolymer cisterns, 14
Orifices, discharge through, 225, 274
Outside air temperature, 93
- Parallel flow, 51
Particle sizes, 187
Peat, 30, 31, 32, 38
Pensky-Martens, 39
Perfect gas laws, 45–47
Perimeter heating, 212, 213
Piezometric head, 224
Pipe(s):
cold water, 155
colour identification, 260
condensate, 138
conduction of heat, 42, 51, 52, 57, 58, 59,
156
conventional signs, 3
copper, 28, 261, 273
domestic hot water supply, 152, 155, 156
erection times, 245, 249
fittings, malleable iron, 29, 260
polyethylene, 266

- Pipe(s): (*cont*)
 resistance in, 124, 125, 149, 150
 standards, 255, 259, 274
flanges, 20-25
flue, 245, 255, 256, 257, 258, 264
fluid flow through, 140-143, 223
gas, 160
heat losses, 42, 57, 58, 59, 156
hot water service, 154, 155
identification of, 260
insulated, 263
oil, 41, 42
plastic, 262, 271, 274
polybutylene, 271
polyethylene, 271
pressure, in, 27
PVC, 262
signs for, 3
sizing, 122, 140-147, 152
standards for, 263, 271
steam high pressure, 146, 147, 148, 150
 low pressure, 144, 145, 148, 149
steel, dimensions of, 26
supports, 262
temperature drop in, 156
underground, 272, 273
working pressure of, 27
- Plastic:
 cisterns, 14, 263, 273
 pipes, 262, 271, 274
 tanks, 14, 263, 273
- Pneumatic conveying plants, 176, 177, 179, 186
- Polyolefin cisterns, 14
- Pound molecule, 46
- Pressure:
 atmospheric, 89
 circulating, 126
 critical, 48, 68, 71
 drop, 169, 178
 equivalent, for, air, 166
 gauges, 246
 gravity, 126
 head, 166, 226
 normal, 89
 piezometric, 224
 static, 230, 231
 tubes, of, 27
 type conveying plant, 177
 vapour, 84, 85, 86
 velocity equivalent of, 166
 ventilation systems, in, 233
 water, of, 66, 67
 working, 27
- Preston, J. Roger, 95
- Primary air, 205
- Propeller fans, 230
- Psychrometric chart, 184, 185
- Pumps:
 boiler feed, 139
 centrifugal, 227, 228, 229
 erection times, 245
 heat, 133, 134
 laws, 228
 pressure, 121
 sizing, 121
 standard for, 259
 testing, 256
- PVC, 262
- Radiant heaters, 270, 271
- Radiant temperature, 88
- Radiation:
 constant, 51
 factor, 116
 from humans, 87
 losses, 33
 solar, 113, 116, 117
 transmission, 49, 50, 117
- Radiator:
 conventional signs, 4
 erection times, 246
 standards, 272
 valves, 271, 272
- Receiver, 134
- Recommended velocities, 169, 178
- Rectangular ducts, circular equivalents, 172
- Refrigerant:
 condensing units, 260
 properties, 217, 218, 219
- Refrigeration:
 absorption cycle, 190, 192
 compressors, 193
 flow diagram, 191, 192
 pressure-enthalpy curve, 191
 systems, 190, 272
 temperature-entropy curve, 191
 units, 260
 variable volume, 214
- Reheat system, 207
- Reheater, 207, 212
- Relative humidity, 79, 81, 82, 83
- Resistance:
 external, 109,
 of fittings, 124, 125, 149, 150, 168, 220
 internal, 109
 surface, 109
 thermal, 109, 274
- Resistivities, thermal, 90, 96-99
- Respiration, human, 87
- Resultant temperature, 88
- Reversible heat pump, 199, 200
- Reynolds number, 41

- Ringlemann scale for smoke density, 32, 261
- Riser, dry, 158
- Roof:
- glazing, 107
 - heat transfer coefficient for, 106, 107
 - spaces, 92
- Room:
- temperatures, 93
- Safe storage temperatures, 39, 130
- Safety valves:
- erection items, 246
 - for hot water boilers, 123, 124
 - standard for, 256, 269
 - for steam boilers, 138
- Saturated:
- air, 79, 84, 85, 86
 - steam, 69, 73, 74, 76, 77
 - water vapour, 84, 85, 86
- Schemes for:
- air conditioning, 198-214
 - domestic hot water, 153
 - flash steam recovery, 148
 - free cooling, 194
 - fume and dust removal, 176-179
 - hot water heating, 120
 - steam heating, 136, 137
 - tall buildings, 157
 - ventilation, 161, 173, 174
 - water supply, 153, 157
- Secondary air, 205
- Sensible heat, 33, 34, 35, 45, 87
- Separators, 187
- Sheet metal, 15-19
- Shell and tube cooler, 195
- Signs, conventional, 3, 4
- Silica-gel, 196
- Single duct:
- boxes, 265
 - system, 210
- Sizes:
- chimneys, 36
 - drawings, 2
 - ducts, 164, 170, 180-183
 - pipes, 122, 140-147, 152
 - pumps, 121
- Smoke:
- alarms, 261
 - density, 32, 261
- Solar radiation, 113, 117
- Solid fuel, 30, 31, 32, 38, 40
- boilers, 263
- Sound, 234-242
- attenuation, 238, 239, 240
- Space heaters, 262
- Specific enthalpy of steam, 72-77
- Specific heat capacity:
- air, 80, 94, 162
 - gases, 61
 - ice, 68
 - substances, 63
 - water, 66, 67, 68
- Specific humidity of air, 79
- Specific speed of pumps, 228
- Specific volume:
- air, 84, 85, 86
 - definition, 70
 - fuels, 38
 - steam, 73, 74, 76, 77
 - vapour, 70, 84, 85, 86
 - water, 66, 67
- Speed, specific, 228
- Spinning disc, 197
- Split system of air conditioning, 199
- of ventilation, 161
 - reversible heat pump, 199, 200
- Splitters, 242
- Sprayed coil, 197
- Stabilisers, draught, 36
- Stainless steel tubes, 263
- Stack effect, 176
- Standard:
- air, 89
 - wire gauge, 15, 16, 17
- Standards for drawings, 2
- Static pressure, 230, 231
- Steam:
- dryness fraction, 69
 - entropy, 70, 72-77
 - flash, 139, 148
 - heating, 135, 136, 138
 - humidifier, 198
 - Mollier chart, 71
 - pipe, 144-150
 - properties, 72-77
 - quality, 69
 - saturated, 69, 73, 74, 76, 77
 - superheated, 69, 70, 72, 75
 - tables, 72-77
 - temperature-entropy chart, 71
 - total heat, 69, 72-77
 - vacuum heating, 137
 - velocity of, 149
 - working pressures, 135
- Steel:
- bars, weight, 18, 19
 - flanges, 20-25
 - sheet, weight, 15, 16, 17
 - tubes, dimensions, 26
 - heat loss from, 57, 58
- Stefan-Boltzmann formula, 50
- Stokers, 256

Storage:

- cold water, 11, 12
- heating, off-peak, 130
- hot water, 154
- ice, 214, 215, 216
- safe temperature, 39, 130
- tanks and cylinders, 12, 13

Sub-multiples, 2**Suction lift of pumps, 139****Sulphur, 30**

- content of fuel, 31
- dioxide, 30

Superheated:

- steam, 72, 75
- vapour, 69

Surface:

- cooler, 190, 195
- ducts, allowance for, 168

Symbols, 1, 3, 4**Tanks:**

- erection times, 244
- expansion, 14, 122, 123
- oil, 42, 43, 44
- plastic, 271
- standard, dimensions of, 12
- standards for, 255, 256, 259, 263, 271

Taps, 258, 261**Temperature:**

- air curtain, 222
- air at supply grilles, 91, 162
- air at various levels, 91
- boiling, 64
- colours of, 49
- comfort, for, 114, 115
- constant, 47
- contract, 95
- conversion, 8, 9, 10
- critical, 48
- dew point, 79, 80, 81
- design, 93, 114
- drop:
 - in ducts, 163
 - in pipes, 156
- dry bulb, 79, 115
- drying, 188
- effective, 88, 115
- entropy chart, 71
- environmental, 88
- equivalent, 88, 95
- floor, 128
- flow, 124
- globe, 88
- high, heating, 131, 132
- ignition, 30
- incandescent bodies, 49

Temperature: (cont)

- industrial processes, for, 221
- logarithmic mean, 51, 55
- low temperature heating, for, 124
- melting, 64
- normal, 89
- outside, 93
- pumping, suction, 139
- radiant, 88
- relief valves, 269
- resultant, 88
- room, 93
- safe storage, 39, 130
- summer, 114
- underfloor heating, 127, 128
- unheated spaces, 92
- various levels, at, 92
- wet bulb, 79, 80, 81, 82, 83, 115
- winter, 93, 114

Temperature Ltd, 204, 205**Terminals:**

- dual duct, 265
- flue, 256
- reheat units, 265
- single duct, 265

Thermal:

- bridges, 274
- conductance, 49, 90
- conductivity, 49, 90, 96-99
- constants, 96-108
- expansion, 45, 46, 47
- insulation, 263, 267, 272, 273, 274
- properties of water, 66, 67, 68
- resistance, 50, 274
- resistivities, 90, 109
- storage plant, 130
- transmittance coefficients, 100-108

Thermo-equivalent conditions, 88, 95**Thermoplastic pipes, 271****Thermostatic radiator valves, 272****Threads:**

- pipe, 255

Time:

- for drying, 188
- lag, 116

Toilet ventilation, 165, 166**Ton of refrigeration, 194****Total heat:**

- air water mixture, 84, 85, 86
- definition, 69, 70
- entropy chart, 71
- steam, 72-77
- vapour, 69, 70
- water, 66, 67

Transport velocity, 179**Tubes:**

- copper, dimensions, of, 28

- Tubes: (*cont*)
 flow of gas in, 160, 274
 heat transmission through, 42, 57, 58,
 59, 156
 pressure, working, 27
 steel, dimensions of, 26
 fittings, 29
 standards, 259, 263
Two pipe system, 202, 205
- Underfeed stokers, 256
Underfloor heating, 127, 128, 129, 274
Unheated spaces, 92
Unit:
 coolers, 264
 heaters, 264
Universal gas constant, 46
Unsteady state heat transfer, 52, 53, 54
Unvented :
 heating systems, 120, 122
 hot water systems, 153
- Vacuum steam heating, 137
Valves:
 erection times, 245
 resistance of, 124, 125, 149, 150
 safety, 123, 124
 signs for, 3
 standards for, 256, 258, 259, 261, 269,
 270, 271, 272
Vaporisation, latent heat of, 64
Vapour, 69, 70, 84, 85, 86
Variable air volume system, 211, 212
refrigerant volume system, 214
Velocity:
 air curtain, 222
 air, due to draughts, 166
 air, in filters, 167
 ducts, 168
 dust extraction for, 178, 186
 fan outlet, 233
 fume removal, for, 178, 186
 head, 166, 226
 horizontal transport, 179
 pneumatic conveying for, 186
 pressure, equivalent, 166, 226
 recommended, 169, 178
 steam, of, 149
 transporting, 179
 ventilating system, 168
 vertical lifting, 179
 washers, 195
 water, 226
Ventilation:
 air changes, 94, 165
 quantity required, 162, 165
 temperature, 162
 bathroom, 165, 166
 chimneys, 174
 design, 162-165
 displacement, 213
 duct sizing, 164, 180-183
 equipment, 250
 garage, 165
 heat gain by, 114, 162
 required for, 94, 162
 natural, 173-176
 rates, 165
 resistance, 164, 167, 168, 169, 233
 schemes, 161, 173, 174
 standards, 267, 274
 velocity, 168
Venturimeter, 225, 274
Vertical lifting velocity, 179
Versatemp system, 204
Viscosity:
 conversion, 7
 of air, 80
 of oil, 39
 of water, 66, 67
Viscous air filter, 167
Volume:
 conversion of, 5
 fuel, of, 38
 specific, 38, 66, 67, 68, 73, 74, 76, 77, 84,
 85, 86
Volumetric expansion, 45, 68
- Walls:
 coefficients for, 100-104
 sound insulation and transmission, 237
Warming up allowance and time, 54, 91
Washers, air, 163, 190, 194, 195
Water:
 air vapour mixture, 78, 80, 81-85, 89
 boiling point of, 64, 69
 bulk elastic modulus of, 68
 cisterns, 11, 12, 14
 cold, service, 154, 155, 157
 consumption, 154, 155
 content, various materials, 188
 cooled air conditioning unit, 201
 waterchiller, 203
 density, 66, 67
 discharge through orifices, 225
 enthalpy of, 66, 67
 entropy of, 66, 67
 expansion of, 68
 evaporated from open vats, 189
 freezing temperature, 64, 68
 general data, 68

Water: (cont)

- hot, cylinders, 13, 362
- service, 151-156
- latent heat, 68
- properties of, 66, 67
- services, 268
- specific heat capacity of, 66, 67
 - volume of, 66, 67
- tall buildings, in, 157
- thermal properties of, 66, 67, 68
- treatment, 152, 198, 272
- total heat, 66, 67
- vapour, 78, 79, 84, 85, 86
- viscosity, 66, 67
- volume circulated, 121
- weight of, evaporated, 188, 189

W.C. ventilation, 165, 166**Weight:**

- atomic, 30
- of air, 78, 84, 85, 86, 89
 - for defogging, 189
 - for drying, 187
 - for ventilation, 162, 175
- conversion of, 5

Weight: (cont)

- flat iron, 18, 19
- sheet metal, 15, 16, 17
- steel bars and sheet, 18, 19
- tubes, 26
- water, 66, 67, 68
 - evaporated, 188, 189

Welding, 256**Wet bulb temperature, 79, 80, 81, 82, 83****Wet riser, 265****Windows:**

- air conditioning units, 198
- condensation on, 110
- heat transmittance coefficients, 104
- radiation through, 117
- sound insulation, 238

Wind:

- pressure, 175
- scoop, 174
- velocity, 171

Winter temperatures, 115**Wire gauges 15, 16, 17****Wood, as fuel, 30, 31, 32****Wrought fittings, 29**