



HEAT LOAD



FULL
Explanation

CALCULATION

PROCEDURE



EXPLAINED

PREPARED BY



What is HVAC Load Calculation.....?

- ❑ An HVAC Load Calculation is a mathematical process for measuring several aspects of a building in order to determine the best size, application and style of HVAC system.
- ❑ The purpose is to ensure energy efficiency while also maximizing comfort.
- ❑ Load calculations have been completed for several years, however, with new technology come quicker and more consistent methods to complete this important step.



Factors to considering during Cooling load requirement

❑ It is necessary for air conditioning designers to know about the heat source and their nature before designing of air conditioning system.

- ❖ Building detailed layout.
- ❖ Building orientation.
- ❖ Ambient condition.
- ❖ Use of Space.
- ❖ Physical dimension of space.
- ❖ Indoor design condition.
- ❖ Filtration level required.
- ❖ Glass area exposed to sun.
- ❖ Occupancy.
- ❖ Lighting load.
- ❖ Equipment load.
- ❖ Fresh air requirement.



HUMAN COMFORT

Application of HVAC System

- Residential
- Commercial
- Industrial
- Educational
- Pharmaceuticals
- Hospitals
- Malls/Offices
- And many more....



Air Conditioning Load Estimate

- ❑ The air conditioning load is to provide the basis of selecting the conditioning equipment.
- ❑ The load is designed for maximum conditions of heat such as :
 - Peak month.
 - Peak day and
 - Peak time of the year.
- ❑ The design load is divided into two types.
 - Outdoor Load
 - Indoor Load



HUMAN COMFORT

OUTDOOR LOADS :

- ❑ Heat flow through the exterior wall, ceilings, floors, windows and doors due to temperature difference between two sides.

LOAD DUE TO SOLAR RADIATION

- ❑ Heat from the Sun absorbed by the wall and roof and later transferred to room by conduction.
- ❑ Heat transmitted directly by radiation through glass of Window.
- ❑ Heat received form infiltration air from windows and doors due to frequent openings.




INDOOR LOADS :

- People
- Light
- Appliances
- Miscellaneous sources.

People



Appliances




Equipment



Lights

HEAT TRANSFER



- Heat gain from outdoors through the roof, exterior walls, skylights, and windows. (This includes the effects of the sun shining on these exterior surfaces.)
- Solar radiation heat gain through skylights and windows.
- Conduction heat gain from adjoining spaces through the ceiling, interior partition walls, and floor.
- Internal heat gains due to people, lights, appliances, and equipment in the space.

EXAPMLE

E20 FORM

Table 1-T-100 : Cooling and Dehumidifying
Heat Load Estimate Form

Job Name				
Address				
Space Used for				
Size	x	= Sq.Ft.x	=	Cu. Ft.
Item	Area of quantity	Sun Gain or Temp. Diff.	Factor	Btu / Hour
SOLAR GAIN GLASS				
Glass	Sq. Ft. x	x		
Glass	Sq. Ft. x	x		
Glass	Sq. Ft. x	x		
Glass	Sq. Ft. x	x		
Sky Light	Sq. Ft. x	x		
SOLAR AND TRAINS GAIN - WALLS AND ROOF				
Wall	Sq. Ft. x	x		
Wall	Sq. Ft. x	x		
Wall	Sq. Ft. x	x		
Wall	Sq. Ft. x	x		
Wall	Sq. Ft. x	x		
Roof Sun	Sq. Ft. x	x		
Roof Shaded	Sq. Ft. x	x		
TRAIN GAIN EXCEPT WALLS AND ROOF				
All Glass	Sq. Ft. x	x		
Partition	Sq. Ft. x	x		
Ceiling	Sq. Ft. x	x		
Floor	Sq. Ft. x	x		
INFILTRATION AND OUTSIDE AIR				
Infiltration	Cfm x	X 1.08		
Outside Air	Cfm x	°F BF X 1.08		
INTERNAL HEAT				
People	People			
Power	H.P. / KW			
Lights	x 1.08			
Appliances Etc.	x			
ROOM SENSIBLE HEAT				
Supply	Supply			
Duct	Duct			
Heat Gain%	Leak Loss %			
EFFECTIVE ROOM SENSIBLE HEAT				
ROOM LATENT HEAT				
Infiltration	cfm x	gr/lb x	0.68	
Outside Air	cfm x	gr/lb x	BF x 0.68	
People	People x			
Steam	Lb / hr x	1080		
Appliances, Etc.				
Vapor Train				
Room Latent Heat Sub Total				
Supply Duct Leakage Loss	% + SAFETY FACTOR %			
EFFECTIVE ROOM LATENT HEAT				
EFFECTIVE ROOM TOTAL HEAT				
Sensible	Cfm x	°F x (1-BF) x	1.08	
Latent	cfm x	gr / lb x (1-BF) x	0.68	
Grand Total Heat Sub Total				

Heat Gain%	Leak Loss			
TONS = GRAND TOTAL HEAT*				
Estimated for	Local Time	Peak Load	Local Time	
CONDITIONS	DB	WB	%RH	DP
Outside				
Room				
Difference		x x x	x x x	xx
Selected Room Conditions DB WB %RH				
People x $\frac{\text{VENTILATION}}{\text{INFILTRATION}}$ cfm Person				
Sg. Ft. x cfm / Sq. ft. = cfm. Ventilation				
SWINGING REVOLVING DOORS - PEOPLE X CFM / PERSON =				
Open Doors x CRM / DOOR =				
Exhaust Fan				
Crack Feet x cfm / Ft =				
SENSIBLE HEAT FACTOR AND APPARATUS DEWPOINT				
$\frac{\text{Eff. room sens. heat}}{\text{Eff. room total heat}} =$ Sens Heat Factor (ESHF)				
Indicated adp °F Selected adp. °F				
(1 - BF) (Room Temp. ADP = Dehumidified rise				
$\frac{\text{Room Sensible Heat}}{1.08 \times \text{Dehumidified rise}} =$ Dehumidified cfm				
NOTES				

HEAT LOAD ESTIMATE FORM

COOLING & DEHUMIDIFICATION

Q = HEAT FLOW (BTU/HR)

$$Q = U \times A \times \Delta T$$



U – Overall heat transfer coefficient of the material. [U = 1/ΣR]

A – Area of the surface in Square Feet.

Δ T – Temperature Outside – Temperature Inside.


WALL / ROOF HEAT LOAD

$$Q = U \times A \times \Delta T$$

U – Overall heat transfer coefficient of the material. [$U = 1/\Sigma R$]

A – Area of the surface in Square Feet.

ΔT – Temperature Outside – Temperature Inside.



GLASS HEAT LOAD


$$Q = A \times SC \times SCL$$

Q = heat gain by solar radiation through glass, Btu/hr [W]

A = total surface area of the glass, ft² [m²]

SC = shading coefficient of the window, dimensionless

SCL = solar cooling load factor, Btu/hr•ft² [W/m²]



HEAT LOAD CALCULATION

- A. SOLAR HEAT GAIN FOR (W) WALL, (F) FLOOR & (R) ROOF.
- B. SOLAR HEAT GAIN FOR (G) GLASS (WINDOWS).
- C. EFFECTIVE ROOM (E.R.S.H.L) SENSIBLE HEAT LOAD.
- D. EFFECTIVE ROOM (E.R.L.H.L) LATENT HEAT LOAD.
- E. EFFECTIVE ROOM (E.R.T.H.L) TOTAL HEAT LOAD.
- F. EFFECTIVE ROOM (E.R.S.H.F) SENSIBLE HEAT FACTOR.
- G. DEHUMIDIFIED (CFM) AIR FLOW.




HEAT LOAD CALCULATION

A. SOLAR HEAT GAIN FOR WALL AND FLOOR

$$Q = U \times A \times \Delta T$$

Condition Of Wall	Area in Sq.Ft	Temperature Difference in F	U Factor	BTU/Hr
West Partition	730	29	0.36	7621.20
North Exposed	451.5	31	0.3	4198.95
South Partition	645	29	0.36	6733.80
Floor	4708.5	29	0.19	25943.84
			Total	44497.79



SECTION - A

Number of Person = 110
 Total Floor Area = 4708.5 Sq.Ft

HEAT LOAD CALCULATION

A. SOLAR HEAT GAIN FOR WALL AND FLOOR


$$Q = U \times A \times \Delta T$$

Condition Of Wall	Area in Sq.Ft	Temperature Difference in F	U Factor	BTU/Hr
West Partition	730	29	0.36	7621.20
North Exposed	451.5	31	0.3	4198.95
South Partition	645	29	0.36	6733.80
Floor	4708.5	29	0.19	25943.84
			Total	44497.79

B. SOLAR HEAT GAIN FOR GLASS

$$Q = A \times SC \times SCL$$

Condition Of Wall	Area in Sq.Ft	SC	SCL	BTU/Hr
North Exposed	193.5	0.8	16.08	2489.28
			Total	2489.28



SECTION - A
 Number of Person = 110
 Total Floor Area = 4708.5 Sq.Ft

HEAT LOAD CALCULATION

C. EFFECTIVE ROOM SENSIBLE HEAT LOAD (E.R.S.H.L)

$$1. \text{ Outside Air} = \frac{\text{Volume of the room (ft}^3\text{) x No. of air changes}}{60} = \frac{4708.5 \times 10 \times 2}{60} = \mathbf{1569.5 \text{ CFM}}$$

$$2. Q_s \text{ (Sensible Heat)} = \text{CFM} \times (\Delta t) \times (bf) \times 1.08 \\ = 1569.5 \times 34 \times 0.15 \times 1.08 \\ = \mathbf{8,644.8 \text{ btu/hr.}}$$

$$3. \text{ Internal Heat} = \text{No. of People} \times \text{Sensible Heat Gain.} \\ = 110 \times 245 \\ = \mathbf{17,150 \text{ btu/hr}}$$

$$4. \text{ Light Load} = \text{Total area (sq.ft)} \times \text{lighting load (watts)} \times 3.4 \\ = 4708.5 \times 2 \times 3.4 \\ = \mathbf{32,017.8 \text{ btu/hr}}$$

$$5. \text{ Equipment Load} = \text{No. of Equipment} \times \text{Load} \times \text{equipment load (watts)} \times 3.4 \\ = 90 \times 300 \times 3.4 \\ = \mathbf{91,800 \text{ btu/hr}}$$

$$6. \text{ Total Sensible Heat Load} = 44,497.78 + 2,492,28 + 8,644.8 + 17,150 + 32,017.8 + 91,800 = \mathbf{206,402.66 \text{ btu/hr}}$$

Safety Factor 8%

$$7. \text{ Effective Room Sensible Heat Load} = \mathbf{222,914.87 \text{ btu/hr}}$$

(Δt) = Outside Temperature – Inside Temperature

$$1.08 = (0.224 \times 60) / 13.5$$

Where :

13.5 = Specific Volume of moist air at 70F DBT,

0.224 = Specific heat of moist air at 70F and 50%RH

and

0.15 = bf

245 = Sensible Heat Contribution in Room (ASHRAE)



HEAT LOAD CALCULATION

D. EFFECTIVE ROOM LATENT HEAT LOAD (E.R.L.H.L)

$$\begin{aligned}
 1. Q_L \text{ (Latent Heat)} &= \text{Outside air CFM} \times (\Delta w) \times (bf) \times 0.68 \\
 &= 1569.5 \times 36 \times 0.15 \times 0.68 \\
 &= \mathbf{5,763.204 \text{ btu/hr.}}
 \end{aligned}$$

$$\begin{aligned}
 (\Delta w) &= \text{Outside Humidity Ratio} - \text{Indoor Humidity Ratio} \\
 0.15 &= bf \\
 205 &= \text{Latent Heat Contribution in Room (ASHRAE)}
 \end{aligned}$$

$$\begin{aligned}
 2. \text{ Latent Heat Internal Load} &= \text{No. of People} \times \text{Latent Heat Gain.} \\
 &= 110 \times 205 \\
 &= \mathbf{22,550 \text{ btu/hr}}
 \end{aligned}$$

$$\begin{aligned}
 3. \text{ Total Latent Heat Load} &= 5,763.204 + 22,550 = \mathbf{28,313.204 \text{ btu/hr}} \\
 (1 + 2) & \qquad \qquad \qquad \text{Safety Factor 8\%}
 \end{aligned}$$

$$4. \text{ Effective Room Latent Heat Load} = \mathbf{30,578 \text{ btu/hr}}$$

HEAT LOAD CALCULATION

E. EFFECTIVE ROOM TOTAL HEAT LOAD (E.R.T.H.L)

$$\begin{aligned} \text{E.R.T.H.L} &= \text{E.R.S.H.L} + \text{E.R.L.H.L} \\ &= 222,914.87 + 30,578 \\ &= 253,492.87 \text{ btu/hr} \end{aligned}$$

$$\begin{aligned} \text{TR} &= \text{E.R.T.H.L} / 12,000 \\ &= 253,492.87 / 12000 \\ &= 21.12 \text{ TR (22 TR approx.)} \end{aligned}$$

F. <u>EFFECTIVE ROOM SENSIBLE HEAT FACTOR</u>	<u>E.R.S.H.L</u>	<u>222,914.87</u>	= 0.88
	E.R.T.H.L	253,492.87	

G. <u>DEHUMIDIFIED (C.F.M)</u>	<u>E.R.S.H.L</u>	<u>222,914.87</u>	11466.81 CFM
	1.08 x (RT – ADP)	1.08 x (72 – 54)	



HEAT LOAD CALCULATION

E. EFFECTIVE ROOM TOTAL HEAT LOAD (E.R.T.H.L)

$$\begin{aligned} \text{E.R.T.H.L} &= \text{E.R.S.H.L} + \text{E.R.L.H.L} \\ &= 222,914.87 + 30,578 \\ &= 253,492.87 \text{ btu/hr} \end{aligned}$$

$$\begin{aligned} \text{TR} &= \text{E.R.T.H.L} / 12,000 \\ &= 253,492.87 / 12000 \\ &= 21.12 \text{ TR (22 TR approx.)} \end{aligned}$$

$$\text{F. } \frac{\text{EFFECTIVE ROOM SENSIBLE HEAT FACTOR}}{\text{E.R.S.H.L}} = \frac{222,914.87}{253,492.87} = 0.88$$

$$\text{G. } \frac{\text{DEHUMIDIFIED (C.F.M)}}{1.08 \times (\text{RT} - \text{ADP})} = \frac{222,914.87}{1.08 \times (72 - 54)} = 11466.81 \text{ CFM}$$

Capacity : 22 TR
Air Flow : 11467 CFM



Thank
you